

ADDENDUM # 1

**CITY OF TORRANCE
3031 Torrance Blvd.
Torrance, CA 90503**

BID NO. B2015-36

Bid for Police Department Women's Restroom and Locker Room Remodel and Expansion

ADDENDUM # 1- Issued 11/25/15

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

Bid Due Date remains **Wednesday, December 9th by 3:00 PM** in the City Clerk's office.

CLARIFY: Verify existing fire sprinkler system in remodeled areas of Police Department remodel.
Modify existing fire sprinkler layout to coordinate with new floor plan configuration & obtain approval from the City of Torrance Fire Prevention Department.

Please return this addendum with your bid proposal.

I hereby acknowledge receipt of this addendum.

Name of Company

Address

City State Zip Code