

**ADDENDUM # 1**

**CITY OF TORRANCE  
3031 Torrance Blvd.  
Torrance, CA 90503**

**BID NO. B2016-06**

---

**Bid for Wilson Park Electrical Improvements**

---

ADDENDUM # 1- Issued 2/17/16

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

Bid Due Date remains **Wednesday, February 24th by 3:00 PM** in the City Clerk's office.

CLARIFY: Cameras at the batting cages will be removed by the City.

BID REVISIONS: As noted at the job walk, sheet E3.0 has been changed to note the correct embedment size (attached). The detail has been revised to call for the 3-1/4" size per ESR-1917.

**Please return this addendum with your bid proposal.**

I hereby acknowledge receipt of this addendum.

\_\_\_\_\_  
Name of Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
City

\_\_\_\_\_  
State

\_\_\_\_\_  
Zip Code