

ADDENDUM # 2

**CITY OF TORRANCE
3031 Torrance Blvd.
Torrance, CA 90503**

BID NO. B2016-21

Bid for Madrona Marsh Nature Center and Preserve Improvements

ADDENDUM # 2- Issued 5/23/16

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

Bid Due Date remains **Wednesday, June 1st, 2016 by 3:00 PM** in the City Clerk's office.

CLARIFICATION: Sheet A203: Key Note #1 – New Skylight Glass with frit pattern to match PV Glass (SHCG=32%, LIGHT TRANSMITTANCE = 16.30%). Glass framing support system shall be identical to PV Glass support system. Finish shall be Kynar finish. Provide pricing as part PV Glass system section.

CLARIFICATION: Sheet A204: Switch Lite Window – See Key Note #1.

CLARIFICATION: Sheet AD01: Use detail 2 / AD01 for PV Glass and Skylight Glass layout. Do not use detail 2 / E203 for PV Glass and Skylight Glass layout.

CLARIFICATION: Sheet AD01: Key Note #1: The drain referenced shall be Galvanized Alhambra Foundry Co. Ltd. product / part numbers A-2401 and A-2420.

CLARIFICATION: Sheet E203: DELETE General Notes #1. REPLACE with, "No visual observation indicated the presence of asbestos containing material in the area of work. However, the contractor shall notify the owner immediately if any asbestos containing material is observed during the implementation of the project."

Please return this addendum with your bid proposal.

I hereby acknowledge receipt of this addendum.

Name of Company

Address

City State Zip Code