

**ADDENDUM # 4**

**CITY OF TORRANCE  
3031 Torrance Blvd.  
Torrance, CA 90503**

**BID NO. B2016-43**

---

**Bid for Charles H. Wilson Park Gazebo Structure**

---

ADDENDUM # 4- Issued 9/29/16

THE FOLLOWING CHANGES ARE HEREBY INCORPORATED INTO AND MADE A MANDATORY PART OF SUBJECT BID:

Bid Due Date remains **Wednesday, October 5, 2016 by 3:00 PM** in the City Clerk's office.

Below is a question raised during the proposal preparation period with the answer in bold.

1. In reference to the project electrical plans, page E3 Fixture Schedule, the Fixture type C is a discontinued item. Please identify a substitute spec (or give a dollar amount if we should include an allowance for this item). Quantity is four.

**For Fixture type C use Deco Lighting D444-LEDM-30-35-UNV, or approved equal.**

**Please return this addendum with your bid proposal.**

I hereby acknowledge receipt of this addendum.

\_\_\_\_\_  
Name of Company

\_\_\_\_\_  
Address

\_\_\_\_\_  
City      State      Zip Code