

CITY OF TORRANCE, CALIFORNIA

ADDENDUM NO. 2
Issued: May 5, 2014

TO

PROPOSAL, SPECIFICATIONS, BOND AND AFFIDAVIT
FOR THE CONSTRUCTION OF

RESIDENTIAL SLURRY SEAL PROGRAM, I-159
AND
ARTERIAL STREET PAVEMENT SEALING PROGRAM, I-139
B2014-21

Note the following changes and/or additions to the Plans and/or Specifications for the project indicated above. The bidder shall execute the Certification at the end of this addendum, and shall attach all pages of this addendum to the Contract Documents submitted with the Bid. In addition, the bidder shall complete and submit the "Acknowledgment of Addenda Received" Form provided in Section C of the Specifications.

1. Refer to Specifications Section E – SPECIAL PROVISIONS: PART 3: CONSTRUCTION METHODS on page E-18.

The following is hereby added:

SECTION 300 - EARTHWORK

300-2.1 General. Add the following text:

Roadway Digouts:

Unclassified excavation of existing AC pavement and underlying materials will be required as directed by the Engineer. City staff will inspect the pavement condition to identify the locations and extents of each area. The minimum width of an area is expected to be no less than 8 feet and within a single travel lane. The City anticipates approximately 20 Dig Out areas, the smallest of which measuring approximately 200 SF.

300-2.9 Payment. Add the following:

Measurement & Payment for the removal and disposal of bituminous pavement and unclassified excavation to a total depth of 10 inches below existing roadway grade shall be considered as included in the Contract Unit Price for **DIG-OUTS** as measured in the field and shall include sawcutting, removal of underlying subgrade and base, disposal, subgrade preparation and compaction, placement & compaction of 6 inches of CMB, placement & compaction of 4 inches of Type B-PG-64-10 Asphalt Concrete, application of tack coat, and all labor and equipment.

By Order of the City Engineer



CRAIG BILEZERIAN
City Engineer

BIDDER'S CERTIFICATION

I acknowledge receipt of the foregoing Addendum No. 1 and accept all conditions contained therein.

Bidder

By

Date

******* Submit this executed form with the bid *******

**Please fill out and submit the
“Acknowledgment of Addenda Received” form
provided in Section C of the Specifications**