


PROJECT MANUAL WILSON PARK ELECTRICAL IMPROVEMENTS
B 2016-06



OCTOBER 2015

TABLE OF CONTENTS

	<u>Page No.</u>
A. NOTICE INVITING BIDS	3
B. INSTRUCTIONS TO BIDDERS	6
C. SPECIAL PROVISIONS	14
D. BID DOCUMENTS	26
Bidder's Proposal	
Addenda Acknowledgment	
Contractor's Affidavit	
Bid Bond (10% of Bid)	
List of Subcontractors	
References	
E. DOCUMENTS TO BE COMPLETED AND DELIVERED TO THE CITY AS PART OF CONTRACT WITH CITY	37
Performance Bond (100% of Bid)	
Labor and Material Bond (100% of Bid)	
Contract – Public Works Agreement	
Verification of Insurance Coverage (Certificates and Endorsements)	
F. PREVAILING WAGE DETERMINATIONS	
G. SPECIFICATIONS	

PART A
NOTICE INVITING BIDS

**CITY OF TORRANCE
CALIFORNIA**

NOTICE INVITING BIDS

Notice is hereby given that sealed proposals for performing the following described work will be received at the office of the City Clerk of the City of Torrance, California, until **3:00 p.m. on Wednesday, February 24, 2016** after which time they will be publicly opened and read at 3:15 p.m. in the Council Chambers of said City:

Bid for Wilson Park Electrical Improvements

B2016-06

Plans, Bid Proposal (for reference only) and Specifications are available for viewing and printing from the City's website at <http://www.torranceca.gov/25079.htm>.

There will be a mandatory pre-bid conference held on Tuesday, February 2, 2016 at 10:00 AM. commencing at Wilson Park, 2200 Crenshaw Boulevard Torrance, CA 90501 (meet in the parking lot north of the Hockey Rink). The City of Torrance will consider the bidder as non-responsive if the bidder does not attend the mandatory pre-bid conference. **Addenda will be issued only by email and only to those attended the mandatory pre-bid conference.** All addenda must be acknowledged. Failure to acknowledge addenda on the bid forms provided may render the proposal non-responsive and cause it to be rejected.

An official bid proposal packet, which includes: bid proposal forms, and a bound Specifications booklet may be obtained at the Office of the City Clerk (310) 618-2870, \$ 50.00 if picked up at City Hall, or payment of \$ 60.00 if requested by mail. Both amounts include tax. Neither amount is refundable. A prospective bidder must provide to the City Clerk's office, the firm's name, address, telephone and fax number, a contact person and a valid email address.

If requesting any item(s) by mail, please send check to the following:

**CITY OF TORRANCE
OFFICE OF THE CITY CLERK
3031 TORRANCE BLVD
TORRANCE, CA 90503-2970
ATTN: B2016-06**

The project estimate is between \$ 150,000 to \$ 195,000. The work shall be completed within ninety (90) calendar days of receipt of the Notice to Proceed (NTP). The ninety (90) calendar day schedule includes: completion of contractual paperwork, submittal review and onsite work. Bids are required for the entire work described herein.

The City has determined the bidder must have or C-10 Electrical Contracting license. Bidder, as the prime contractor, must have successfully completed at least four projects of a similar size and scope within the last five (5) years. Bidder must have at least five (5) years experience under the current license and organization. References must reflect this experience.

Per Division 2, Chapter 2 of the Torrance Municipal Code, the Torrance City Council may reject any and all bids, waive any informality or irregularity in such bids, and determine the lowest responsible bidder.

No Facsimile Bids shall be accepted by the City.

By order of the City Council of the City of Torrance, California.

This contract is subject to California State Prevailing Wage- Pursuant to Section 1771 and 1773 of the Labor Code, the general prevailing wage rates in the county in which the work is to be done have been determined by the Director of the California Department of Industrial Relations. These wages are set forth in the General Prevailing Wage Rates for this project, are attached and available from the California Department of Industrial Relations' internet site at <http://www.dir.ca.gov/Public-Works/Prevailing-Wage.html>. Future effective general prevailing wage rates which have been predetermined and are on file with the California Department of Industrial Relations are referenced but not printed in the general prevailing wage rates.

APPRENTICESHIP EMPLOYMENT STANDARDS. Attention is directed to the provisions in Sections 1776 and 1777.5 of the California Labor Code concerning the employment of apprentices by the Contractor or any subcontractor under them.

One of the legal requirements for working on a public works project is the employment of apprentices. The Division of Apprenticeship Standards provides assistance to contractors in employing apprentices on public works sites.

Information relative to apprenticeship standards, wage schedules, and other requirements may be obtained from the Director of Industrial Relations, <http://www.dir.ca.gov/das/PublicWorksForms.htm>

Contractor Registration with the Department of Industrial Relations (SB 854)

- No contractor or subcontractor may be listed on a bid proposal for a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code section 1771.1(a)].
- No contractor or subcontractor may be awarded a contract for public work on a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5.
- This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations. All contractors and subcontractors must furnish electronic certified payroll records directly to the Labor Commissioner (aka Division of Labor Standards Enforcement). For additional information and to register online go to <http://www.dir.ca.gov/Public-Works/Contractors.html>

For further information, please contact Diane Megerdichian, Sr. Business Manager General Services Department at 310-781-7151 or dmegerdichian@torranceca.gov. If emailing questions, please put project title in the subject line.

PART B
INSTRUCTIONS TO BIDDERS

**CITY OF TORRANCE
CALIFORNIA**

INSTRUCTIONS TO BIDDERS

A. QUALIFICATION OF BIDDERS

1. Competency of Bidders

The Bidder shall be thoroughly competent and capable of satisfactorily performing the Work covered by the Bid. As specified in the Bid Documents, the Bidder shall furnish statements of previous experience on similar work. When requested, the Bidder shall also furnish a plan of procedure proposed; organization, machinery, plant and other equipment available for the Work; evidence of financial condition and resources; and any other documentation as may be required by the City to determine if the Bidder is responsible.

2. Contractor's License

At the time of submitting the Bid, the Bidder shall be licensed as a contractor in accordance with the provisions of Chapter 9, Division 3, of the California Business and Professions Code. The required prime contractor license class for the Work is shown in the project Notice Inviting Bids. However, the City reserves the right to award the Contract to a contractor with another class if the City determines that the license is proper for the work.

B. BIDDER RESPONSIBILITY

A responsible Bidder is a Bidder who has demonstrated the attribute of trustworthiness, as well as ability, fitness, capacity and experience to satisfactorily perform the work.

Bidders are notified that, in accordance with Division 2, Chapter 2 of the Torrance Municipal Code, the City Council may determine whether the Bidder is responsible based on a review of the Bidder's performance on other contracts.

If, based on the provision and criteria in Division 2, Chapter 2 of the Torrance Municipal Code, the General Services Director proposes not to recommend the award of contract to the apparent low bidder, the Director shall notify the Bidder in writing of its intention to recommend to the City Council that the Council award the contract to the next lowest responsible bidder. If the Bidder presents evidence in rebuttal to the recommendation, the Director shall evaluate the merits of such evidence, and based on that evaluation, make a recommendation to the City Council.

C. ADDENDA TO THE CONTRACT DOCUMENTS

The City reserves the right to revise or amend these specifications prior to the date set for opening bids. Revisions and amendments, if any, will be announced by an addendum to this bid. If the revisions require additional time to enable Bidders to respond, the City may postpone the opening date accordingly. In such case, the addendum will include an announcement of the new opening date.

All addenda must be attached to the bid. Failure to attach any addendum may render the bid non-responsive and cause it to be rejected.

D. PREPARATION OF THE BID

1. Examination of Site, Plans and Specifications

Bidders shall examine the site of the work and acquaint themselves with all conditions affecting the work. By submitting a bid, the bidder shall be held to have personally examined the site and the drawings, to have carefully read the specifications, and to have satisfied itself as to its ability to meet all the difficulties attending the execution of the proposed contract before the delivery of this proposal, and agrees that if awarded the contract, will make no claim against the City based on ignorance or misunderstanding of the plans, specifications, site conditions and/or contract provisions.

The Contractor shall have included in the contract price a sufficient sum to cover all items, including labor, materials, tools, equipment and incidentals, that are implied or required for the complete improvements as contemplated by the drawings, specifications, and other contract documents.

2. Bid Instructions and Submissions

The Bid shall be submitted on the Bid Proposal forms included in the Specifications. All Bid Documents must be completed, executed and submitted with Bid by Bidder. Required seven (7) Bid Proposal Documents:

1. Bidder's Proposal
2. Addenda Acknowledgment
3. Contractor's Affidavit
4. Bid Bond (10% of Bid)
5. List of Subcontractors and DIR Registration
6. References (1 pages)
7. Bidder's Information (2 pages)

All prices submitted will be considered as including any and all sales or use taxes. In case of a discrepancy between a unit bid price and total bid, the unit price shall prevail.

E. BID FORM/BOND

The Bid must be accompanied by cash, a certified or cashier's check, or a surety bond (bid bond) payable to the City of Torrance. Bids must be submitted on the proposal forms furnished by the City Clerk's office. The Bid Guaranty shall be in an amount equivalent to at least 10% of the Total Contract Bid Price.

Within ten (10) days after the award of the contract, the City Clerk will return the proposal guarantees accompanying those proposals, which are not to be considered in making the award. All other proposal guarantees will be held until the contract has been finally executed, after which they will be returned to the respective bidders whose proposals they accompany.

F. AFFIDAVIT

An affidavit form is enclosed. It must be completed signifying that the bid is genuine and not collusive or made in the interest or on behalf of any person not named in the bid, that the bid has not directly or indirectly induced or solicited any other Bidder to put in a sham bid or any other person, firm, or corporation to refrain from bidding, and that the Bidder has not in any manner sought by collusion to secure for itself an advantage over any other Bidder. Any bid submitted without an affidavit or in violation of this requirement will be rejected.

G. NONRESPONSIVE BIDS AND BID REJECTION

1. A Bid in which bid proposal documents are not completed, executed and submitted may be considered non-responsive and be rejected.
2. A Bid in which the Contract Unit Prices are unbalanced, which is incomplete or which shows alteration of form or irregularities of any kind, or which contains any additions or conditional or alternate Bids that are not called for, may be considered non-responsive and be rejected.

H. AWARD OF CONTRACT

In accordance with Division 2, Chapter 2 of the Torrance Municipal Code, the City Council reserves the right to reject any and all bids received, to take all bids under advisement for a period not-to-exceed sixty (60) days after date of opening thereof, to waive any informality or irregularity in the Bid, and to be the sole judge of the merits of material included in the respective bids received.

This bid does not commit the City to award a contract or to pay any cost incurred in the preparation of a bid. All responses to this bid become the property of the City of Torrance.

I. NOTICE OF INTENT TO AWARD

Approximately two (2) weeks prior to the anticipated City Council meeting awarding a contract as a result of the RFP or bid, results will be posted on the City of Torrance Web site www.Torranceca.gov and may be found by clicking on the following:

- Government
- Current Bids and RFPs
- View evaluated results of Bids and RFPs tentatively scheduled for recommendation of award to the City Council [here](#).

J. BID PROTEST PROCEDURES

Please refer to City of Torrance website link below to obtain the City's Protest Procedures. http://www.torranceca.gov/PDF/Bid_RFP_Protest_Procedures.pdf

K. EXECUTION OF CONTRACT

After the Contract is awarded, the awarded bidder shall execute the following five (5) documents:

1. Performance Bond (100% of Bid)
2. Labor and Material Bond (100% of Bid)
3. Contract – Public Works Agreement
4. Verification of Insurance Coverage (Certificates and Endorsements)
5. Business License Application Form

The contract shall be signed by the successful bidder and returned, together with the contract bonds and evidence of required insurance coverage, **within ten (10) working days**, not including Sundays, after the bidder has received notice that the contract has been awarded. Failure to execute the contract as specified above shall be just cause for annulment of the award and forfeiture of the proposal guarantee. The Contract shall not be considered binding upon the CITY until executed by the authorized CITY officials.

Bond amounts shall be as provided in Section 2-4 of the Standard Specifications for Public Works Construction. The Performance Bond shall be required to remain in effect for one (1) year following the date specified in the City's Notice of Completion, or, if no Notice of Completion is recorded for one (1) year following the date of final acceptance by the City Manager.

L. PERMITS, LICENSES AND CONTRACT SERVICES AGREEMENT

The Contractor shall procure and execute all permits, licenses, pay all charges and fees, and give all notices necessary and incidental to completion of Work. The Contractor shall execute a Contract Services Agreement. No fee is charged for a permits issued by the City of Torrance for a City project. The Contractor shall obtain a City of Torrance Business License. To obtain a Torrance Business License please call 310-618-5923.

M. INSURANCE

The Contractor shall maintain Automobile Liability, General Liability and Workers' Compensation Insurance as specified in the Contract Services Agreement included in the Project Specifications.

N. SUBCONTRACTS

B. Each Bidder shall comply with the Chapter of the Public Contract Code including sections 4100 through 4113. The Contractor shall perform, with its own organization, Contract work amounting to at least 50 percent of the Contract price. When a portion of an item is subcontracted, the value of the work subcontracted will be based on the estimated percentage of the Contract Unit Price, determined from information submitted by the Contractor, subject to approval by the City Manager (or his designated representative). This percentage will be based on direct labor hours used on the project. Supervision and overhead are not included in this calculation.

O. TRAFFIC CONTROL- Not applicable

P. PRE-BID INQUIRIES

Bidders with pre-bid inquiries must submit questions in writing to the General Services Department. Any and all questions must be emailed to Diane Megerdichian, Business Manager at DMegerdichian@torranceca.gov. Please list "**Wilson Park Electrical Improvements**" in the subject line of the email. For questions of a general nature, bidders may contact Diane Megerdichian directly at 310-781-7151

Q. RESPONSIBILITY OF CITY.

The City of Torrance shall not be held responsible for the care or protection of any material or parts of the work prior to final acceptance, except as expressly provided in these specifications.

R. CONSTRUCTION SCHEDULE AND PRECONSTRUCTION CONFERENCE.

The office staff of the City is currently operating on a 9/80 work week; therefore, City Hall is closed every other Friday.

In accordance with the herein Special Provisions, after notification of award and prior to start of any work, **the Contractor shall submit to the City for approval its proposed Construction Schedule within ten (10) working days from the date of Notice of Proceed.** At least two (2) days, exclusive of Saturdays, Sundays and holidays, prior to commencement of work, the Contractor shall attend a pre-construction conference.

The Contractor will provide all product and equipment submittals to the City of Torrance or designated consultant within ten (10) working days from the date of Notice to Proceed. The Contractor shall immediately order materials requiring a delivery delay upon receipt of a written notice from the City that the City Council has approved an Award of Contract. Contractor shall provide written proof(s) of timely material order(s) and shall include any delivery delays in the Construction Schedule.

S. PROGRESS OF THE WORK AND TIME FOR COMPLETION

The Contractor shall begin work after the mailing, from the City Manager to the Contractor, by first class mail, postage prepaid, of a Notice to Proceed. **The Contractor shall diligently prosecute the same to completion within ninety (90) calendar days of the start date specified in said Notice.** The ninety calendar schedule includes, completion of contractual paper work, equipment material submittal review, the lead time for materials and equipment, and on site work.

During periods when weather or other conditions are unfavorable for construction, the Contractor shall pursue only such portions of the work as shall not be damaged thereby. No portions of the work whose acceptable quality or efficiency will be affected by any unfavorable conditions shall be constructed while those conditions exist. It is expressly understood and agreed by and between the Contractor and the City that the Contract time for completion of the work described herein is a reasonable time taking into consideration the average climatic and economic conditions and other factors prevailing in the locality of the work.

T. LIQUIDATED DAMAGES

The Contractor agrees that failure to complete work within the time allowed will result in damages being sustained by the City. Contractor and City agree that failure to complete the project will result in inconvenience to the citizens of Torrance and the City of Torrance and their customers using the affected areas. Such delay will also result in the necessity of several inspections each day to ensure that the project is properly progressing. The parties also agree that failure to complete the project on time will prevent the City from having the use of the facility. Therefore, the parties agree such damages among others are, and will continue to be, impracticable and extremely difficult to determine, but that **five hundred (\$500) per calendar day** is the minimum value of such costs to the City and is a reasonable amount that the Contractor agrees to reimburse the City for each calendar day of delay in finishing the work in excess of the time specified for completion, plus any authorized time extensions.

Execution of the contract under these specifications shall constitute agreement by the Contractor and the City that five hundred Dollars (\$500) per calendar day is the minimum value of the costs and actual damage caused by failure of the Contractor to complete the work within the allotted time, that such sum is liquidated damages and shall not be construed as a penalty, and that such sum may be deducted from payments due the Contractor if such delay occurs. Said amount may be reduced by the City if work is sufficiently completed within the allotted time so that the damages are minimized.

The Contractor will not be assessed liquidated damages for any delay in completion of the work when such delay was caused by the failure of the City or the owner of a utility to provide for removal or relocation of the existing utility facilities; provided, however, that the Contractor shall have given the City and the owner of a utility timely notice of the interference. "Timely notice" shall be defined as a verbal notice (to be followed up in writing) no later than one (1) hour after initial discovery of the interference unless the City Representative is present, in which case notice shall be given immediately in writing to the City Manager.

U. GENERAL PREVAILING WAGE RATE

Pursuant to Section 1771 and 1773 of the Labor Code, the general prevailing wage rates in the county in which the work is to be done have been determined by the Director of the California Department of Industrial Relations. These wages are set forth in the General Prevailing Wage Rates for this project, are attached and available from the California Department of Industrial Relations' internet site at <http://www.dir.ca.gov/Public-Works/Prevailing-Wage.html>. Future effective general prevailing wage rates which have been predetermined and are on file with the California Department of Industrial Relations are referenced but not printed in the general prevailing wage rates.

APPRENTICESHIP EMPLOYMENT STANDARDS. Attention is directed to the provisions in Sections 1776 and 1777.5 of the California Labor Code concerning the employment of apprentices by the Contractor or any subcontractor under them.

One of the legal requirements for working on a public works project is the employment of apprentices. The Division of Apprenticeship Standards provides assistance to contractors in employing apprentices on public works sites.

Information relative to apprenticeship standards, wage schedules, and other requirements may be obtained from the Director of Industrial Relations, <http://www.dir.ca.gov/DAS/DASApprenticesOnPublicWorksSummaryOfRequirements.htm>

Contractor Registration with the Department of Industrial Relations (DIR)

- No contractor or subcontractor may be listed on a bid proposal for a public works project (submitted on or after March 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code section 1771.1(a)].
- No contractor or subcontractor may be awarded a contract for public work on a public works project (awarded on or after April 1, 2015) unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5.
- This project is subject to compliance monitoring and enforcement by the Department of Industrial Relations.
- All contractors and subcontractors must furnish electronic certified payroll records directly to the Labor Commissioner (aka Division of Labor Standards Enforcement).

For additional information and to register online go to <http://www.dir.ca.gov/Public-Works/Contractors.html>

DIR provides a searchable database of registered contractors and subcontractors on its website <https://efiling.dir.ca.gov/PWCR/Search>, so that all contractors can comply with the requirement to only use registered contractors and subcontractors

Labor Code Section 1813

The contractor or subcontractor shall, as a penalty to the state or political subdivision on whose behalf the contract is made or awarded, forfeit twenty-five dollars (\$25) for each worker employed in the execution of the contract by the respective contractor or subcontractor for each calendar day during which the worker is required or permitted to work more than 8 hours in any one calendar day and 40 hours in any one calendar week in violation of the provisions of this article. In awarding any contract for public work, the awarding body shall cause to be inserted in the contract a stipulation to this effect. The awarding body shall take cognizance of all violations of this article committed in the course of the execution of the contract, and shall report them to the Division of Labor Standards Enforcement.

Labor Code Section 1815

Notwithstanding the provisions of Sections 1810 to 1814, inclusive, of this code, and notwithstanding any stipulation inserted in any contract pursuant to the requirements of said sections, work performed by employees of contractors in excess of 8 hours per day, and 40 hours during any one week, shall be permitted upon public work upon compensation for all hours worked in excess of 8 hours per day at not less than 1¹/₂ times the basic rate of pay.

V. **PRELIMINARY NOTICES**

Preliminary Notices should be mailed to the following address.

Diane Megerdichian
General Services Department
3350 Civic Center Drive
Torrance, CA 90503

PART C
SPECIAL PROVISIONS

SECTION A. GENERAL

The Project Specifications for all work on this project are the specifications contained in the "Project Manual for Wilson Park Electrical Improvements", prepared by J.C. Chang & Associates, Inc. and the City of Torrance.

These Specifications are intended to govern all aspects of the appurtenant construction including, but not limited to, materials, methods and details, except as modified herein or as inconsistent with the provisions hereof.

DEFINITIONS

Whenever the following terms are used, they shall be understood to mean and refer to the following:

CITY - City of Torrance.

Board- The City Council of the City of Torrance herein referred to as City Council.

City Manager- The General Services Director of the City of Torrance, acting either directly or through properly authorized agents, such agents acting within the scope of the particular duties entrusted to them.

Consulting Architect – Sevag Avanesian
J.C. Chang & Associates, Inc.
385 Van Ness Avenue, Suite 208
Torrance, California 90501
Ph: (310) 212-7644 ext. 228
Email: SAvanessian@jccainc.com

Laboratory - The designated laboratory authorized by the City of Torrance to test materials and work involved in the contract.

SECTION B. REFERENCE TO STANDARDS OR PUBLICATIONS

Any reference made in the Contract Documents to any specification, standard, or publication of any organization shall, in the absence of a specific designation to the contrary, be understood to refer to the latest edition of the specification, standard, or publication in effect as of the date of advertising the work, except to the extent that said standard or publication may be in conflict with applicable laws, ordinances, or governing codes. Contractors should be aware of all new code requirements (such as Cal-Green) when dealing with HVAC and other general building work. No requirements of these specifications or the drawings shall be waived because of any provisions of, or omission from, said standards or publications.

SECTION C. DESCRIPTION OF THE WORK

1. Scope of the Work. The work to be done consists of furnishing all labor, materials, tools, equipment and incidentals complete the Wilson Park Electrical Improvements as shown in the plans and specifications prepared by J.C. Chang & Associates, Inc. and the City of Torrance.

SECTION D. GENERAL PROCEDURES

1. Specifications and Drawings Complementary. The Specifications and Drawings are complementary, and what is called for in one shall be as binding as if called for in both.
2. Order of Precedence of Contract Documents. In resolving conflicts resulting from conflicts, errors, or discrepancies in any of the Contract Documents, the order of precedence shall be as follows:
 1. Change Orders (including Plans and Specifications attached thereto).
 2. Permits Issued by other agencies.
 3. Contract Services Agreement
 4. Addenda
 5. Special or General Provisions.
 6. Plans
 7. City Standard Plans
 8. Instructions to Bidders
 9. Reference Specifications

Within the Specifications the order of precedence is as follows:

1. Addenda/Change Orders
2. Permits from other agencies/supplemental agreements
3. Special or General Provisions
4. Instructions to Bidders
5. Referenced Standard Plans
6. Referenced Specifications

With reference to the Plans/Drawings the order of precedence is as follows:

1. Change Orders plans govern over Addenda and Contract Drawings
 2. Addenda plans govern over Contract plans.
 3. Contract plans govern over standard plans
 4. Detail plans govern over general plans
 5. Figures govern over scaled dimensions
3. Discrepancies in the Contract Documents. Any discrepancies, conflicts, errors or omissions found in the Contract Documents shall be promptly reported in writing to the City Manager, who will issue a correction in writing. The Contractor shall not take advantage of any such discrepancies, conflicts, errors or omissions, but shall comply with any corrective measures regarding the same prescribed by the City Manager, and no additional payment or time shall be allowed therefor.

If discrepancies are discovered between the drawings and the specifications, and no specific interpretation is issued prior to bidding, the decision regarding this interpretation shall rest with the City Manager. The Contractor shall be compelled to act on the City Manager's decision as directed. In the event the installation is not in compliance with the direction of the City Manager, the installation shall be corrected by and at the expense of the Contractor at no additional cost to the City.

See Section E of these Special Provisions for "Claims".

4. Errors and Omissions. If the Contractor, in the course of the work, becomes aware of any claimed errors or omissions in the contract documents or in the City's field work, he shall immediately inform the City Manager. The City Manager shall promptly review the matter, and if the City Manager finds an error or omission has been made the City Manager shall determine the corrective actions and advise the Contractor accordingly. If the corrective work associated with an error or omission increases or decreases the amount of work called for in the Contract, the City shall issue an appropriate Change Order. After discovery of an error or omission by the Contractor, any related work performed by the Contractor shall be done at its risk unless authorized by the City Manager.
5. Changed Conditions. The plans for the work show conditions as they are believed by the City Manager to exist, but it is not intended or to be inferred that the conditions as shown thereon constitute a representation by the City that such conditions are actually existent, nor shall the City be liable for any loss sustained by the Contractor as a result of any variance of the conditions as shown on the plans and the actual conditions revealed during the progress of the work or otherwise. The word "conditions" as used in this paragraph includes, but is not limited to, site conditions, both surface and subsurface.

The Contractor shall examine the site, compare it with the drawings and specifications and shall satisfy itself as to the conditions under which the work is to be performed. The Contractor shall ascertain and check the location of all existing structures, utilities and equipment, which may affect its work. The Contractor shall be responsible to re-examine the site, as necessary, for performance of change orders or other proposed changes, which may affect its work. No allowance shall subsequently be made on the Contractor's behalf for any extra expense or loss of time, which is incurred due to failure or negligence on its part to make such examination.
6. As-built Drawings. The Contractor shall maintain a control set of Plans and Specifications on the Work site at all times. All final locations determined in the field, and any deviations from the Plans and Specifications, shall be marked in red on this control set to show as-built conditions. Upon completion of the Work, the Contractor shall submit the control set to the Engineer for approval. Final payment will not be made until this requirement is met.
7. Construction Staking. The Contractor is responsible for all construction staking and shall be responsible for the cost of any restaking required due to disturbance caused by its operations, failure to protect the work site from vandalism or other causes of loss.

8. Notice to Proceed. Notwithstanding any other provisions of the Contract, the Contractor shall not be obligated to perform any work and the City shall not be obligated to accept or pay for any work performed by the Contractor prior to delivery of a Notice to Proceed. The City's knowledge of work being performed prior to delivery of the Notice to Proceed shall not obligate the City to accept or pay for such work. The Contractor shall provide all required contract bonds and evidences of insurance prior to commencing work at the site.
9. Delay in Obtaining Materials. No extension of time will be granted for a delay caused by the inability to obtain materials unless the Contractor either obtains advance written approval from the City Manager or obtains from the supplier and furnishes to the City Manager documentary proof that such materials could not be obtained due to war, government regulations, labor disputes, strikes, fires, floods, adverse weather necessitating the cessation of work, or other similar action of the elements. The Contractor is required to order materials in a timely manner as specified in the "Instruction to Bidders".
10. Inspection and Testing. The Work is subject to inspection and approval by the CITY or any authorized representative. It is the duty of the Contractor to notify the inspector that specific work is ready for inspection. Requests for inspections should be made through the automated phone system at 310-618-5901, using the permit number and following the prompts. Request can be made up to 11pm the night before an inspection is required. The inspection will be typically made the next day.

All rough Mechanical, Electrical and Plumbing should be inspected by the City Specialty Inspectors and approved prior to any framing inspection. 2. All framing, fire-blocking and bracing shall be in place prior to ordering a framing inspection. 3. Gypsum board shall only be installed after approved framing inspection and then order a gypsum board nailing inspection prior to tape and finishing.

The CITY will make, or have made, such inspections and tests, as he deems necessary to see that the Work is in conformance with the Contract Documents. The contractor will responsible for coordinating all inspections/tests and pay for all related costs. In the event such inspections or tests reveal noncompliance with the Contract Documents, the Contractor shall bear the cost of such corrective measures as deemed necessary by the CITY, as well as the cost of subsequent re-inspection and re-testing.

Work done in the absence of inspection by the CITY may be required to be removed and replaced under the inspection of the CITY, and the entire cost of removal and replacement, including the cost of all materials which may be furnished by the CITY and used in the work thus removed, shall be borne by the Contractor, regardless of whether the work removed is found to be defective or not. Work covered without the approval of the CITY shall, if so directed, be uncovered to the extent required by the CITY, and the Contractor shall similarly bear the entire cost of performing all the work and furnishing all the materials necessary for the removal of the covering and its subsequent replacement, including all costs for additional inspection.

The CITY and any authorized representatives shall at all times have access to the Work during its construction at shops and yards as well as the Work site. The Contractor

shall provide every reasonable facility for ascertaining that the materials and workmanship are in accordance with the Contract Documents.

Inspection of the Work shall not relieve the Contractor of the obligation to fulfill all conditions of the Contract.

11. Project Schedule

Within ten (10) working days after the receipt of the Notice to Proceed, the Contractor shall submit a proposed construction schedule to the CITY for approval. The schedule shall be in accordance with section 11 and shall be in sufficient detail to show chronological relationship of all activities of the Work. These include, but are not limited to: estimated starting and completion dates of various activities, submittal of shop drawings to the Engineer for approval, procurement of materials and scheduling of equipment.

No work may be started until the Schedule has been approved in writing. The work shall be scheduled to assure that construction will be completed within the specified time. The Contractor shall be responsible for coordination of all phases of the operation so that the time schedule can be met.

During construction, the Contractor shall also submit to the CITY, a two-week "look ahead" construction schedule during the construction progress meetings held biweekly.

If the Contractor decides to make a major change in the method of operations after commencing construction, or if the schedule fails to reflect the actual progress, the Contractor shall submit to the CITY a revised construction schedule in advance of beginning revised operations.

Sequence of Construction - The Contractor shall sequence the Work in a manner to expeditiously complete the project with a minimum of inconvenience to the CITY or adjacent owners.

The construction schedule shall conform to the following criteria:

- 1) The schedule shall be prepared using the latest version of Microsoft Project or approved equal.
- 2) Work activities shall be based on the following:
 - a) Contract Unit Price items shall be subdivided into those portions to be constructed during each stage or phase of construction. (if applicable)
 - b) Lump sum items shall be subdivided into those portions to be constructed during each stage or phase of construction.
- 3) Utility relocations and/or coordination by the Contractor per section 14 of these Special Provisions shall be considered as activities.
- 4) Required submittals, working and shop drawings shall be included as activities.

- 5) The procurement of construction materials and equipment with long lead times for deliveries shall be included as activities.
- 6) Work to be performed by subcontractors shall be identified and shown as work activities.
- 7) Start and completion dates of each activity shall be illustrated.
- 8) Completion of all Work under the Contract shall be within the time specified in these Special Provisions and in accordance with the Plans and Specifications.

12. Mobilization

12.1 Scope. Mobilization shall include the provision of the Construction Schedule; Best Management Practices and Safety Plan, site review; obtaining all permits, insurance, and bonds; moving onto the site all materials and equipment; furnishing temporary construction facilities, and removal of same at completion of the project; all as required for the proper performance and completion of the work.

Mobilization shall include, but not be limited to, the following principle items.

- (a) Submittal and modification, as required, of the Construction Schedule.
- (b) All associated documentation and submittals as required.
- (c) Installing temporary construction power and wiring.
- (d) Establishing fire protection system.
- (e) Developing construction water supply.
- (f) Providing on-site sanitary facilities and portable water facilities, as required.
- (g) Arranging for and erection of Contractor's work and storage yard.
- (h) Submittal of all required insurance certificates and bonds, including subcontractors.
- (i) Obtaining all required permits.
- (j) Posting all OSHA required notices and establishment of safety programs.
- (k) Have the Contractor's superintendent at the job site full-time.
- (l) Pot-holing and other research and review as necessary to verify site conditions and utility locations, including research and review as necessary for change orders.

(m) Demobilization.

13. Markup.

The markups mentioned hereinafter shall include, but are not limited to, all costs for the services of superintendents, project managers, timekeepers and other personnel not working directly on the change order, and pickup or yard trucks used by the above personnel. These costs shall not be reported as labor and equipment elsewhere except when actually performing work directly on the change order and then shall be reported at the labor classification of the work performed.

The following percentages shall apply for additional work:

Profit	5% maximum
Overhead	5% maximum

Subcontractor markup: maximum allowed is 5% for profit and overhead on the subcontractor's costs.

To the sum of the costs and markups provided for in this subsection, one (1) percent shall be added as compensation for bonding and one (1) percent for insurance.

For changes involving only a decrease in price, the contractor and subcontractors shall return as credit for overhead and profit those same percentages which are allowed for like changes involving increases in price. On changes involving both an increase and decrease in price, overhead and profit will be allowed only on the net increase.

For conflicts in the plans or specifications, the bidder shall include in his bid the more expensive item and/or methodology.

14. Utilities. The Contractor shall provide coordination with all the utility companies involved and shall provide protection from damage to their facilities. The Contractor shall be responsible for repair or replacement to said facilities made necessary by its failure to provide required protection. The Contractor is required to include utility requirements in the Construction Schedule.

The Contractor shall be solely responsible to check all utility record maps, books, and/or other data in the possession of the CITY, other agencies, and/or all utility companies, and no allowance shall be made for any failure to have done so.

The Contractor shall utilize the services of "Underground Service Alert - Southern California" for utility locating in all public right-of-ways by calling 1-800-227-2600 at least 48 hours prior to any excavation.

15. Completion, Acceptance and Warranty. If, in the CITY's judgment, the Work has been completed and is ready for acceptance, the CITY will so certify and will determine the date when the Work was completed. This will be the date when the Contractor is relieved from responsibility to protect the Work. The CITY may cause a Notice of Completion to be filed and recorded with the Los Angeles County Recorder's Office. At

the CITY's option, the CITY may certify acceptance to the City Council who may then cause a Notice of Completion to be filed and recorded with the Los Angeles County Recorder's Office.

Manufacturer's warranties and guaranties furnished for materials used in the Work and instruction sheets and parts listed supplied with materials shall be delivered to the CITY prior to acceptance of the Work. The duration of the warranty or guaranty shall be the standard of the industry with a minimum of 1 year from the date of Notice of Completion or Date of Acceptance.

The prime contractor will be required to warranty the entire project regardless of whether warranties from subcontractors are also required. Coordination and correction of any issue related to project scope that arises during that one (1) year warranty period will be the responsibility of the prime contractor.

Manufacturer's warranties shall not relieve the Contractor of liability under these Specifications. Such warranties only shall supplement the Contractor's responsibility.

The CITY may require a manufacturer's warranty on any product offered for use.

16. Superintendent. Contractor shall employ a superintendent to be in attendance at all times on the Project site during the performance of the work. Superintendent shall represent the Contractor, and communications given to the superintendent shall be binding as if given to the Contractor. The superintendent must be able to communicate verbally and in writing to both City Representatives and all contract labor regarding all aspects of work. The superintendent shall be approved by the CITY prior to the start of the Work. If the designated superintendent is rejected, the Contractor shall immediately designate another superintendent in writing and submit to the City for consideration. A replacement must be provided before work continues. The CITY shall have the authority to require the Contractor to remove its superintendent and/or alternate superintendent at any time and at no cost to the CITY.

17. Requirements for Recycling Construction Materials

The City of Torrance requires that all demolition projects and construction or remodeling projects valued at \$100,000 or more must recycle or reuse at least 50% of the materials that leave the project site and 100% of excavated soil and land-clearing debris. A Waste Management Plan (WMP) form is part of the permit process for projects that meet these criteria. The WMP form is available at the permit counter or a downloadable form is available here:

<http://www.torranceca.gov/PDF/WMPFormRevised2012onestop.pdf>

Step 1 - when applying for the permit, you must complete the WMP form stating that at least 50% of the waste generated by the project will be recycled or reused and that 100% of excavated soil and land-clearing debris will be recycled or reused.

Step 2 - collect and keep all receipts and records of the disposal, recycling, donations, and reuse of the materials from your project. Receipts must show material type, tonnage or weight, how the materials were treated, the facility used, and the address of the jobsite.

Step 3 - complete the WMP by attaching the receipts listing the actual disposal and recycling that occurred and submitting the WMP to Public Works for approval. This is required before your project can get its final inspection.

Failure to fulfill the requirements of the WMP process will result in penalties of \$5,000 for construction projects and \$10,000 for demolition projects, as per the Torrance Municipal Code.

For additional information concerning recycling or recycling facilities please visit the City of Torrance Public Works Department website at <http://www.torranceca.gov/8614.htm>

SECTION E. PAYMENTS TO CONTRACTOR AND CLAIMS

1. Breakdown of Contract Prices. The Contractor shall, within ten (10) working days of receipt of a request from the City, submit a complete breakdown of lump sum bid prices showing the value assigned to each part of the work, including a separate line item for profit and overhead. The breakdown shall include separate line for each subcontractor's bid and/or contract amount. For each part of the work where an application for payment may include materials or equipment, purchased or fabricated and stored, but not yet installed, provide separate line items on the schedule of values. In submitting the breakdown, the Contractor certifies that it is not unbalanced and that the value assigned to each part of the work represents its estimate of the actual cost, including profit and overhead, of performing that part of the work. The breakdown shall be sufficiently detailed to permit its use by the City Manager as one of the bases for evaluating requests for payment. No extra costs shall be allowed for these breakdowns.
2. Payment for Labor and Materials. The Contractor shall pay and cause the subcontractors to pay any and all accounts for labor, including Worker's Compensation premiums, State Unemployment and Federal Social Security payments and all other wage and salary deductions required by law. The Contractor also shall pay and cause the subcontractors to pay any and all accounts for services, equipment and materials used by it and the subcontractors during the performance of work under this contract. All such accounts shall be paid as they become due and payable. If requested by the City Manager, the Contractor shall immediately furnish the City with proof of payment of such accounts.
3. Additional Work. Payment for additional work and all expenditures in excess of the bid amount must be authorized in writing by the City Manager. Such authorization shall be obtained by the Contractor prior to engaging in additional work. It shall be the Contractor's sole responsibility to obtain written approval from the City Manager for any change(s) in material or in the work proposed by suppliers or subcontractors. No payment shall be made to the Contractor for additional work which has not been approved in writing, and the Contractor hereby agrees that it shall have no right to additional compensation for any work not so authorized.
4. Claims. The Contractor shall not be entitled to the payment of any additional compensation for any cause, including any act, or failure to act, by the City, or the happening of any event, thing or occurrence, unless he shall have given the City due written notice of potential claim as hereinafter specified.

The written notice of potential claim shall set forth the reasons for which the Contractor believes additional compensation will or may be due, the nature of the costs involved, and, insofar as possible, the amount of the potential claim. Said notice shall be submitted on a form approved by the City at least forty-eight (48) hours (two working days) in advance of performing said work, unless the work is of an emergency nature, in which case the Contractor shall notify and obtain approval from the Inspector prior to commencing the work. The City Manager may require the Contractor to delay construction involving the claim, but no other work shall be delayed, and the Contractor shall not be allowed additional costs for any said delay but may be allowed on extension of time if the City Manager agrees that the work delayed is a controlling element of the Construction Schedule. The Contractor shall be required to submit any supporting data (or a detailed written explanation justifying further delay) within five (5) Work Days of a request from the City Manager and shall be responsible for any delays resulting from late and/or incomplete submittals. By submitting a Bid, the Contractor hereby agrees that this Section shall supersede Sections 6-6.3 and 6-6.4 of the Standard Specifications.

The City shall be the sole authority to interpret all plans, specifications and contract documents, and no claim shall be accepted which is based on the Contractor's ignorance, misunderstanding or noncompliance with any provision or portion thereof. The Contractor shall be responsible to provide all data and to obtain all approvals required by said Specifications. No claims or extras shall be approved by the City unless all work was done under the direction of and subject to the approval of the Inspector.

It is the intention of this Subsection that differences between the parties arising under and by virtue of the Contract be brought to the attention of the City Manager at the earliest possible time in order that such matters may be settled, if possible, or other appropriate action promptly taken. The Contractor hereby agrees that it shall have no right to additional compensation for any claim that may be based on any such act, failure to act, event, thing or occurrence for which no written notice of potential claim as herein required was filed.

5. Noncompliance with Plans and Specifications. Failure of the Contractor to comply with any requirement of the Plans and Specifications, and/or to immediately remedy any such noncompliance upon notice from the City Manager, may result in suspension of Contract Progress Payments. Any Progress Payments so suspended shall remain in suspension until the Contractor's operations and/or submittals are brought into compliance to the satisfaction of the City Manager. No additional compensation shall be allowed as a result of suspension of Progress Payments due to noncompliance with the plans or specifications. The Contractor shall not be permitted to stop work due to said suspension of Progress Payments.
6. Request for Payment. Contractor shall submit all requests for payment on AIA Document G702 – Application and Certificate for Payment and G703- Continuation Sheet. For each item provide a column for listing: Item Number; Description of Work; Scheduled Value, Previous Application; Authorized Change Orders; Total completed and Stored to Date of Application; Percentage of Completion; Balance to Finish; and Retainage.

Prior to submittal of said form, all items for which payment is requested shall be checked and approved in writing by the City Manager (or authorized representative). No payments will be made unless all back-up data (below) is submitted with the payment request and the Progress Payment Invoice is signed by both Contractor and Manager.

Back up data required to process payment shall include but not limited to the following:

- Copies of Certified payroll covering the payment period and proof of submission to the Department of Industrial Relations (DIR). Although this project is subject to compliance monitoring and enforcement by the DIR. The City reserves the right to review the certified payroll for compliance, request additional clarification and require the contractor to provide proof of payment such as cancelled checks prior to payment of invoice.
- Conditional and Unconditional lien releases from contractor, subcontractor and suppliers from which the contractor is expecting payment. Release forms must reflect amount of draw and through date of invoice payment.
 1. Conditional releases for the current pay period shall be provided with the current payment request.
 2. Unconditional releases for the immediate prior pay period shall be provided with the current payment request. Unconditional lien release forms must match the preceding Conditional release form in amount and through date and must be signed authorized company representative. Unconditional Lien Release on Final Payment with a zero balance is required from all material suppliers and subcontractors with the request for final payment (retention). All Unconditional Lien Release on Final Payments will be signed authorized company representative and notarized. Release forms can be found at the Contractors State License Board website at http://www.cslb.ca.gov/Media_Room/Industry_Bulletins/2012/July_11.aspx. The most update current lien release forms must be used.
- Any required outside agency reports and/or written observations.

The City will retain 5 percent of the value of all work done and materials installed as part security for fulfillment of the contract by Contractor. The full 5 percent retention will be retained on all payments for 35 days after the filing of the Notice of Completion. In addition 125% of the amount of the "unreleased" STOP notice will be withheld.

There shall be no separate payment for any relocations, barriers or forms, grading or temporary construction required to construct the improvements herein. Payment for these items shall be absorbed in the Bid Prices for the applicable work to which they are appurtenant, and no extra costs shall be allowed.

The payment of amounts due to the Contractor shall be contingent upon the Contractor furnishing the City with a release of all claims against the City arising by virtue of the Contract related to said amounts. It is the contractor's responsibility to provide the correct releases in order to obtain payment by the City.

7. Preconstruction Meeting. The City will hold a preconstruction meeting with awarded contractor and discuss procedural, and mobilization issues. The contractor needs to have key administrative staff attend such as: project manager, superintendent, administrative personnel who handle the certified payroll and pay requests. Attendees can also include subcontractors and major suppliers/fabricators.

In addition to staffing preconstruction meeting, the awarded contractor will need to bring the following to the preconstruction meeting for review and discussion.

- Project Schedule (see section D General Procedures #11 for details)
- Schedule of Values (see section E, Payment to Contractors #1 for details)
- Submittal Log, list all the submittals you plan to submit for review.
- List of subcontractors and contact information
- List of principal suppliers and fabricators
- Prime Contractor's Safety Plan
- Example of Daily Project Report and Daily Sign In Sheet for Review (see #8 below for details)
- Prime contractors' signed contract, performance and labor and material bonds, insurance certificates with endorsements, workers compensation certificate and Torrance Business License. The exact verbiage of additionally insured clause for the insurance is found Item 17C of the contract. The certificate needs to be endorsed as well naming the City as additional insured.
- Signed contracts for subcontractors, insurance certificates with endorsements, workers compensation certificates. Subcontractor's insurance must also meet the contract limits and language and be endorsed.

8. Daily Project Report and Contractor Daily Sign In Sheets.

The contractor will provide daily project reports and/or contractor daily sign in sheets on a daily basis (next working day) during the entire project's onsite work. At minimum the report/sign in sheets consist of the following:

Daily Project Report

- Date, Day of the Week, and Weather
- List all staffing by prime and subcontractors each, include classification and count of persons within the specific classification and denote journeyman vs. apprentice.
- List all deliveries of equipment and materials to site.
- List onsite discussions, meetings any resolution or direction given.
- List progress of the project (i.e. was scheduled and completed).
- List all visitors to the site.

Daily Sign In Sheet

- Date and Day of the Week
- Employee Name (printed), company and classification of work, denote journeyman vs. apprentice for each classification.
- Time started and time completed, any breaks.
- Employee signature of the individual worker (confirming reported time)

PART D
BID DOCUMENTS

BIDDER'S PROPOSAL

BID FOR WILSON PARK ELECTRICAL IMPROVEMENTS

B2016-06

In accordance with the Notice Inviting Bids pertaining to the receiving of sealed proposals by the City Clerk of the City of Torrance for the above titled improvement, the undersigned hereby proposes to furnish all work to be performed in accordance with the Plans, Specifications and Contract Documents, prepared by J.C. Chang & Associates, Inc. and City of Torrance for the bid as set forth in the following schedules.

Assignment of Contractor's values:

Item	Description	Total Amount In Figures*
Division 01	General Requirements:	
Division 02	Site Work:	
Division 03	Concrete:	
Division 04	Masonry:	
Division 05	Metals:	
Division 06	Wood and Plastics:	
Division 07	Thermal and Moisture Protection:	
Division 08	Openings:	
Division 09	Finishes:	
Division 10	Specialties:	
Division 11	Equipment:	
Division 12	Furnishings:	
Division	Specialty Structure:	

13		
----	--	--

Item	Description	Total Amount In figures*
Division 22	Plumbing:	
Division 23	Mechanical:	
Division 26	Electrical:	
Division 99	Miscellaneous:	
	B2016-06 -BID TOTAL- in figures*	

BASE BID TOTAL: _____
(In Words)*

***BID MAY BE REJECTED IF TOTAL IS NOT SHOWN IN FIGURES AND WORDS.**

The City of Torrance awards to the lowest responsible bidder per the Torrance Municipal Code. Based on the funding available, the City reserves the right to select any combination of base bid and bid alternate(s) to determine the lowest responsible bidder for award.

The undersigned furthermore agrees to enter into and execute a contract, with necessary bonds, at the prices set forth herein and in case of default in executing such contract, with necessary bonds, the check or bond accompanying this bid and the money payable thereon shall be forfeited thereby to and remain the property of the City of Torrance.

The above prices include all work appurtenant to the various items as outlined in the specifications and all work or expense required for the satisfactory completion of said item.

The undersigned declares that it has carefully examined the Specifications, and Contract Documents, and has investigated the site of the work and is familiar with the conditions thereon.

Company Name

Signature of principal in company

CONTRACTOR'S AFFIDAVIT B2016-06 (CONTINUED)

7. That the Contractor did not, directly or indirectly, submit the Contractor's bid price or any breakdown thereof, or the contents thereof, or divulge information or data relative thereto, to any corporation, partnership, company, association, organization, bid depository, or to any member or agent thereof, or to any individual or group of Individuals, except to the City of Torrance, or to any person or persons who have a partnership or other financial interest with said Contractor in its business.

Dated this _____ day of _____, 20_____.

Subscribed and Sworn to
before me this _____
of _____, 20_____

(Contractor)

(Title)

Notary Public in and for said
County and State.
(Seal)

BID BOND

B2016-06

KNOW ALL MEN BY THESE PRESENTS: That we, _____

_____ as principal, and _____ as sureties, are held and firmly bound unto the City of Torrance, State of California, in the penal sum of _____ dollars (\$ _____), for the payment whereof we hereby bind ourselves, our successors, heirs, executors or administrators jointly and severally, firmly by these presents.

The condition of this obligation is such that, whereas the above bounded principal is about to file with and submit to the City of Torrance a bid or proposal for the performance of certain work as required in the City of Torrance, Project No. B2016-06 , said work being: Wilson Park Electrical Improvements, in compliance with the Specifications therefore under an invitation of said City contained in a notice or advertisement for bids or proposals; now if the bid or proposal of said principal shall be accepted and if said work be thereupon awarded to the principal by said City and if the said principal shall enter into a contract with the said City in accordance with said bid or proposal, or if the bid or proposal of the said principal is rejected, then this bond shall be void and of no effect and otherwise in full force and effect.

WITNESS our hands this _____ day of _____, 20 _____.

Principal

Surety/Attorney-in-Fact

Signature

Name: _____
Local Address: _____
Phone No.: _____
Fax No.: _____

LIST OF SUBCONTRACTORS

The Bidder is required to fill in the following blanks in accordance with the provisions of the Subletting and Subcontracting Fair Practices Act (Chapter 2 of Division 5, Title 1 of the Government Code of the State of California) and should familiarize itself with Section 2-3 of the Standard Specifications.

1. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

2. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

3. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

4. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

5. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

6. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

7. Name Under Which Subcontractor is Licensed: _____

Subcontractor's Address: _____

Specific Description of Sub-Contract: _____

License Number: _____ CA License Classification/Type: _____

DIR Registration #: _____

Subcontractors must be properly licensed under the laws of the State of California for the type of work which they are to perform. Do not list alternate subcontractors for the same work.

The Bidding Contractor must include each subcontractor's contract license number (AB 44). An inadvertent error in listing the subcontractor's license number shall not be grounds for filing a bid protest or grounds for considering the bid nonresponsive, if the corrected contractor's license number is submitted to the public entity by the prime contractor within 24 hours after the bid opening-provided that the correct license number corresponds to the submitted name and location of the subcontractor.

No contractor or subcontractor may be listed on a bid proposal for a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5 [with limited exceptions from this requirement for bid purposes only under Labor Code section 1771.1(a)].

No contractor or subcontractor may be awarded a contract for public work on a public works project unless registered with the Department of Industrial Relations pursuant to Labor Code section 1725.5.

REFERENCES

(Bidder must have completed at least four (4) projects of a similar size and scope within the last five (5) years). The references must reflect this requirement.

1. Name (Firm/Agency): _____

Address: _____

Contact Person: _____ Telephone No.: _____

Title of Project: _____

Project Location: _____

Date of Completion _____ Contract Amount: \$ _____

2. Name (Firm/Agency): _____

Address: _____

Contact Person: _____ Telephone No.: _____

Title of Project: _____

Project Location: _____

Date of Completion _____ Contract Amount: \$ _____

3. Name (Firm/Agency): _____

Address: _____

Contact Person: _____ Telephone No.: _____

Title of Project: _____

Project Location: _____

Date of Completion _____ Contract Amount: \$ _____

4. Name (Firm/Agency): _____

Address: _____

Contact Person: _____ Telephone No.: _____

Title of Project: _____

Project Location: _____

Date of Completion _____ Contract Amount: \$ _____

Bidder's Information

The bidder must provide a detailed list of the trades and the description of the work they will perform with their own company for this project.

1. _____

2. _____

3. _____

4. _____

5. _____

6. _____

7. _____

8. _____

9. _____

10. _____

11. _____

12. _____

13. _____

14. _____

Contractor's License No.: _____ Class: _____

Date first obtained: _____

Has License ever been suspended or revoked? _____

If yes, describe when and why _____

Any current claims against License or Bond? _____

If yes, describe claims: _____

Type of entity (check one)

_____ Incorporated _____ Partnership _____ Sole Proprietorship

If incorporated, in what state _____

Federal Tax ID Number # _____

Principals in Company (List all - attach additional sheets if necessary):

<u>NAME</u>	<u>TITLE</u>	<u>LICENSE NO.</u> (If Applicable)
_____	_____	_____
_____	_____	_____
_____	_____	_____

PART E

**DOCUMENTS TO BE COMPLETED
AND DELIVERED TO CITY AS PART
OF CONTRACT WITH THE CITY**

PERFORMANCE BOND

KNOW ALL MEN BY THESE PRESENTS:

That we, _____ as Principal(s) and ____ a _____ corporation, incorporated, organized, and existing under the laws of the State of _____, and authorized to execute bonds and undertakings and to do a general surety business in the State of California, as Surety, are jointly and severally held and firmly bound unto the City of Torrance, a municipal corporation, located in the County of Los Angeles, State of California, in the full and just sum of: _____ Dollars (\$ _____), lawful money of the United States of America, for the payment of which sum, well and truly to be made, we bind ourselves and our respective heirs, executors, administrators, representative, successors and assigns, jointly and severally, firmly by these presents.

THE CONDITION OF THIS OBLIGATION IS SUCH, that: WHEREAS, said Principal(s) have/has entered into, or are/is about to enter into, a certain written contract or agreement, dated as of the _____ day of _____, 20____, with the said City of Torrance for the **WILSON PARK ELECTRICAL IMPROVEMENTS B2016-06** all as is more specifically set forth in said contract or agreement, a full, true and correct copy of which is hereunto attached, and hereby referred to and by this reference incorporated herein and made a part hereof;

NOW, THEREFORE, if the said Principal(s) shall faithfully and well and truly do, perform and complete, or cause to be done, performed and complete, each and all of the covenants, terms, conditions, requirements, obligations, acts and things, to be met, done or performed by said Principal(s), including any guarantee period as set forth in, or required by, said contract or agreement, all at and within the time or times, and in the manner as therein specified and contemplated, then this bond and obligation shall be null and void; otherwise it shall be and remain in full force, virtue and effect.

The said Surety, for value received, hereby stipulates and agrees that no amendment, change, extension of time, alteration or addition to said contract or agreement, or of any feature or item or items of performance required therein or there under, shall in any manner affect its obligations on or under this bond; and said Surety does hereby waive notice of any such amendment, change, extension of time, alteration, or addition to said contract or agreement, and of any feature or item or items of performance required therein or there under.

PERFORMANCE BOND B2016-06 (CONTINUED)

In the event any suit, action or proceedings is instituted to recover on this bond or obligation, said Surety will pay, and does hereby agree to pay, as attorney's fees for said City, such sum as the Court in any such suit, action or proceeding may adjudge reasonable.

EXECUTED, SEALED AND DATED this _____ day of _____, 20____

CORPORATE SEAL

PRINCIPAL(S):

BY _____

BY _____

CORPORATE SEAL

SURETY:

BY _____

Name: _____
Local Address: _____
Phone No.: _____
Fax No.: _____

LABOR AND MATERIAL BOND
B2016-06

KNOW ALL MEN BY THESE PRESENTS:

That we, _____
As Principal(s) and _____ a
corporation, incorporated, organized, and existing under the laws of the State of
_____, and authorized to execute bonds and undertakings and to do a general
surety business in the State of California, as Surety, are jointly and severally held and firmly
bound unto:

- (a) The State of California for the use and benefit of the State Treasurer, as ex-officio Treasurer and custodian of the Unemployment Fund of said State; and
- (b) The City of Torrance, California; and
- (c) Any and all persons who do or perform or who did or performed work or labor upon or in connection with the work or improvement referred to in the contract or agreement hereinafter mentioned; and
- (d) Any and all materialmen, persons, companies, firms, association, or corporations, supplying or furnishing any materials, provisions, provender, transportation, appliances or power, or other supplies used in, upon, for or about or in connection with the performance of the work or improvement contracted to be executed, done, made or performed under said contract or agreement; and
- (e) Any and all persons, companies, firms, associations, or corporations furnishing, renting, or hiring teams, equipment, implements or machinery for, in connection with, or contributing to, said work to be done or improvement to be made under said contract or agreement; and
- (f) Any and all persons, companies, firms, associations, or corporations who supply both work and materials;

and whose claim has not been paid by said Principal(s), in full and just sum of _____ Dollars (\$_____), lawful money of the United States of America, for the payment of which will and truly to be made, said Principal(s) and said Surety do hereby bind themselves and their respective heirs, executors, administrators, representatives, successors and assigns, jointly and severally, firmly by these presents.

LABOR AND MATERIAL BOND (CONTINUED)

THE CONDITION OF THE FOREGOING OBLIGATION IS SUCH, THAT: WHEREAS, said Principal(s) have/has entered into or are/is about to enter into a certain written contract or agreement, dated as of the _____ day of _____ 20 ____, with the City of Torrance for the WILSON PARK ELECTRICAL IMPROVEMENTS, B2016-06, all as is more specifically set forth in said contract or agreement, a full, true and correct copy of which is hereunto attached, and hereby referred to and by this reference incorporated herein and made a part hereof;

NOW, THEREFORE, if the said Principal(s) (or any of his/her, its, or their subcontractors) under said contract or agreement fails or fail to pay:

- (1) For any materials, provisions, provender, transportation, appliances, or power, or other supplies; or
- (2) For the hire of any teams, equipment, implements, or machinery; or
- (3) For any work or labor; supplies, furnished, provided, used, done or performed in, upon, for or about or in connection with the said work or improvement; or
- (4) For amounts due under the Unemployment Insurance Act of the State of California with respect to such work or improvement;

the Surety on this bond will pay the same in an amount not exceeding the sum hereinabove specified in this bond; and, also, in case suit is brought upon this bond, said Surety will (and does hereby agree to) pay a reasonable attorney's fee, to be fixed and taxed as costs, and included in the judgment therein rendered.

This bond shall (and it is hereby made to) insure to the benefit of any and all persons entitled to file claims under Section 1192.1 of the Code of Civil Procedure of the State of California, so as to give a right of action to them or their assigns in any suit brought upon this bond, all as contemplated under the provisions of Section 4205 of the Government Code, and of Chapter 1 of Title 4 of Part 3 of the Code of Civil Procedure, of the State of California.

This bond is executed and filed in connection with said contract or agreement hereunto attached to comply with each and all of the provisions of the laws of the State of California above mentioned or referred to, and of all amendments thereto, and the obligors so intend and do hereby bind themselves accordingly.

LABOR AND MATERIAL BOND B2016-06 (CONTINUED)

The said Surety, for value received, hereby stipulates and agrees that no amendment, change, extension of time, alteration, or addition to said contract or agreement, or of any feature or item or items of performance required therein or thereunder, shall in any manner affect its obligations on or under this bond; and said Surety does hereby waive notice of any such amendment, change, extension of time, alteration, or addition to said contract or agreement, and of any feature or item or items of performance required therein or thereunder.

EXECUTED, SEALED AND DATED this _____ day of _____, 20 _____

CORPORATE SEAL

PRINCIPAL:

BY _____

CORPORATE SEAL

SURETY:

BY _____

Name: _____
Local Address: _____
Phone No.: _____
Fax No.: _____

PART F
PREVAILING WAGE DETERMINATIONS

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1
FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

CRAFT: # CARPENTER AND RELATED TRADES

DETERMINATION: SC-23-31-2-2015-1

ISSUE DATE: August 22, 2015

EXPIRATION DATE OF DETERMINATION: June 30, 2016* Effective until superseded by a new determination issued by the Director of Industrial Relations. Contact the Office of the Director – Research Unit at (415) 703-4774 for new rates after 10 days from the expiration date, if no subsequent determination is issued.

LOCALITY: All localities within Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, and Ventura counties.

Classification (Journey person)	Basic Hourly Rate	Employer Payments					Straight-Time		Overtime Hourly Rate		
		Health and Welfare	Pension	Vacation/ and Holiday	Training	Other	Total Hourly Rate	Hours	Daily ^a 1 1/2X	Saturday ^b 1 1/2X	Sunday and Holiday
* AREA 1											
Carpenter ^{c,1} , Cabinet Installer, Insulation Installer, Hardwood Floor Worker, Acoustical Installer	\$40.40	\$6.60	\$4.41	\$3.45 ^f	\$0.57	\$0.34	8	\$55.77	\$75.97	\$75.97	\$96.17
Pile Driverman ¹ , Derrick Bargeman, Rockslinger, Bridge or Dock Carpenter, Cable Splicer	40.53	6.60	4.41	3.45 ^f	0.57	0.34	8	55.90	76.165	76.165	96.43
Bridge Carpenter ^c	40.53	6.60	4.41	3.45 ^f	0.57	0.34	8	55.90	76.165	76.165	96.43
Shingler ^c	40.53	6.60	4.41	3.45 ^f	0.57	0.34	8	55.90	76.165	76.165	96.43
Saw Filer	40.49	6.60	4.41	3.45 ^f	0.57	0.34	8	55.86	76.105	76.105	96.35
Table Power Saw Operator	40.50	6.60	4.41	3.45 ^f	0.57	0.34	8	55.87	76.12	76.12	96.37
Pneumatic Nailer or Power Stapler	40.65	6.60	4.41	3.45 ^f	0.57	0.34	8	56.02	76.345	76.345	96.67
Roof Loader of Shingles	28.37	6.60	4.41	3.45 ^f	0.57	0.34	8	43.74	57.925	57.925	72.11
Scaffold Builder	31.60	6.60	4.41	3.45 ^f	0.57	0.34	8	46.97	62.77	62.77	78.57
Millwright ^c	40.90	6.60	4.41	3.45 ^f	0.57	0.54	8	56.47	76.92	76.92	97.37
Head Rockslinger	40.63	6.60	4.41	3.45 ^f	0.57	0.34	8	56.00	76.315	76.315	96.63
Rock Bargeman or Scowman	40.43	6.60	4.41	3.45 ^f	0.57	0.34	8	55.80	76.015	76.015	96.23
Diver, Wet (Up To 50 Ft. Depth) ^d	\$89.06	6.60	4.41	3.45 ^f	0.57	0.34	8	104.43	148.96	148.96	193.49
Diver, (Stand-By) ^d	\$44.53	6.60	4.41	3.45 ^f	0.57	0.34	8	59.90	82.165	82.165	104.43
Diver's Tender ^d	43.53	6.60	4.41	3.45 ^f	0.57	0.34	8	58.90	80.665	80.665	102.43
Assistant Tender (Diver's) ^d	40.53	6.60	4.41	3.45 ^f	0.57	0.34	8	55.90	76.165	76.165	96.43
* AREA 2											
Carpenter ^{c,1} , Cabinet Installer, Insulation Installer, Hardwood Floor Worker, Acoustical Installer	39.83	6.60	4.41	3.45 ^f	0.57	0.34	8	55.20	75.115	75.115	95.03
Shingler ^c	39.97	6.60	4.41	3.45 ^f	0.57	0.34	8	55.34	75.325	75.325	95.31
Saw Filer	39.83	6.60	4.41	3.45 ^f	0.57	0.34	8	55.20	75.115	75.115	95.03
Table Power Saw Operator	40.93	6.60	4.41	3.45 ^f	0.57	0.34	8	56.30	76.765	76.765	97.23
Pneumatic Nailer or Power Stapler	40.09	6.60	4.41	3.45 ^f	0.57	0.34	8	55.46	75.505	75.505	95.55
Roof Loader of Shingles	27.98	6.60	4.41	3.45 ^f	0.57	0.34	8	43.35	57.34	57.34	71.33

DETERMINATION: SC-31-741-1-2014-1

ISSUE DATE: August 22, 2014

EXPIRATION DATE OF DETERMINATION: May 31, 2015*. Effective until superseded by a new determination issued by the Director of Industrial Relations. Contact the Office of the Director – Research Unit at (415) 703-4774 for new rates after 10 days from the expiration date, if no subsequent determination is issued.

LOCALITY: All localities within Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, and Ventura counties.

Classification (Journey person)	Basic Hourly Rate	Employer Payments					Straight-Time		Overtime Hourly Rate		
		Health and Welfare	Pension	Vacation/ and Holiday	Training	Other	Total Hourly Rate	Hours	Daily 1 1/2X	Saturday/ Sunday 1 1/2X ^h	Holiday 2X
Terrazzo Installer	\$36.52	6.10	4.16	3.36 ^f	0.42		8	50.56	68.82	68.82	87.08
Terrazzo Finisher	30.02	6.10	4.16	3.36 ^f	0.42		8	44.06	59.07	59.07	74.08

Indicates an apprenticeable craft. The current apprentice wage rates are available on the Internet @ <http://www.dir.ca.gov/OPRL/PWAppWage/PWAppWageStart.asp>. To obtain any apprentice wage rates as of July 1, 2008 and prior to September 27, 2012, please contact the Division of Apprenticeship Standards or refer to the Division of Apprenticeship Standards' website at <http://www.dir.ca.gov/das/das.html>.

a. AREA 1 - Imperial, Los Angeles, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara and Ventura counties.

AREA 2 - Inyo, Kern, and Mono counties. For Bridge Carpenter, Scaffold Builder, Pile Driverman, Derrick Bargeman, Rockslinger, Bridge or Dock Carpenter, Cable Splicer, Millwright, Head Rockslinger, Rock Bargeman or Scowman, Diver, Wet (Up to 50 Ft. Depth), Diver (Stand-By), Diver's Tender, and Assistant Tender (Diver's) rates, please see Area 1 as this rate applies to Area 2 as well. Basic Hourly Rates for Area 2 include an additional amount deducted for vacation/holiday.

b. First eight (8) hours worked paid at 1 1/2 times the straight time rate, all hours after that paid at double (2x) the straight time rate. Saturdays in the same work week may be worked at straight-time rates if a job is shut down during the normal work week due to inclement weather, major mechanical breakdown or lack of materials beyond the control of the Employer.

c. When performing welding work requiring certification, classification will receive an additional \$1.00 per hour.

d. Shall receive a minimum of 8 hours pay for any day or part thereof.

e. For specific rates over 50 ft depth, contact the Office of the Director – Research Unit. Rates for Technicians, Manifold Operators, Pressurized Submersible Operators, Remote Control Vehicle Operators, and Remote Operated Vehicle Operators, as well as rates for Pressurized Bell Diving and Saturation Diving are available upon request.

f. Includes an amount for supplemental dues.

g. All overtime worked Mon - Fri shall be paid at 1 1/2 times the straight time rate for the first four (4) hours and double (2x) the straight time for work performed after twelve (12) hours.

h. Saturdays in the same work week may be worked at straight-time rates if a job is shut down during the normal work week due to inclement weather, major mechanical breakdown or lack of materials beyond the control of the Employer. Work on Sunday, if it is the 7th consecutive workday, shall be paid at double (2x) the straight-time rate.

i. A Carpenter who performs work of forming in the construction of open cut sewers or storm drains shall receive a premium of thirteen cents (\$0.13) per hour in addition to his Carpenter's scale. This premium shall apply only on an operation in which horizontal lagging is used in conjunction with Steel H-Beams driven or placed in pre-drilled holes, for that portion of a lagged trench against which concrete is poured, namely, as a substitute for back forms, which work is performed by pile drivers.

j. When performing welding work requiring certification, classification will receive an additional \$1.00 per hour. An additional \$0.50 per hour when handling or working with new pressure-treated creosote piling or timber, or driving of used pressure-treated creosote piling.

RECOGNIZED HOLIDAYS: Holidays upon which the general prevailing hourly wage rate for Holiday work shall be paid, shall be all holidays in the collective bargaining agreement, applicable to the particular craft, classification, or type of worker employed on the project, which is on file with the Director of Industrial Relations. If the prevailing rate is not based on a collectively bargained rate, the holidays upon which the prevailing rate shall be paid shall be as provided in Section 6700 of the Government Code. You may obtain the holiday provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Holiday provisions for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

TRAVEL AND/OR SUBSISTENCE PAYMENT: In accordance with Labor Code Sections 1773.1 and 1773.9, contractors shall make travel and/or subsistence payments to each worker to execute the work. You may obtain the travel and/or subsistence provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Travel and/or subsistence requirements for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1

FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

CRAFT: #LABORER AND RELATED CLASSIFICATIONS

DETERMINATION: SC-23-102-2-2015-2

ISSUE DATE: August 22, 2015

EXPIRATION DATE OF DETERMINATION: July 3, 2016** The rate to be paid for work performed after this date has been determined. If work will extend past this date, the new rate must be paid and should be incorporated in contracts entered into now. Contact the Office of the Director – Research Unit for specific rates at (415) 703-4774.

LOCALITY: All localities within Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, and Ventura counties.

Classification ^a (Journey person)	Basic Hourly Rate	Employer Payments					Straight-Time		Overtime Hourly Rates		
		Health and Welfare	Pension	Vacation/ and Holiday ^d	Training	Other Payment	Hours	Total Hourly Rate	Daily ^b	Saturday ^{bc}	Sunday and Holiday

CLASSIFICATION GROUPS

Group 1	\$31.39	6.86	6.50	4.47	0.64	0.62	8	50.48	66.175	66.175	81.87
Group 2	31.94	6.86	6.50	4.47	0.64	0.62	8	51.03	67.00	67.00	82.97
Group 3	32.49	6.86	6.50	4.47	0.64	0.62	8	51.58	67.825	67.825	84.07
Group 4	34.04	6.86	6.50	4.47	0.64	0.62	8	53.13	70.15	70.15	87.17
Group 5	34.39	6.86	6.50	4.47	0.64	0.62	8	53.48	70.675	70.675	87.87

Indicates an apprenticeable craft. The current apprentice wage rates are available on the Internet @ <http://www.dir.ca.gov/OPRL/PWAppWage/PWAppWageStart.asp>. To obtain any apprentice wage rates as of July 1, 2008 and prior to September 27, 2012, please contact the Division of Apprenticeship Standards or refer to the Division of Apprenticeship Standards' website at <http://www.dir.ca.gov/das/das.html>.

^a For classification within each group, see page 14.

^b Any hours worked over 12 hours in a single workday are double (2) time.

^c Saturdays in the same work week may be worked at straight-time if job is shut down during work week due to inclement weather or similar Act of God, or a situation beyond the employers control.

^d Includes an amount per hour worked for supplemental dues

RECOGNIZED HOLIDAYS: Holidays upon which the general prevailing hourly wage rate for Holiday work shall be paid, shall be all holidays in the collective bargaining agreement, applicable to the particular craft, classification, or type of worker employed on the project, which is on file with the Director of Industrial Relations. If the prevailing rate is not based on a collectively bargained rate, the holidays upon which the prevailing rate shall be paid shall be as provided in Section 6700 of the Government Code. You may obtain the holiday provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Holiday provisions for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

TRAVEL AND/OR SUBSISTENCE PAYMENT: In accordance with Labor Code Sections 1773.1 and 1773.9, contractors shall make travel and/or subsistence payments to each worker to execute the work. You may obtain the travel and/or subsistence provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Travel and/or subsistence requirements for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

DETERMINATION: SC-23-102-2-2015-2

CLASSIFICATION GROUPS

GROUP 1

Boring Machine Helper (Outside)
Certified Confined Space Laborer
Cleaning and Handling of Panel Forms
Concrete Screeding for Rough Strike-Off
Concrete, Water Curing
Demolition Laborer, the cleaning of brick if performed by an employee performing any other phase of demolition work, and the cleaning of lumber
Fiberoptic Installation, Blowing, Splicing, and Testing Technician on public right-of-way only
Fire Watcher, Limbers, Brush Loaders, Pilers and Debris Handlers
Flagman
Gas, Oil and/or Water Pipeline Laborer
Laborer, Asphalt-Rubber Material Loader
Laborer, General or Construction
Laborer, General Cleanup
Laborer, Jetting
Laborer, Temporary Water and Air Lines
Plugging, Filling of Shee-Bolt Holes; Dry Packing of Concrete and Patching
Post Hole Digger (Manual)
Railroad Maintenance, Repair Trackman and Road Beds; Streetcar and Railroad Construction Track Laborers
Rigging and Signaling
Scaler
Slip Form Raisers
Tarman and Mortar Man
Tool Crib or Tool House Laborer
Traffic Control by any method
Water Well Driller Helper
Window Cleaner
Wire Mesh Pulling - All Concrete Pouring Operations

GROUP 2

Asphalt Shoveler
Cement Dumper (on 1 yard or larger mixer and handling bulk cement)
Cesspool Digger and Installer
Chucktender
Chute Man, pouring concrete, the handling of the chute from readymix trucks, such as walls, slabs, decks, floors, foundations, footings, curbs, gutters and sidewalks
Concrete Curer-Impervious Membrane and Form Oiler
Cutting Torch Operator (Demolition)
Fine Grader, Highways and Street Paving, Airport, Runways, and similar type heavy construction
Gas, Oil and/or Water Pipeline Wrapper-Pot Tender and Form Man
Guinea Chaser
Headerboard Man-Asphalt
Installation of all Asphalt Overlay Fabric and Materials used for Reinforcing Asphalt
Laborer, Packing Rod Steel and Pans
Membrane Vapor Barrier Installer
Power Broom Sweepers (small)
Riprap, Stonepaver, placing stone or wet sacked concrete
Roto Scraper and Tiller
Sandblaster (Pot Tender)
Septic Tank Digger and Installer (leadman)

GROUP 2 (continued)

Tank Scaler and Cleaner
Tree Climber, Faller, Chain Saw Operator, Pittsburgh Chipper and similar type Brush Shredders
Underground Laborer, including Caisson Bellower

GROUP 3

Asphalt Installation of all fabrics
Buggymobile Man
Compactor (all types including Tampers, Barko, Wacker)
Concrete Cutting Torch
Concrete Pile Cutter
Driller, Jackhammer, 2 1/2 ft. drill steel or longer
Dri Pak-it Machine
Gas, Oil and/or Water Pipeline Wrapper - 6-inch pipe and over by any method, inside and out
High Scaler (including drilling of same)
Impact Wrench, Multi-Plate
Kettlemen, Potmen and Men applying asphalt, lay-kold, creosote, lime caustic and similar type materials
Laborer, Fence Erector
Material Hoseman (Walls, Slabs, Floors and Decks)
Operators of Pneumatic, Gas, Electric Tools, Vibrating Machines, Pavement Breakers, Air Blasting, Come-Alongs, and similar mechanical tools not separately classified herein; operation of remote controlled robotic tools in connection with Laborers work
Pipelayer's backup man, coating, grouting, making of joints, sealing, caulking, diapering and including rubber gasket joints, pointing and any and all other services
Power Post Hole Digger
Rock Slinger
Rotary Scarifier or Multiple Head Concrete Chipping Scarifier
Steel Headerboard Man and Guideline Setter
Trenching Machine, Hand Propelled

GROUP 4

Any Worker Exposed to Raw Sewage
Asphalt Raker, Luteman, Ironer, Asphalt Dumpman, and Asphalt Spreader Boxes (all types)
Concrete Core Cutter (walls, floors or ceilings), Grinder or Sander
Concrete Saw Man, Cutting Walls or Flat Work, Scoring old or new concrete
Cribber, Shorer, Lagging, Sheeting and Trench Bracing, Hand-Guided Lagging Hammer
Head Rock Slinger
Laborer, Asphalt-Rubber Distributor Bootman
Laser Beam in connection with Laborer's work
Oversize Concrete Vibrator Operator, 70 pounds and over
Pipelayer
Prefabricated Manhole Installer
Sandblaster (Nozzleman), Water Blasting, Porta Shot-Blast
Traffic Lane Closure, certified

GROUP 5

Blasters Powderman
Driller
Toxic Waste Removal
Welding, certified or otherwise in connection with Laborers' work

DEPARTMENT OF INDUSTRIAL RELATIONS
Office of the Director – Research Unit
455 Golden Gate Avenue, 9th Floor
San Francisco, CA 94102

ADDRESS REPLY TO:

San Francisco P.O. Box 420603
CA 94142-0603



PREDETERMINED INCREASES FOR

LABORER AND RELATED CLASSIFICATIONS (SC-23-102-2-2015-2)

ALL LOCALITIES WITHIN IMPERIAL, INYO, KERN, LOS ANGELES, MONO,
ORANGE, RIVERSIDE, SAN BERNARDINO, SAN LUIS OBISPO, SANTA
BARBARA, AND VENTURA COUNTIES

These predetermined increases for the above named craft applies only to the current determination for work being performed on public works projects with bid advertisement dates on or after **September 1, 2015**, until this determination is superseded by a new determination or a predetermined increase modification notice becomes effective.

When referencing our prevailing wage determinations, please note that if the prevailing wage rate determination which was in effect on the bid advertisement date of a project has a single asterisk (*) after the expiration date, the rate will be good for the life of the project. However, if a prevailing wage rate determination has double asterisks (**) after the expiration date, the rate must be updated on the following date to reflect the predetermined rate change(s).

LABORER

Determination SC-23-102-2-2015-2 is currently in effect and expires on July 3, 2016**.

Effective July 4, 2016, there will be an increase of \$1.60 allocated as follows: \$0.25 to Pension and \$1.35 to be allocated to wages and/or employer payments

Effective July 3, 2017, there will be an increase of \$1.65 allocated as follows: \$0.25 to Pension and \$1.40 to be allocated to wages and/or employer payments. (See Important Notice issued September 23, 2015)

There will be no further increases applicable to this determination.

Issued 8/22/2015, Effective 9/1/2015.

This page will be updated when wage rate breakdown information becomes available.
Last Updated: September 23, 2015

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1

FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

CRAFT: #OPERATING ENGINEER

DETERMINATION: SC-23-63-2-2015-1

ISSUE DATE: August 22, 2015

EXPIRATION DATE OF DETERMINATION: June 30, 2016* Effective until superseded by a new determination issued by the Director of Industrial Relations. Contact the Office of the Director – Research Unit at (415) 703-4774 for new rates after 10 days from the expiration date, if no subsequent determination is issued.

LOCALITY: All localities within Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, and Ventura counties.

CLASSIFICATION (Journey person)	Basic Hourly Rate	Health and Welfare	Employer Payments				Straight – Time		Overtime Hourly Rate					
			Pension	Vacation/ Holiday (a)	Training	Other Payments	Hours	Total Hourly Rate	Daily (c)	Saturday (d)	Sunday/ Holiday			
											1 1/2X	1 1/2X	2X	
Classification Groups (b)														
Group 1	\$39.95	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$64.89	\$84.865	\$84.865	\$104.84			
Group 2	\$40.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$65.67	\$86.035	\$86.035	\$106.40			
Group 3	\$41.02	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$65.96	\$86.470	\$86.470	\$106.98			
Group 4	\$42.51	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$67.45	\$88.705	\$88.705	\$109.96			
Group 6	\$42.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$67.67	\$89.035	\$89.035	\$110.40			
Group 8	\$42.84	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$67.78	\$89.200	\$89.200	\$110.62			
Group 10	\$42.96	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$67.90	\$89.380	\$89.380	\$110.86			
Group 12	\$43.13	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.07	\$89.635	\$89.635	\$111.20			
Group 13	\$43.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.17	\$89.785	\$89.785	\$111.40			
Group 14	\$43.26	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.20	\$89.830	\$89.830	\$111.46			
Group 15	\$43.34	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.28	\$89.950	\$89.950	\$111.62			
Group 16	\$43.46	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.40	\$90.130	\$90.130	\$111.86			
Group 17	\$43.63	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.57	\$90.385	\$90.385	\$112.20			
Group 18	\$43.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.67	\$90.535	\$90.535	\$112.40			
Group 19	\$43.84	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.78	\$90.700	\$90.700	\$112.62			
Group 20	\$43.96	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.90	\$90.880	\$90.880	\$112.86			
Group 21	\$44.13	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.07	\$91.135	\$91.135	\$113.20			
Group 22	\$44.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.17	\$91.285	\$91.285	\$113.40			
Group 23	\$44.34	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.28	\$91.450	\$91.450	\$113.62			
Group 24	\$44.46	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.40	\$91.630	\$91.630	\$113.86			
Group 25	\$44.63	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.57	\$91.885	\$91.885	\$114.20			

Indicates an apprenticeable craft. The current apprentice wage rates are available on the Internet @ <http://www.dir.ca.gov/OPRL/PWAppWage/PWAppWageStart.asp>. To obtain any apprentice wage rates as of July 1, 2008 and prior to September 27, 2012, please contact the Division of Apprenticeship Standards or refer to the Division of Apprenticeship Standards' website at <http://www.dir.ca.gov/das/das.html>.

* Includes an amount withheld for supplemental dues.

^b For classifications within each group, see pages 8 and 9.

^c Rate applies to the first 4 overtime hours. All other daily overtime is paid at the Sunday rate.

^d Rate applies to the first 12 hours worked. All other time is paid at the Sunday rate.

NOTE: For Special Shift and Multi-Shift, see pages 9A and 9B.

RECOGNIZED HOLIDAYS: Holidays upon which the general prevailing hourly wage rate for Holiday work shall be paid, shall be all holidays in the collective bargaining agreement, applicable to the particular craft, classification, or type of worker employed on the project, which is on file with the Director of Industrial Relations. If the prevailing rate is not based on a collectively bargained rate, the holidays upon which the prevailing rate shall be paid shall be as provided in Section 6700 of the Government Code. You may obtain the holiday provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Holiday provisions for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

TRAVEL AND/OR SUBSISTENCE PAYMENT: In accordance with Labor Code Sections 1773.1 and 1773.9, contractors shall make travel and/or subsistence payments to each worker to execute the work. You may obtain the travel and/or subsistence provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Travel and/or subsistence requirements for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

DETERMINATION: SC-23-63-2-2015-1

CLASSIFICATIONS:

GROUP 1

Bargeman
Brakeman
Compressor Operator
Ditchwitch, with seat or similar type equipment
Elevator Operator - Inside
Engineer Oiler
Forklift Operator (includes load, full or similar types – under 5 tons)
Generator Operator
Generator, Pump or Compressor Plant Operator
Heavy Duty Repairman Helper
Pump Operator
Signalman
Switchman

GROUP 2

Asphalt-Rubber Plant Operator (Nurse Tank Operator)
Concrete Mixer Operator - Skip Type
Conveyor Operator
Fireman
Forklift Operator (includes load, full or similar types – over 5 tons)
Hydrostatic Pump Operator
Oiler Crusher (Asphalt or Concrete Plant)
Petromat Laydown Machine
RJU Side Dump Jack
Rotary Drill Helper (Oilfield)
Screening and Conveyor Machine Operator (or similar types)
Skiploader (Wheel type up to 3/4 yd. without attachment)
Tar Pot Fireman
Temporary Heating Plant Operator
Trenching Machine Oiler

GROUP 3

Asphalt Rubber Blend Operator
Bobcat or similar type (Skid Steer, with all attachments)
Equipment Greaser (rack)
Ford Ferguson (with dragtype attachments)
Helicopter Radioman (ground)
Stationary Pipe Wrapping and Cleaning Machine Operator

GROUP 4

Asphalt Plant Fireman
Backhoe Operator (mini-max or similar type)
Boring Machine Operator
Boring System Electronic Tracking Locator
Boxman or Mixerman (asphalt or concrete)
Chip Spreading Machine Operator
Concrete Cleaning Decontamination Machine Operator
Concrete Pump Operator (small portable)
Drilling Machine Operator, Small Auger types (Texoma Super Economat, or similar types - Hughes 100 or 200, or similar types - drilling depth of 30 maximum)
Equipment Greaser (grease truck)
Excavator Track/Rubber-Tired (Operating weight under 21,000 lbs)
Guard Rail Post Driver Operator
Highline Cableway Signalman
Hydra-Hammer-Aero Stomper
Hydraulic Casing Oscillator Operator – drilling depth of 30' maximum
Micro Tunneling Operator (above ground tunnel)
Power Concrete Curing Machine Operator
Power Concrete Saw Operator
Power - Driver Jumbo Form Setter Operator
Power Sweeper Operator
Rock Wheel Saw/Trencher
Roller Operator (compacting)
Screed Operator (asphalt or concrete)
Trenching Machine Operator (up to 6ft.)
Vacuum or Muck Truck

GROUP 5 (for multi-shift rate, see page 9B)

Equipment Greaser (Grease Truck/Multi-Shift)

GROUP 6

Articulating Material Hauler
Asphalt Plant Engineer
Batch Plant Operator
Bit Sharpener
Concrete Joint Machine Operator (canal and similar type)
Concrete Placer Operator
Concrete Planer Operator
Dandy Digger
Deck Engine Operator
Deck Engineer
Derrickman (oilfield type)

Drilling Machine Operator, Bucket or Auger types (Calweld 100 bucket or similar types - Watson 1000 auger or similar types - Texoma 330, 500 or 600 auger or similar types - drilling depth of 45' maximum)
Drilling Machine Operator (including water wells)

Hydraulic Casing Oscillator Operator – drilling depth of 45' maximum
Hydrographic Seeder Machine Operator (straw, pulp or seed)
Jackson Track Maintainer, or similar type
Kalamazoo Switch Tamper, or similar type
Machine Tool Operator
Maginnis Internal Full Slab Vibrator
Mechanical Berm, Curb or Gutter (concrete or asphalt)
Mechanical Finisher Operator (concrete, Clary-Johnson-Bidwell or similar)
Micro Tunnel System Operator (below ground)
Pavement Breaker Operator
Railcar Mover
Road Oil Mixing Machine Operator
Roller Operator (asphalt or finish)
Rubber-Tired Earthmoving Equipment (single engine, up to and including 25 yds. struck)
Self-Propelled Tar Pipelining Machine Operator
Skiploader Operator (crawler and wheel type, over 3/4 yds. and up to and including 1 1/2 yds.
Slip Form Pump Operator (power driven hydraulic lifting device for concrete forms)
Tractor Operator - Bulldozer, Tamper-Scraper (single engine, up to 100 H.P. flywheel and similar types, up to and including D-5 and similar types)
Tugger Hoist Operator (1 drum)
Ultra High Pressure Waterjet Cutting Tool System Operator
Vacuum Blasting Machine Operator
Volume Mixer Operator
Welder – General

GROUP 7 (for multi-shift rate, see page 9B)

Welder – General (Multi-Shift)

GROUP 8

Asphalt or Concrete Spreading Operator (tamping or finishing)
Asphalt Paving Machine Operator (barber greene or similar type, one (1) Screedman)
Asphalt-Rubber Distributor Operator
Backhoe Operator (up to and including 3/4 yds.) small ford, case or similar
Backhoe Operator (over 3/4 yd. and up to 5 cu. yds. M.R.C.)
Barrier Rail Mover (BTM Series 200 or similar types)
Cast in Place Pipe Laying Machine Operator
Cold Foamed Asphalt Recycler
Combination Mixer and Compressor Operator (gunite work)
Compactor Operator - Self Propelled
Concrete Mixer Operator - Paving
Crushing Plant Operator
Drill Doctor
Drilling Machine Operator, Bucket or Auger types (Calweld 150 bucket or similar types - Watson 1500, 2000, 2500 auger or similar types - Texoma 700, 800 auger or similar types - drilling depth of 60' maximum)
Elevating Grader Operator
Excavator Track/Rubber-Tired (Operating Weight 21,000 lbs - 100,000 lbs)
Global Positioning System/GPS (or Technician)
Grade Checker
Gradall Operator
Grouting Machine Operator
Heavy Duty Repairman/Pump Installer
Heavy Equipment Robotics Operator
Hydraulic Casing Oscillator Operator – drilling depth of 60' maximum
Hydraulic Operated Grout Plant (excludes hand loading)
Kalamazoo Ballast Regulator or similar type
Klemm Drill Operator or similar types
Kolman Belt Loader and similar type
Le Tourneau Blob Compactor or similar type
Lo Drill
Loader Operator (Athey, Euclid, Sierra and similar types)
Master Environmental Maintenance Mechanic
Mobark Chipper or similar types
Ozzie Padder or similar types
P.C. 490 Slot Saw
Pneumatic Concrete Placing Machine Operator (Hackley-Presswell or similar type)
Prentice 72IE Hydro-Ax
Pumpcrete Gun Operator
Rock Drill or Similar Types (see Miscellaneous Provision #4 for additional information regarding this classification)
Rotary Drill Operator (excluding caison type)
Rubber-Tired Earth Moving Equipment Operator (single engine, caterpillar, euclid, atthey wagon, and similar types with any and all attachments over 25 yds. and up to and including 50 cu. yds. struck)
Rubber-Tired Earth Moving Equipment Operator (multiple engine - up to and including 25 yds. struck)
Rubber-Tired Scraper Operator (self-loading paddle wheel type - John Deere, 1040 and similar single unit)
Self-Propelled Curb and Gutter Machine Operator
Shuttle Buggy
Skiploader Operator (crawler and wheel type over 1 1/2 yds. up to and including 6 1/2 yds.)
Soil Remediation Plant Operator (CMI, Envirotech or Similar)
Soil Stabilizer and Reclaimer (WR-2400)
Somero SXP Laser Screed
Speed Swing Operator
Surface Heaters and Planer Operator
Tractor Compressor Drill Combination Operator

DETERMINATION: SC-23-63-2-2015-1

GROUP 8 CONT.

Tractor Operator (any type larger than D-5 - 100 flywheel H.P. and over, or similar - bulldozer, tamper, scraper and push tractor, single engine)

Tractor Operator (boom attachments)

Traveling Pipe Wrapping, Cleaning and Bending Machine Operator

Trenching Machine Operator (over 6 ft. depth capacity, manufacturer's rating)

Trenching Machine with Road Miner Attachment (over 6ft. depth capacity, manufacturer's rating - Oiler or Journeyman Trainee required)

Ultra High Pressure Waterjet Cutting Tool System Mechanic

Water Pull (compaction)

GROUP 9 (for multi-shift rate, see page 9B)

Heavy Duty Repairman (Multi-Shift)

GROUP 10

Backhoe Operator (over 5 cu. yds. M.R.C.)

Drilling Machine Operator, Bucket or Auger types (Calweld 200 B bucket or similar types - Watson 3000

or 5000 auger or similar types - Texoma 900 auger or similar types - drilling depth of 105' maximum)

Dual Drum Mixer

Dynamic Compactor LDC350 or similar types

Heavy Duty Repairman-Welder combination

Hydraulic Casing Oscillator Operator - drilling depth of 105' maximum

Monorail Locomotive Operator (diesel, gas or electric)

Motor Patrol - Blade Operator (single engine)

Multiple Engine Tractor Operator (euclid and similar type - except quad 9 cat.)

Pneumatic Pipe Ramming Tool and similar types

Pre-stressed Wrapping Machine Operator (2 Operators required)

Rubber-Tired Earth Moving Equipment Operator (single engine, over 50 yds. struck)

Rubber-Tired Earth Moving Equipment Operator (multiple engine, euclid caterpillar and similar - over 25 yds. and up to 50 yds. struck)

Tower Crane Repairman

Tractor Loader Operator (crawler and wheel-type over 6 1/2 yds.)

Welder - Certified

Woods Mixer Operator (and similar pugmill equipment)

GROUP 11 (for multi-shift rate, see page 9B)

Heavy Duty Repairman - Welder Combination (Multi-Shift)

Welder - Certified (Multi-Shift)

GROUP 12

Auto Grader Operator

Automatic Slip Form Operator

Backhoe Operator (over 7 cu. yds. M.R.C.)

Drilling Machine Operator, Bucket or Auger types (Calweld, auger 200 CA or similar types - Watson,

auger 6000 or similar types - Hughes super duty, auger 200 or similar types - drilling depth of 175'

maximum)

Excavator Track/Rubber Tired (Operating Weight 100,000 lbs. - 200,000 lbs)

Hoe Ram or similar with compressor

Hydraulic Casing Oscillator Operator - drilling depth of 175' maximum

Mass Excavator Operator - less than 750 cu. yds.

Mechanical Finishing Machine Operator

Mobile Form Traveler Operator

Motor Patrol Operator (multi-engine)

Pipe Mobile Machine Operator

Rubber-Tired Earth Moving Equipment Operator (multiple engine, euclid, caterpillar and similar type,

over 50 cu. yds. struck)

Rubber-Tired Self-Loading Scraper Operator (paddle-wheel-auger type self-loading - (two (2) or more

units)

GROUP 13

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Push-Pull System (single

engine, up to and including 25 yds. struck)

GROUP 14

Canal Liner Operator

Canal Trimmer Operator

Remote Controlled Earth Moving Operator (\$1.00 per hour additional to base rate)

Wheel Excavator Operator (over 750 cu. yds. per hour)

GROUP 15

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Push-Pull System (single

engine, caterpillar, euclid, atthey wagon, and similar types with any and all attachments over 25 yds. and

up to and including 50 cu. yds. struck)

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Push-Pull System

(multiple engine - up to and including 25 yds. struck)

MISCELLANEOUS PROVISIONS:

1. Operators on hoists with three drums shall receive fifteen cents (15¢) per hour additional pay to the regular rate of pay. The additional pay shall be added to the regular rate and become the base rate for the entire shift.
2. All heavy duty repairman and heavy duty combination shall receive fifty cents (50¢) per hour tool allowance in addition to their regular rate of pay and this shall become their base rate of pay.
3. Employees required to suit up and work in a hazardous material environment, shall receive Two Dollars (\$2.00) per hour in addition to their regular rate of pay, and that rate shall become the basic hourly rate of pay.
4. A review of rock drilling is currently pending. The minimum acceptable rate of pay for this classification or type of work on public works projects is Laborer and Related Classifications/Group 5 (Driller) as published on pages 13 and 14 of the Director's General Prevailing Wage Determinations. However, the published rate for the craft/classification of Operating Engineer/Group 8 (Rock Drill or Similar Types) may be used by contractors to perform rock drilling on public works projects.

GROUP 16

Excavator Track/Rubber Tired (Operating Weight exceeding 200,000 lbs.)

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Push-Pull

System (single engine, over 50 yds. struck)

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Push-Pull

System (multiple engine, euclid, caterpillar, and similar, over 25 yds. and up to 50 yds.

struck)

GROUP 17

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Push-Pull

System (multiple engine, euclid, caterpillar, and similar type, over 50 cu. yds. struck)

Tandem Tractor Operator (operating crawler type tractors in tandem - Quad 9 and similar

type)

GROUP 18

Rubber-Tired Earth Moving Equipment Operator, Operating in Tandem (scrappers, belly

dumps, and similar types in any combination, excluding compaction units - single engine, up

to and including 25 yds. struck)

GROUP 19

Rotex Concrete Belt Operator

Rubber-Tired Earth Moving Equipment Operator, Operating in Tandem (scrappers, belly

dumps, and similar types in any combination, excluding compaction units - single engine,

caterpillar, euclid, atthey wagon, and similar types with any and all attachments over 25 yds.

and up to and including 50 cu. yds. struck)

Rubber-Tired Earth Moving Equipment Operator, Operating in Tandem (scrappers, belly

dumps, and similar types in any combination, excluding compaction units - multiple engines,

up to and including 25 yds. struck)

GROUP 20

Rubber-Tired Earth Moving Equipment Operator, Operating in Tandem (scrappers, belly

dumps, and similar types in any combination, excluding compaction units - single engine,

over 50 yds. struck)

Rubber-Tired Earth Moving Equipment Operator, Operating in Tandem (scrappers, belly

dumps, and similar types in any combination, excluding compaction units - multiple engine,

euclid, caterpillar and similar, over 25 yds. and up to 50 yds. struck)

Drilling Machine Operator, Bucket or Auger types (Calweld, auger 200 CA or similar types -

GROUP 21

Rubber-Tired Earth Moving Equipment Operator, Operating in Tandem (scrappers, belly

dumps, and similar types in any combination, excluding compaction units - multiple engine,

euclid, caterpillar and similar type, over 50 cu. yds. struck)

GROUP 22

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Tandem

Push-Pull System (single engine, up to and including 25 yds. struck)

GROUP 23

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Tandem

Push-Pull System (single engine, caterpillar, euclid, atthey wagon, and similar types with any

and all attachments over 25 yds. and up to and including 50 cu. yds. struck)

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Tandem

Push-Pull System (multiple engine, up to and including 25 yds. struck)

GROUP 24

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Tandem

Push-Pull System (single engine, over 50 yds. struck)

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Tandem

Push-Pull System (multiple engine, euclid, caterpillar and similar, over 25 yds. and up to 50

yds. struck)

GROUP 25

Concrete Pump Operator-Truck Mounted

Pedestal Concrete Pump Operator

Rubber-Tired Earth Moving Equipment Operator, Operating Equipment with the Tandem

Push-Pull System (multiple engine, euclid, caterpillar and similar over 50 cu. yds. struck)

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1

FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

CRAFT: #OPERATING ENGINEER (Special Shift)

DETERMINATION: SC-23-63-2-2015-1

ISSUE DATE: August 22, 2015

EXPIRATION DATE OF DETERMINATION: June 30, 2016* Effective until superseded by a new determination issued by the Director of Industrial Relations. Contact the Office of the Director – Research Unit at (415) 703-4774 for new rates after 10 days from the expiration date, if no subsequent determination is issued.

LOCALITY: All localities within Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, and Ventura counties.

CLASSIFICATION (Journey person)	Employer Payments						Straight – Time		Overtime Hourly Rate		
	Basic Hourly Rate	Health and Welfare	Pension	Vacation/ Holiday (a)	Training	Other Payments	Hours	Total Hourly Rate	Daily (c)	Saturday (d)	Sunday/ Holiday
									1 1/2X	1 1/2X	2X
Classification Groups (b)											
Group 1	\$40.45	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$65.39	\$85.615	\$85.615	\$105.84
Group 2	\$41.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$66.17	\$86.785	\$86.785	\$107.40
Group 3	\$41.52	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$66.46	\$87.220	\$87.220	\$107.98
Group 4	\$43.01	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$67.95	\$89.455	\$89.455	\$110.96
Group 6	\$43.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.17	\$89.785	\$89.785	\$111.40
Group 8	\$43.34	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.28	\$89.950	\$89.950	\$111.62
Group 10	\$43.46	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.40	\$90.130	\$90.130	\$111.86
Group 12	\$43.63	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.57	\$90.385	\$90.385	\$112.20
Group 13	\$43.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.67	\$90.535	\$90.535	\$112.40
Group 14	\$43.76	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.70	\$90.580	\$90.580	\$112.46
Group 15	\$43.84	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.78	\$90.700	\$90.700	\$112.62
Group 16	\$43.96	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.90	\$90.880	\$90.880	\$112.86
Group 17	\$44.13	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.07	\$91.135	\$91.135	\$113.20
Group 18	\$44.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.17	\$91.285	\$91.285	\$113.40
Group 19	\$44.34	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.28	\$91.450	\$91.450	\$113.62
Group 20	\$44.46	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.40	\$91.630	\$91.630	\$113.86
Group 21	\$44.63	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.57	\$91.885	\$91.885	\$114.20
Group 22	\$44.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.67	\$92.035	\$92.035	\$114.40
Group 23	\$44.84	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.78	\$92.200	\$92.200	\$114.62
Group 24	\$44.96	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.90	\$92.380	\$92.380	\$114.86
Group 25	\$45.13	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$70.07	\$92.635	\$92.635	\$115.20

Indicates an apprenticeable craft. The current apprentice wage rates are available on the Internet @ <http://www.dir.ca.gov/OPRL/PWAppWage/PWAppWageStart.asp>. To obtain any apprentice wage rates as of July 1, 2008 and prior to September 27, 2012, please contact the Division of Apprenticeship Standards or refer to the Division of Apprenticeship Standards' website at <http://www.dir.ca.gov/das/das.html>.

^a Includes an amount withheld for supplemental dues.

^b For classifications within each group, see pages 8 and 9.

^c Rate applies to the first 4 overtime hours. All other daily overtime is paid at the Sunday rate.

^d Rate applies to the first 12 hours worked. All other time is paid at the Sunday rate.

RECOGNIZED HOLIDAYS: Holidays upon which the general prevailing hourly wage rate for Holiday work shall be paid, shall be all holidays in the collective bargaining agreement, applicable to the particular craft, classification, or type of worker employed on the project, which is on file with the Director of Industrial Relations. If the prevailing rate is not based on a collectively bargained rate, the holidays upon which the prevailing rate shall be paid shall be as provided in Section 6700 of the Government Code. You may obtain the holiday provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Holiday provisions for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

TRAVEL AND/OR SUBSISTENCE PAYMENT: In accordance with Labor Code Sections 1773.1 and 1773.9, contractors shall make travel and/or subsistence payments to each worker to execute the work. You may obtain the travel and/or subsistence provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Travel and/or subsistence requirements for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1

FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

CRAFT: #OPERATING ENGINEER (Multi-Shift)

DETERMINATION: SC-23-63-2-2015-1

ISSUE DATE: August 22, 2015

EXPIRATION DATE OF DETERMINATION: June 30, 2016* Effective until superseded by a new determination issued by the Director of Industrial Relations. Contact the Office of the Director – Research Unit at (415) 703-4774 for new rates after 10 days from the expiration date, if no subsequent determination is issued.

LOCALITY: All localities within Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, and Ventura counties.

CLASSIFICATION (Journey/Person)	Employer Payments						Straight – Time		Overtime Hourly Rate		
	Basic Hourly Rate	Health and Welfare	Pension	Vacation/ Holiday (a)	Training	Other Payments	Hours (e)	Total Hourly Rate	Daily (c) 1 1/2X	Saturday (d) 1 1/2X	Sunday/ Holiday 2X
Classification Groups (b)											
Group 1	\$40.95	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$65.89	\$86.365	\$86.365	\$106.84
Group 2	\$41.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$66.67	\$87.535	\$87.535	\$108.40
Group 3	\$42.02	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$66.96	\$87.970	\$87.970	\$108.98
Group 4	\$43.51	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.45	\$90.205	\$90.205	\$111.96
Group 5	\$43.61	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.55	\$90.355	\$90.355	\$112.16
Group 6	\$43.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.67	\$90.535	\$90.535	\$112.40
Group 7	\$43.83	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.77	\$90.685	\$90.685	\$112.60
Group 8	\$43.84	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.78	\$90.700	\$90.700	\$112.62
Group 9	\$43.94	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.88	\$90.850	\$90.850	\$112.82
Group 10	\$43.96	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$68.90	\$90.880	\$90.880	\$112.86
Group 11	\$44.06	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.00	\$91.030	\$91.030	\$113.06
Group 12	\$44.13	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.07	\$91.135	\$91.135	\$113.20
Group 13	\$44.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.17	\$91.285	\$91.285	\$113.40
Group 14	\$44.26	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.20	\$91.330	\$91.330	\$113.46
Group 15	\$44.34	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.28	\$91.450	\$91.450	\$113.62
Group 16	\$44.46	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.40	\$91.630	\$91.630	\$113.86
Group 17	\$44.63	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.57	\$91.885	\$91.885	\$114.20
Group 18	\$44.73	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.67	\$92.035	\$92.035	\$114.40
Group 19	\$44.84	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.78	\$92.200	\$92.200	\$114.62
Group 20	\$44.96	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$69.90	\$92.380	\$92.380	\$114.86
Group 21	\$45.13	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$70.07	\$92.635	\$92.635	\$115.20
Group 22	\$45.23	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$70.17	\$92.785	\$92.785	\$115.40
Group 23	\$45.34	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$70.28	\$92.950	\$92.950	\$115.62
Group 24	\$45.46	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$70.40	\$93.130	\$93.130	\$115.86
Group 25	\$45.63	\$11.20	\$9.65	\$3.00	\$0.80	\$0.29	8	\$70.57	\$93.385	\$93.385	\$116.20

Indicates an apprenticeable craft. The current apprentice wage rates are available on the Internet @ <http://www.dir.ca.gov/OPRL/PWAppWage/PWAppWageStart.asp>. To obtain any apprentice wage rates as of July 1, 2008 and prior to September 27, 2012, please contact the Division of Apprenticeship Standards or refer to the Division of Apprenticeship Standards' website at <http://www.dir.ca.gov/das/das.html>.

^a Includes an amount withheld for supplemental dues.

^b For classifications within each group, see pages 8 and 9.

^c Rate applies to the first 4 overtime hours. All other daily overtime is paid at the Sunday rate.

^d Rate applies to the first 12 hours worked. All other time is paid at the Sunday rate.

^e The Third Shift shall work 6.5 hours, exclusive of meal period, for which 8 hours straight-time shall be paid at the non-shift rate, Monday through Friday.

RECOGNIZED HOLIDAYS: Holidays upon which the general prevailing hourly wage rate for Holiday work shall be paid, shall be all holidays in the collective bargaining agreement, applicable to the particular craft, classification, or type of worker employed on the project, which is on file with the Director of Industrial Relations. If the prevailing rate is not based on a collectively bargained rate, the holidays upon which the prevailing rate shall be paid shall be as provided in Section 6700 of the Government Code. You may obtain the holiday provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Holiday provisions for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

TRAVEL AND/OR SUBSISTENCE PAYMENT: In accordance with Labor Code Sections 1773.1 and 1773.9, contractors shall make travel and/or subsistence payments to each worker to execute the work. You may obtain the travel and/or subsistence provisions for the current determinations on the Internet at <http://www.dir.ca.gov/OPRL/PWD>. Travel and/or subsistence requirements for current or superseded determinations may be obtained by contacting the Office of the Director – Research Unit at (415) 703-4774.

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
 PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1
 FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

LOCALITY: LOS ANGELES COUNTY
 DETERMINATION: LOS-2015-2

CRAFT (JOURNEY LEVEL)	ISSUE DATE	EXPIRATION DATE	EMPLOYER PAYMENTS					STRAIGHT-TIME				OVERTIME HOURLY RATE				
			BASIC HOURLY RATE	HEALTH AND WELFARE	PENSION	VACATION/HOLIDAY	TRAINING	OTHER PAYMENTS	HOURS	TOTAL HOURLY RATE	DAILY	SATURDAY	SUNDAY AND HOLIDAY			
# BRICKLAYER, STONEMASON, MARBLE MASON, CEMENT BLOCKLAYER, POINTER, CAULKER, CLEANER	08/22/2015	04/30/2016*	A 37.930	7.500	6.900	-	B 0.780	0.350	C 8.0	53.460	D 72.430	D 72.430	D 72.430	D 72.430	D 72.430	91.390
# BRICKLAYER:																
# MASON FINISHER	08/22/2015	04/30/2016*	A 26.550	7.500	6.900	-	E 0.670	0.350	C 8.0	41.970	D 55.240	D 55.240	D 55.240	D 55.240	D 55.240	68.520
# F BRICK TENDER	08/22/2015	06/30/2016*	29.570	6.860	6.500	G 3.900	0.650	0.470	C 8.0	47.950	62.740	62.740	62.740	62.740	62.740	77.520
# BRICK TENDER:																
# FORKLIFT OPERATOR	08/22/2015	06/30/2016*	30.020	6.860	6.500	G 3.900	0.650	0.470	C 8.0	48.400	63.410	63.410	63.410	63.410	63.410	78.420
# CARPET, LINOLEUM,																
# RESILIENT TILE LAYER	02/22/2015	12/31/2015**	H 29.850	5.080	5.800	2.050	0.630	0.200	8.0	43.610	58.540	I 58.540	I 58.540	I 58.540	I 58.540	73.460
# MATERIAL HANDLER	02/22/2015	12/31/2015**	H 9.000	5.080	2.100	0.550	0.630	0.100	8.0	17.460	21.960	I 21.960	I 21.960	I 21.960	I 21.960	26.460
# DRYWALL FINISHER																
# K DRYWALL FINISHER	08/22/2015	09/30/2015**	L 32.110	7.550	4.620	3.070	0.670	0.470	8.0	48.490	64.540	M 64.540	M 64.540	M 64.540	M 64.540	80.600
# DRYWALL FINISHER	08/22/2015	09/30/2015**	H 35.180	7.550	4.620	3.070	0.670	0.470	8.0	51.560	69.150	M 69.150	M 69.150	M 69.150	M 69.150	86.740
# ELECTRICIAN:																
# COMM & SYSTEM INSTALLER	02/22/2015	12/27/2015**	29.760	7.810	N 3.620	-	0.650	O 0.250	8.0	42.980	58.310	P 58.310	P 58.310	P 58.310	P 58.310	73.640
# SOUND ELECTRICIAN	02/22/2015	12/27/2015**	32.560	7.810	N 3.620	-	0.650	O 0.250	8.0	45.870	62.640	P 62.640	P 62.640	P 62.640	P 62.640	79.400
# INSIDE WIREMAN, RADIO MONITOR TECHNICIAN	08/22/2015	01/31/2016**	40.800	11.440	Q 13.270	R -	0.660	0.450	8.0	67.840	88.860	P 88.860	P 88.860	P 88.860	P 88.860	109.870
# CABLE SPLICER-WELDER	08/22/2015	01/31/2016**	42.840	11.440	Q 13.270	R -	0.660	0.450	8.0	69.950	92.010	P 92.010	P 92.010	P 92.010	P 92.010	114.070
# TUNNEL WIREMAN	08/22/2015	01/31/2016**	44.880	11.440	Q 13.270	R -	0.660	0.450	8.0	72.050	95.160	P 95.160	P 95.160	P 95.160	P 95.160	118.270
# TUNNEL CABLE SPLICER	08/22/2015	01/31/2016**	47.120	11.440	Q 13.270	R -	0.660	0.450	8.0	74.350	98.620	P 98.620	P 98.620	P 98.620	P 98.620	122.890
# TRANSPORTATION SYSTEMS ELECTRICIAN	08/22/2015	01/31/2016**	40.800	11.440	Q 13.270	R -	0.660	0.450	8.0	67.840	88.860	P 88.860	P 88.860	P 88.860	P 88.860	109.870
# TRANSPORTATION SYSTEMS ELECTRICIAN (CABLE SPLICING, WELDING, AND META TESTING)	08/22/2015	01/31/2016**	42.840	11.440	Q 13.270	R -	0.660	0.450	8.0	69.950	92.010	P 92.010	P 92.010	P 92.010	P 92.010	114.070
# TRANSPORTATION SYSTEMS TECHNICIAN	08/22/2015	01/31/2016**	30.600	11.440	Q 13.270	R -	0.660	0.450	8.0	57.340	73.100	P 73.100	P 73.100	P 73.100	P 73.100	88.860
# FIELD SURVEYOR:																
# T CHIEF OF PARTY (018.167-010)	08/22/2015	09/30/2015**	43.910	11.200	8.550	G 4.150	0.900	0.150	8.0	68.860	90.810	P 90.810	P 90.810	P 90.810	P 90.810	112.770
# T INSTRUMENTMAN (018.167-034)	08/22/2015	09/30/2015**	41.410	11.200	8.550	G 4.150	0.900	0.150	8.0	66.360	87.060	P 87.060	P 87.060	P 87.060	P 87.060	107.770
# T CHAINMAN/RODMAN (869.567-010)	08/22/2015	09/30/2015**	40.830	11.200	8.550	G 4.150	0.900	0.150	8.0	65.780	86.190	P 86.190	P 86.190	P 86.190	P 86.190	106.610
# GLAZIER	08/22/2015	05/31/2016**	U 40.700	7.000	13.030	W -	0.770	0.530	8.0	62.030	81.380	X 81.380	X 81.380	X 81.380	X 81.380	100.730
# MARBLE FINISHER	08/22/2015	05/31/2016**	Y 28.450	9.160	2.710	-	0.810	0.330	Z 8.0	41.460	55.690	AA 55.690	AB 55.690	AC 55.690	AC 55.690	69.910
# PAINTER																
# AD INDUSTRIAL PAINTER	08/22/2015	06/30/2016*	L 32.020	8.050	3.040	1.050	0.790	0.820	8.0	45.770	61.780	AE 61.780	AE 61.780	AE 61.780	AE 61.780	61.780
# PAINTER:																
# AD PAINTER, LEAD ABATEMENT	08/22/2015	06/30/2016*	L 30.720	8.050	3.040	1.050	0.690	0.820	8.0	44.370	59.730	AE 59.730	AE 59.730	AE 59.730	AE 59.730	59.730
# AD REPAINT PAINTER, LEAD ABATEMENT	08/22/2015	06/30/2016*	L 27.290	8.050	3.040	1.050	0.690	0.820	8.0	40.940	54.580	AF 54.580	AF 54.580	AF 54.580	AF 54.580	54.580
# AG PAINTER, LEAD ABATEMENT	08/22/2015	06/30/2016*	L 26.410	8.050	3.040	1.050	0.690	0.820	8.0	40.060	53.260	AE 53.260	AE 53.260	AE 53.260	AE 53.260	53.260
# AG REPAINT PAINTER, LEAD ABATEMENT	08/22/2015	06/30/2016*	L 24.190	8.050	3.040	1.050	0.690	0.820	8.0	37.840	49.930	AF 49.930	AF 49.930	AF 49.930	AF 49.930	49.930
# AD INDUSTRIAL REPAIR PAINTER	08/22/2015	06/30/2016*	L 28.450	8.050	3.040	1.050	0.790	0.820	8.0	42.200	56.430	AF 56.430	AF 56.430	AF 56.430	AF 56.430	56.430
# PLASTERER	08/22/2015	08/02/2016**	32.910	8.930	4.210	AH 5.530	0.630	0.990	AI 8.0	53.200	69.650	AJ 69.650	AJ 69.650	AJ 69.650	AJ 69.650	86.110
# AK PLASTER TENDER	08/22/2015	08/02/2016**	32.710	7.000	5.900	AH 5.050	1.020	1.020	8.0	52.700	69.060	AM 69.060	AM 69.060	AM 69.060	AM 69.060	85.410

GENERAL PREVAILING WAGE DETERMINATION MADE BY THE DIRECTOR OF INDUSTRIAL RELATIONS
 PURSUANT TO CALIFORNIA LABOR CODE PART 7, CHAPTER 1, ARTICLE 2, SECTIONS 1770, 1773 AND 1773.1
 FOR COMMERCIAL BUILDING, HIGHWAY, HEAVY CONSTRUCTION AND DREDGING PROJECTS

LOCALITY: LOS ANGELES COUNTY
 DETERMINATION: LOS-2015-2

#	CRAFT (JOURNEY LEVEL)	ISSUE DATE	EXPIRATION DATE	EMPLOYER PAYMENTS					STRAIGHT-TIME			OVERTIME HOURLY RATE			
				BASIC HOURLY RATE	HEALTH AND WELFARE	PENSION	VACATION/HOLIDAY	TRAINING	OTHER PAYMENTS	HOURS	TOTAL HOURLY RATE	DAILY	SATURDAY	SUNDAY AND HOLIDAY	
	PLASTER CLEAN-UP LABORER	08/22/2015	08/02/2016**	30.160	7.000	5.900	5.050	1.020	1.020	8.0	50.150	AL	65.230	AM	80.310
	PLUMBER: PLUMBER, INDUSTRIAL AND GENERAL PIPEFITTER	08/22/2015	06/30/2016**	42.930	7.110	11.050	3.030	2.550	1.000	8.0	67.670	AQ	89.850	AQ	110.520
	SEWER AND STORM DRAIN PIPELAYER	08/22/2015	06/30/2016**	33.110	7.110	8.200	1.000	2.170	1.000	8.0	52.590	AR	68.850	AR	84.600
AS	SEWER AND STORM DRAIN PIPE TRADESMAN	08/22/2015	06/30/2016**	17.060	7.110	0.380	-	1.600	0.850	8.0	27.000	AR	34.730	AR	42.460
	LANDSCAPE/IRRIGATION FITTER	08/22/2015	06/30/2016**	27.620	7.110	11.050	2.490	1.940	0.800	8.0	51.010	AR	66.070	AR	79.880
AT	LANDSCAPE/IRRIGATION TRADESMAN	08/22/2015	06/30/2016*	13.390	2.000	AN	0.880	0.100	0.750	8.0	17.120	AR	23.820	AR	30.510
	(HVACR)	08/22/2014	08/31/2015*	41.290	9.530	AU	8.830	1.300	0.560	8.0	61.510	AW	82.150	AW	101.650
	REFRIGERATION SERVICE AND REPAIR TRADESMAN (HVACR)	08/22/2014	08/31/2015*	10.900	9.530	1.400	R	0.500	0.440	8.0	22.770	AW	28.220	AW	33.220
AX	FIRE SPRINKLER FITTER (PROTECTION AND CONTROL SYSTEMS, OVERHEAD AND UNDERGROUND)	08/22/2015	12/31/2015**	35.570	8.520	AY	10.900	0.450	0.250	8.0	55.690	BB	73.470	BB	91.260
AZ	FIRE SPRINKLER FITTER (PROTECTION AND CONTROL SYSTEMS, OVERHEAD AND UNDERGROUND)	08/22/2015	12/31/2015**	40.460	8.670	14.150	R	1.350	0.550	8.0	65.180	BK	85.410	BK	105.640
	ROOFER	08/22/2014	07/31/2015*	35.020	7.560	BD	5.590	0.400	0.520	8.0	49.090	BK	64.800	BK	80.510
	PITCH WORK	08/22/2014	07/31/2015*	36.770	7.560	BD	5.590	0.400	0.520	8.0	50.840	BK	67.430	BK	84.010
	PREPARER	08/22/2014	07/31/2015*	36.020	7.560	BD	5.590	0.400	0.520	8.0	50.090	BK	66.300	BK	82.510
# BF	SHEET METAL WORKER	08/22/2015	06/30/2016**	41.260	9.870	BG	14.710	0.820	0.650	8.0	67.310	BK	87.940	BK	108.570
# BI	SHEET METAL WORKER LIGHT COMMERCIAL SHEET METAL WORKER UP TO AND INCLUDING 10,000 SQUARE FEET.	08/22/2015	06/30/2016**	31.530	9.870	BJ	13.720	1.670	0.350	8.0	57.140	BK	72.900	BK	88.670
BI	TERRAZZO FINISHER	08/22/2015	06/30/2016**	25.220	9.870	BJ	13.720	1.670	0.350	8.0	50.830	AA	63.440	AA	63.440
#	TERRAZZO WORKER	08/22/2014	08/31/2015*	27.530	7.510	3.270	R	0.490	0.120	8.0	38.920	AA	52.690	AA	66.450
#	TILE FINISHER	08/22/2014	08/31/2015*	34.570	8.300	3.270	R	0.570	0.120	8.0	46.830	AA	64.110	AA	81.400
#	TILE FINISHER	08/22/2015	05/31/2016**	23.780	8.430	1.800	-	0.750	0.280	8.0	35.040	AA	46.930	AA	58.820
#	TILE LAYER	08/22/2015	05/31/2016**	35.140	9.250	5.680	-	0.910	0.370	8.0	51.350	AA	68.920	AA	86.490

FOOTNOTES

LOCALITY: LOS ANGELES COUNTY
 DETERMINATION: LOS-2015-52

CRAFT (JOURNEY LEVEL)	ISSUE DATE	EXPIRATION DATE	INCREASE 1	INCREASE 2	INCREASE 3	INCREASE 4	INCREASE 5	INCREASE 6	INCREASE 7	INCREASE 8	INCREASE 9	INCREASE 10	
	DATE OF NEXT CHANGE	DATE OF NEXT CHANGE	AMOUNT OF INCREASE	DATE OF NEXT CHANGE	AMOUNT OF NEXT INCREASE	DATE OF NEXT CHANGE	AMOUNT OF NEXT INCREASE	DATE OF NEXT CHANGE	AMOUNT OF NEXT INCREASE	DATE OF NEXT CHANGE	AMOUNT OF NEXT INCREASE	DATE OF NEXT CHANGE	AMOUNT OF NEXT INCREASE
CARPET, LINOLEUM													
B RESILIENT TILE LAYER	02/22/2015	12/31/2015**	\$0.50	A	01/01/2016								
B MATERIAL HANDLER	02/22/2015	12/31/2015**	\$0.18	C	01/01/2016								
D DRYWALL FINISHER	08/22/2015	09/30/2015**	\$1.91	E	10/01/2015								
D DRYWALL FINISHER	08/22/2015	09/30/2015**	\$1.91	E	10/01/2015								
ELECTRICIAN:													
COMM & SYSTEM INSTALLER	02/22/2015	12/27/2015**	\$2.00	F	12/26/2016	\$2.00	F	01/01/2019	\$2.50	F			
SOUND ELECTRICIAN	02/22/2015	12/27/2015**	\$2.00	F	12/26/2016	\$2.00	F	01/01/2019	\$2.50	F			
INSIDE WIREMAN, RADIO MONITOR TECHNICIAN	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
CABLE SPlicer-WELDER	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
TUNNEL WIREMAN	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
TUNNEL CABLE SPICER	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
TRANSPORTATION SYSTEMS ELECTRICIAN	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
TELEPHONE SYSTEMS ELECTRICIAN (CABLE SPLICING, WELDING AND META TESTING)	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
TECHNICIAN	08/22/2015	01/31/2016**	\$1.00	F	08/01/2016	\$1.00	F	07/31/2017	\$1.10	G	01/29/2018	\$1.00	
H FIELD SURVEYOR:													
CHIEF OF PARTY (018 167-010)	08/22/2015	01/31/2016**	\$0.75	F	08/01/2016	\$0.75	F	01/30/2017	\$0.85	I	01/29/2018	\$0.75	
INSTRUMENTMAN (018 167-054)	08/22/2015	01/31/2016**	\$0.75	F	08/01/2016	\$0.75	F	01/30/2017	\$0.85	I	01/29/2018	\$0.75	
J CHAINMAN/RODMAN (868 567-010)	08/22/2015	09/30/2015**	\$2.00	K	10/01/2015								
GLAZIER	08/22/2015	05/31/2016**	\$1.33	L	06/01/2016								
MARBLE FINISHER	08/22/2015	05/31/2016**	\$1.00	F	06/01/2016								
PLASTERER	08/22/2015	08/02/2016**	\$1.75	F	08/02/2017	\$1.75	F	08/02/2017	\$1.75	F			
PLASTER TENDER	08/22/2015	08/02/2016**	\$1.75	F	08/02/2017	\$1.75	F	08/02/2017	\$1.75	F			
PLASTER CLEAN-UP LABORER	08/22/2015	08/02/2016**	\$1.75	F	08/02/2017	\$1.75	F	08/02/2017	\$1.75	F			
PLUMBER:													
RUBBER, INDUSTRIAL AND GENERAL PIPEFITTER	08/22/2015	06/30/2016**	\$2.02	F	07/01/2017	\$2.43	F	07/01/2017	\$2.43	F			
SEWER AND STORM DRAIN PIPELAYER	08/22/2015	06/30/2016**	\$1.56	F	07/01/2017	\$1.87	F	07/01/2017	\$1.87	F			
SEWER AND STORM DRAIN PIPE TRADESMAN	08/22/2015	06/30/2016**	\$0.80	F	07/01/2017	\$0.97	F	07/01/2017	\$0.97	F			
LANDSCAPE/IRRIGATION FITTER (PROTECTION AND CONTROL SYSTEMS, OVERHEAD AND UNDERGROUND)	08/22/2015	06/30/2016**	\$1.52	F	07/01/2017	\$1.82	F	07/01/2017	\$1.82	F			
O FIRE SPRINKLER FITTER (PROTECTION AND CONTROL SYSTEMS, OVERHEAD AND UNDERGROUND)	08/22/2015	12/31/2015**	\$0.40	P	01/01/2016								
Q SHEET METAL WORKER	08/22/2015	12/31/2015**		R	01/01/2016								
S SHEET METAL WORKER	08/22/2015	06/30/2016**	\$2.10	T	07/01/2017	\$2.00	U	07/01/2018	\$2.00	F	07/01/2019	\$2.00	
V LIGHT COMMERCIAL SHEET METAL WORKER UP TO AND INCLUDING 10,000 SQUARE FEET.	08/22/2015	06/30/2016**	\$1.25	F	07/01/2017	\$1.35	F	07/01/2017	\$1.35	F			
V TILE FINISHER	08/22/2015	06/30/2016**	\$1.00	F	07/01/2017	\$1.08	F	07/01/2017	\$1.08	F			
TILE LAYER	08/22/2015	05/31/2016**	\$0.85	F	06/01/2016	\$0.85	F	06/01/2016	\$0.85	F			
TILE LAYER	08/22/2015	05/31/2016**	\$1.15	F	06/01/2016	\$1.15	F	06/01/2016	\$1.15	F			

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** Issue Date: **08-22-2015** Expire Date: **06-30-2016** * Page: **1**

Craft/Classification: **Scaffold Builder (Carpenter)**

Counties: Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, Ventura

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1	6	1,000	\$12.640	\$6.600		\$2.450	\$.570	\$.340	\$22.600
2	6	600	\$15.800	\$6.600		\$2.450	\$.570	\$.340	\$25.760
3	6	600	\$18.960	\$6.600		\$3.450	\$.570	\$.340	\$29.920
4	6	600	\$20.540	\$6.600	\$4.410	\$3.450	\$.570	\$.340	\$35.910
5	6	600	\$22.120	\$6.600	\$4.410	\$3.450	\$.570	\$.340	\$37.490
6	6	600	\$23.700	\$6.600	\$4.410	\$3.450	\$.570	\$.340	\$39.070
7	6	600	\$25.280	\$6.600	\$4.410	\$3.450	\$.570	\$.340	\$40.650
8	6	600	\$28.440	\$6.600	\$4.410	\$3.450	\$.570	\$.340	\$43.810

Footnote(s):

Vacation/Holiday--Includes an amount for Supplemental Dues.

Other--Includes an amount for Contract Administration, Cooperation Committee, Grievance, & Industry Advancement.

*No Predetermined Increases

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: 2015-2 Issue Date: 08-22-2015 Expire Date: 07-03-2016 ** Page: 1

Craft/Classification: **Laborer**

Counties: Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, Ventura

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1		500	\$17.200	\$4.800	\$1.300	\$3.130	\$.640	\$.620	\$27.690
2		500	\$18.910	\$4.800	\$1.300	\$3.130	\$.640	\$.620	\$29.400
3		500	\$20.630	\$4.800	\$1.300	\$3.130	\$.640	\$.620	\$31.120
4		500	\$24.070	\$4.800	\$1.300	\$3.130	\$.640	\$.620	\$34.560
5		500	\$27.510	\$4.800	\$1.300	\$3.130	\$.640	\$.620	\$38.000
6		500	\$29.230	\$4.800	\$1.300	\$3.130	\$.640	\$.620	\$39.720

Footnote(s):

Note: Apprentice rates are based on JM Laborer Group V rates.

Vacation -- Includes an amount for supplemental dues.

Other -- Includes amounts for Center for Contract Compliance, Industry Fund, and Administrative Trust Fund, Contract Administration Fund and Partnership for Jobs Industry Advancement Fund.

****Journeyman Predetermined Increases**

Effective 7/4/2016: \$0.25 to Pension and 1.35 to be allocated to wages and/or employer payments

Effective 7/3/2017: \$0.25 to Pension and 1.45 to be allocated to wages and/or employer payments

There may be corresponding predetermined increase(s) to the apprentices associated with this journeyman craft/classification. Please fax a request to (415) 703-4771 or send to the following address:

Department of Industrial Relations
Office of the Director - Research Unit
P.O. Box 420603
San Francisco, CA 94142-0603

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** *Issue Date:* **08-22-2015** *Expire Date:* **01-31-2016** ****** *Page:* **1**

Craft/Classification: **Electrician, Inside Wireman** *Shift:* **1**

County: Los Angeles

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1	6		\$16.320	\$10.440	\$.490		\$.710	\$.450	\$28.410
2	6		\$18.360	\$10.440	\$.550		\$.710	\$.450	\$30.510
3	6		\$20.400	\$11.440	\$7.250		\$.710	\$.450	\$40.250
4	6		\$22.440	\$11.440	\$7.970		\$.710	\$.450	\$43.010
5	6		\$24.480	\$11.440	\$8.700		\$.710	\$.450	\$45.780
6	6		\$26.520	\$11.440	\$9.420		\$.710	\$.450	\$48.540
7	6		\$28.560	\$11.440	\$10.150		\$.710	\$.450	\$51.310
8	6		\$30.600	\$11.440	\$10.870		\$.710	\$.450	\$54.070
9	6		\$32.640	\$11.440	\$11.600		\$.710	\$.450	\$56.840
10	6		\$34.680	\$11.440	\$12.320		\$.710	\$.450	\$59.600

Footnote(s):

Pension -- includes amounts for defined contribution and benefit plans for apprentices above Period 2. In addition, an amount equal to 3% of the basic hourly rate is added to the total hourly rate and overtime hourly rates for the National Employees Benefit Board. Pursuant to Labor Code Sections 1773.1 and 1773.8 the amount paid for this employer payment may vary resulting in a lower taxable basic hourly wage rate, but the total hourly rates for straight time and overtime may not be less than the general prevailing rate of per diem wages.

Vacation/Holiday included in the Basic Hourly Rate.

Journeyman Predetermined Increases:

- 2/1/16 \$1.00 to be allocated to wages and/or fringes
- 8/1/16 \$1.00 to be allocated to wages and/or fringes
- 1/30/17 \$1.00 to be allocated to wages and/or fringes .
- 7/31/17 \$0.05 to Training, \$0.05 to Other, and \$1.00 to be allocated to wages and/or fringes .
- 1/29/18 \$1.00 to be allocated to wages and/or fringes .
- 7/30/18 \$1.00 to be allocated to wages and/or fringes .
- 1/28/19 \$1.00 to be allocated to wages and/or fringes .

There may be corresponding predetermined increase(s) to the apprentices associated with this journeyman craft/classification. Please fax a request to (415) 703-4771 or send to the following address:

Department of Industrial Relations, Office of the Director - Research Unit
P.O. Box 420603
San Francisco, CA 94142-0603

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** *Issue Date:* **08-22-2015** *Expire Date:* **01-31-2016** ****** *Page:* **2**

Craft/Classification: **Electrician, Inside Wireman** *Shift:* **2**

County: Los Angeles

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1	6		\$19.140	\$10.440	\$.570		\$.710	\$.450	\$31.310
2	6		\$21.540	\$10.440	\$.650		\$.710	\$.450	\$33.790
3	6		\$23.930	\$11.440	\$7.350		\$.710	\$.450	\$43.880
4	6		\$26.320	\$11.440	\$8.090		\$.710	\$.450	\$47.010
5	6		\$28.720	\$11.440	\$8.820		\$.710	\$.450	\$50.140
6	6		\$31.110	\$11.440	\$9.560		\$.710	\$.450	\$53.270
7	6		\$33.500	\$11.440	\$10.290		\$.710	\$.450	\$56.390
8	6		\$35.890	\$11.440	\$11.030		\$.710	\$.450	\$59.520
9	6		\$38.290	\$11.440	\$11.760		\$.710	\$.450	\$62.650
10	6		\$40.680	\$11.440	\$12.500		\$.710	\$.450	\$65.780

Footnote(s):

Pension -- includes amounts for defined contribution and benefit plans for apprentices above Period 2. In addition, an amount equal to 3% of the basic hourly rate is added to the total hourly rate and overtime hourly rates for the National Employees Benefit Board. Pursuant to Labor Code Sections 1773.1 and 1773.8 the amount paid for this employer payment may vary resulting in a lower taxable basic hourly wage rate, but the total hourly rates for straight time and overtime may not be less than the general prevailing rate of per diem wages.

Vacation/Holiday included in the Basic Hourly Rate.

Journeyman Predetermined Increases:

- 2/1/16 \$1.00 to be allocated to wages and/or fringes
- 8/1/16 \$1.00 to be allocated to wages and/or fringes
- 1/30/17 \$1.00 to be allocated to wages and/or fringes .
- 7/31/17 \$0.05 to Training, \$0.05 to Other, and \$1.00 to be allocated to wages and/or fringes .
- 1/29/18 \$1.00 to be allocated to wages and/or fringes .
- 7/30/18 \$1.00 to be allocated to wages and/or fringes .
- 1/28/19 \$1.00 to be allocated to wages and/or fringes .

There may be corresponding predetermined increase(s) to the apprentices associated with this journeyman craft/classification. Please fax a request to (415) 703-4771 or send to the following address:

Department of Industrial Relations, Office of the Director - Research Unit
P.O. Box 420603
San Francisco, CA 94142-0603

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** *Issue Date:* **08-22-2015** *Expire Date:* **01-31-2016** ****** *Page:* **3**

Craft/Classification: **Electrician, Inside Wireman** *Shift:* **3**

County: Los Angeles

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1	6		\$21.440	\$10.440	\$.640		\$.710	\$.450	\$33.680
2	6		\$24.130	\$10.440	\$.720		\$.710	\$.450	\$36.450
3	6		\$26.810	\$11.440	\$7.440		\$.710	\$.450	\$46.850
4	6		\$29.490	\$11.440	\$8.180		\$.710	\$.450	\$50.270
5	6		\$32.170	\$11.440	\$8.930		\$.710	\$.450	\$53.700
6	6		\$34.850	\$11.440	\$9.670		\$.710	\$.450	\$57.120
7	6		\$37.530	\$11.440	\$10.410		\$.710	\$.450	\$60.540
8	6		\$40.210	\$11.440	\$11.160		\$.710	\$.450	\$63.970
9	6		\$42.890	\$11.440	\$11.900		\$.710	\$.450	\$67.390
10	6		\$45.570	\$11.440	\$12.650		\$.710	\$.450	\$70.820

Footnote(s):

Pension -- includes amounts for defined contribution and benefit plans for apprentices above Period 2. In addition, an amount equal to 3% of the basic hourly rate is added to the total hourly rate and overtime hourly rates for the National Employees Benefit Board. Pursuant to Labor Code Sections 1773.1 and 1773.8 the amount paid for this employer payment may vary resulting in a lower taxable basic hourly wage rate, but the total hourly rates for straight time and overtime may not be less than the general prevailing rate of per diem wages.

Vacation/Holiday included in the Basic Hourly Rate.

Journeyman Predetermined Increases:

- 2/1/16 \$1.00 to be allocated to wages and/or fringes
- 8/1/16 \$1.00 to be allocated to wages and/or fringes
- 1/30/17 \$1.00 to be allocated to wages and/or fringes .
- 7/31/17 \$0.05 to Training, \$0.05 to Other, and \$1.00 to be allocated to wages and/or fringes .
- 1/29/18 \$1.00 to be allocated to wages and/or fringes .
- 7/30/18 \$1.00 to be allocated to wages and/or fringes .
- 1/28/19 \$1.00 to be allocated to wages and/or fringes .

There may be corresponding predetermined increase(s) to the apprentices associated with this journeyman craft/classification. Please fax a request to (415) 703-4771 or send to the following address:

Department of Industrial Relations, Office of the Director - Research Unit
P.O. Box 420603
San Francisco, CA 94142-0603

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** *Issue Date:* **08-22-2015** *Expire Date:* **06-30-2016** *

Page: **1**

Craft/Classification: **Operating Engineer**

Shift: **1**

Counties: Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, Ventura

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1		1,000	\$25.640	\$11.200		\$3.000	\$.800	\$.290	\$40.930
2		1,000	\$27.770	\$11.200		\$3.000	\$.800	\$.290	\$43.060
3		1,000	\$29.910	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$54.850
4		1,000	\$32.050	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$56.990
5		1,000	\$34.180	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$59.120
6		1,000	\$38.460	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$63.400

Footnote(s):

Operating Engineers Group 13 through 25 apprentice wage rates are based on the applicable journeyman's wage rates for that group.

Vacation & Holiday: Includes an amount for Supplemental Dues.

Other: Includes amounts for Industry Fund, Engineers Contract Compliance Committee (ECCC), and Contract Administration Fund.

Rates above also apply to crafts:

Tunnel Operating Engineer

Crane, Pile Driver, and Hoisting Equipment Operating Engineer

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** *Issue Date:* **08-22-2015** *Expire Date:* **06-30-2016** *

Page: **2**

Craft/Classification: **Operating Engineer**

Shift: **2**

Special Shift

Counties: Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, Ventura

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1		1,000	\$26.140	\$11.200		\$3.000	\$.800	\$.290	\$41.430
2		1,000	\$28.270	\$11.200		\$3.000	\$.800	\$.290	\$43.560
3		1,000	\$30.140	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$55.080
4		1,000	\$32.550	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$57.490
5		1,000	\$34.680	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$59.620
6		1,000	\$38.960	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$63.900

Footnote(s):

Operating Engineers Group 13 through 25 apprentice wage rates are based on the applicable journeyman's wage rates for that group.

Vacation & Holiday: Includes an amount for Supplemental Dues.

Other: Includes amounts for Industry Fund, Engineers Contract Compliance Committee (ECCC), and Contract Administration Fund.

Rates above also apply to crafts:

Tunnel Operating Engineer

Crane, Pile Driver, and Hoisting Equipment Operating Engineer

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

GENERAL PREVAILING WAGE APPRENTICE RATES

APPRENTICE INFORMATION

Determination: **2015-2** *Issue Date:* **08-22-2015** *Expire Date:* **06-30-2016** * *Page:* **3**

Craft/Classification: **Operating Engineer** *Shift:* **3**

Multi-shift

Counties: Imperial, Inyo, Kern, Los Angeles, Mono, Orange, Riverside, San Bernardino, San Luis Obispo, Santa Barbara, Ventura

Period	Duration Months	OJT Hours	Hourly Basic Rate	Health & Welfare	Pension	Vacation /Holiday	Training	Other	Hourly Total Rate
1		1,000	\$26.640	\$11.200		\$3.000	\$.800	\$.290	\$41.930
2		1,000	\$28.770	\$11.200		\$3.000	\$.800	\$.290	\$44.060
3		1,000	\$30.910	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$55.850
4		1,000	\$33.050	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$57.990
5		1,000	\$35.180	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$60.120
6		1,000	\$39.460	\$11.200	\$9.650	\$3.000	\$.800	\$.290	\$64.400

Footnote(s):

Operating Engineers Group 13 through 25 apprentice wage rates are based on the applicable journeyman's wage rates for that group.

Vacation & Holiday: Includes an amount for Supplemental Dues.

Other: Includes amounts for Industry Fund, Engineers Contract Compliance Committee (ECCC), and Contract Administration Fund.

Rates above are for Multi-shift

Rates above also apply to crafts:

Tunnel Operating Engineer

Crane, Pile Driver, and Hoisting Equipment Operating Engineer

Apprentice Prevailing Wage Rates are paid only to apprentices registered with the State of California, Division of Apprenticeship Standards, for work the registered apprentice performs in his/her specific craft or trade. You may check whether an Apprentices is registered at <http://www.dir.ca.gov/DAS/appcertpw/AppCertSearch.asp>

PART G
SPECIFICATIONS

21 September 2015
100% Submittal

ELECTRICAL RENOVATIONS, WILSON PARK

SPECIFICATIONS

Prepared for:

CITY OF TORRANCE
General Services Division
3350 Civic Center Drive
Torrance, California 90503



Prepared by:

J.C. CHANG & ASSOCIATES, INC.
Engineers ■ Architects ■ Planners
385 Van Ness Avenue, Suite 208
Torrance, California 90501
Telephone: (310) 212-7644
www.jccainc.com
JCCA 15580-1

SECTION 00 01 10 - TABLE OF CONTENTS

DIVISION 26 - ELECTRICAL

26 05 00	Common Work Results for Electrical
26 05 19	Low-Voltage Electrical Power Conductors and Cables
26 05 26	Grounding and Bonding for Electrical Systems
26 05 29	Hangers and Supports for Electrical Systems
26 05 33	Raceways and Boxes for Electrical Systems
26 05 53	Identification for Electrical Systems
26 56 19	LED Exterior Lighting

END OF SECTION 000110

SECTION 260500 - COMMON WORK RESULTS FOR ELECTRICAL

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Electrical equipment coordination and installation.
 - 2. Sleeves for raceways and cables.
 - 3. Sleeve seals.
 - 4. Grout.
 - 5. Common electrical installation requirements.

1.3 DEFINITIONS

- A. EPDM: Ethylene-propylene-diene terpolymer rubber.
- B. NBR: Acrylonitrile-butadiene rubber.

1.4 SUBMITTALS

- A. Product Data: For sleeve seals.

1.5 COORDINATION

- A. Coordinate arrangement, mounting, and support of electrical equipment:
 - 1. To allow maximum possible headroom unless specific mounting heights that reduce headroom are indicated.
 - 2. To provide for ease of disconnecting the equipment with minimum interference to other installations.
 - 3. To allow right of way for piping and conduit installed at required slope.
 - 4. So connecting raceways, cables, wireways, cable trays, and busways will be clear of obstructions and of the working and access space of other equipment.
- B. Coordinate installation of required supporting devices and set sleeves in cast-in-place concrete, masonry walls, and other structural components as they are constructed.

- C. Coordinate location of access panels and doors for electrical items that are behind finished surfaces or otherwise concealed. Access doors and panels are specified in Division 08 Section "Access Doors and Frames."
- D. Coordinate sleeve selection and application with selection and application of firestopping specified in Division 07 Section "Penetration Firestopping."

PART 2 - PRODUCTS

2.1 SLEEVES FOR RACEWAYS AND CABLES

- A. Steel Pipe Sleeves: ASTM A 53/A 53M, Type E, Grade B, Schedule 40, galvanized steel, plain ends.
- B. Cast-Iron Pipe Sleeves: Cast or fabricated "wall pipe," equivalent to ductile-iron pressure pipe, with plain ends and integral waterstop, unless otherwise indicated.
- C. Sleeves for Rectangular Openings: Galvanized sheet steel.
 - 1. Minimum Metal Thickness:
 - a. For sleeve cross-section rectangle perimeter less than 50 inches (1270 mm) and no side more than 16 inches (400 mm), thickness shall be 0.052 inch (1.3 mm).
 - b. For sleeve cross-section rectangle perimeter equal to, or more than, 50 inches (1270 mm) and 1 or more sides equal to, or more than, 16 inches (400 mm), thickness shall be 0.138 inch (3.5 mm).

2.2 SLEEVE SEALS

- A. Description: Modular sealing device, designed for field assembly, to fill annular space between sleeve and raceway or cable.
 - 1. Basis-of-Design Product: Subject to compliance with requirements, provide product indicated on Drawings or comparable product by one of the following:
 - a. Advance Products & Systems, Inc.
 - b. Calpico, Inc.
 - c. Metraflex Co.
 - d. Pipeline Seal and Insulator, Inc.
 - e. Or approved equal
 - 2. Sealing Elements: NBR interlocking links shaped to fit surface of cable or conduit. Include type and number required for material and size of raceway or cable.
 - 3. Pressure Plates: Carbon steel. Include two for each sealing element.
 - 4. Connecting Bolts and Nuts: Carbon steel with corrosion-resistant coating of length required to secure pressure plates to sealing elements. Include one for each sealing element.

2.3 GROUT

- A. Nonmetallic, Shrinkage-Resistant Grout: ASTM C 1107, factory-packaged, nonmetallic aggregate grout, noncorrosive, nonstaining, mixed with water to consistency suitable for application and a 30-minute working time.

PART 3 - EXECUTION

3.1 COMMON REQUIREMENTS FOR ELECTRICAL INSTALLATION

- A. Comply with NECA 1.
- B. Measure indicated mounting heights to bottom of unit for suspended items and to center of unit for wall-mounting items.
- C. Headroom Maintenance: If mounting heights or other location criteria are not indicated, arrange and install components and equipment to provide maximum possible headroom consistent with these requirements.
- D. Equipment: Install to facilitate service, maintenance, and repair or replacement of components of both electrical equipment and other nearby installations. Connect in such a way as to facilitate future disconnecting with minimum interference with other items in the vicinity.
- E. Right of Way: Give to piping systems installed at a required slope.

3.2 SLEEVE INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Electrical penetrations occur when raceways, cables, wireways, cable trays, or busways penetrate concrete slabs, concrete or masonry walls, or fire-rated floor and wall assemblies.
- B. Concrete Slabs and Walls: Install sleeves for penetrations unless core-drilled holes or formed openings are used. Install sleeves during erection of slabs and walls.
- C. Use pipe sleeves unless penetration arrangement requires rectangular sleeved opening.
- D. Fire-Rated Assemblies: Install sleeves for penetrations of fire-rated floor and wall assemblies unless openings compatible with firestop system used are fabricated during construction of floor or wall.
- E. Cut sleeves to length for mounting flush with both surfaces of walls.
- F. Extend sleeves installed in floors 2 inches (50 mm) above finished floor level.
- G. Size pipe sleeves to provide 1/4-inch (6.4-mm) annular clear space between sleeve and raceway or cable, unless indicated otherwise.
- H. Seal space outside of sleeves with grout for penetrations of concrete and masonry

1. Promptly pack grout solidly between sleeve and wall so no voids remain. Tool exposed surfaces smooth; protect grout while curing.
- I. Interior Penetrations of Non-Fire-Rated Walls and Floors: Seal annular space between sleeve and raceway or cable, using joint sealant appropriate for size, depth, and location of joint. Comply with requirements in Division 07 Section "Joint Sealants."
- J. Fire-Rated-Assembly Penetrations: Maintain indicated fire rating of walls, partitions, ceilings, and floors at raceway and cable penetrations. Install sleeves and seal raceway and cable penetration sleeves with firestop materials. Comply with requirements in Division 07 Section "Penetration Firestopping."
- K. Roof-Penetration Sleeves: Seal penetration of individual raceways and cables with flexible boot-type flashing units applied in coordination with roofing work.
- L. Aboveground, Exterior-Wall Penetrations: Seal penetrations using steel pipe sleeves and mechanical sleeve seals. Select sleeve size to allow for 1-inch (25-mm) annular clear space between pipe and sleeve for installing mechanical sleeve seals.
- M. Underground, Exterior-Wall Penetrations: Install cast-iron pipe sleeves. Size sleeves to allow for 1-inch (25-mm) annular clear space between raceway or cable and sleeve for installing mechanical sleeve seals.

3.3 SLEEVE-SEAL INSTALLATION

- A. Install to seal exterior wall penetrations.
- B. Use type and number of sealing elements recommended by manufacturer for raceway or cable material and size. Position raceway or cable in center of sleeve. Assemble mechanical sleeve seals and install in annular space between raceway or cable and sleeve. Tighten bolts against pressure plates that cause sealing elements to expand and make watertight seal.

3.4 FIRESTOPPING

- A. Apply firestopping to penetrations of fire-rated floor and wall assemblies for electrical installations to restore original fire-resistance rating of assembly. Firestopping materials and installation requirements are specified in Division 07 Section "Penetration Firestopping."

END OF SECTION 260500

SECTION 260519 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Building wires and cables rated 600 V and less.
 - 2. Connectors, splices, and terminations rated 600 V and less.

1.3 DEFINITIONS

- A. VFC: Variable frequency controller.

1.4 ACTION SUBMITTALS

- A. Product Data: For each type of product.

1.5 INFORMATIONAL SUBMITTALS

- A. Qualification Data: For testing agency.
- B. Field quality-control reports.

1.6 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Member company of NETA or an NRTL.
 - 1. Testing Agency's Field Supervisor: Certified by NETA to supervise on-site testing.

PART 2 - PRODUCTS

2.1 CONDUCTORS AND CABLES

- A. Copper Conductors: Comply with NEMA WC 70/ICEA S-95-658.

- B. Conductor Insulation: Comply with NEMA WC 70/ICEA S-95-658 for Type THHN/THWN-2

2.2 CONNECTORS AND SPLICES

- A. Description: Factory-fabricated connectors and splices of size, ampacity rating, material, type, and class for application and service indicated.

2.3 SYSTEM DESCRIPTION

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with NFPA 70.

PART 3 - EXECUTION

3.1 CONDUCTOR MATERIAL APPLICATIONS

- A. Feeders: Copper. Solid for No. 10 AWG and smaller; stranded for No. 8 AWG and larger.
- B. Branch Circuits: Copper. Solid for No. 12 AWG and smaller; stranded for No. 10 AWG and larger, except VFC cable, which shall be extra flexible stranded.

3.2 CONDUCTOR INSULATION AND MULTICONDUCTOR CABLE APPLICATIONS AND WIRING METHODS

- A. Feeders Concealed in Ceilings, Walls, Partitions, and Crawlspace: Type THHN/THWN-2, single conductors in raceway.
- B. Feeders Concealed in Concrete, below Slabs-on-Grade, and Underground: Type THHN/THWN-2, single conductors in raceway.
- C. Feeders Installed below Raised Flooring: Type THHN/THWN-2, single conductors in raceway.
- D. Feeders in Cable Tray: Type THHN/THWN-2, single conductors in raceway.
- E. Branch Circuits Concealed in Ceilings, Walls, and Partitions: Type THHN/THWN-2, single conductors in raceway.
- F. Branch Circuits Concealed in Concrete, below Slabs-on-Grade, and Underground: Type THHN/THWN-2, single conductors in raceway.
- G. Branch Circuits Installed below Raised Flooring: Type THHN/THWN-2, single conductors in raceway.
- H. Branch Circuits in Cable Tray: Type THHN/THWN-2, single conductors in raceway.

3.3 INSTALLATION OF CONDUCTORS AND CABLES

- A. Conceal cables in finished walls, ceilings, and floors unless otherwise indicated.
- B. Complete raceway installation between conductor and cable termination points according to Section 260533 "Raceways and Boxes for Electrical Systems" prior to pulling conductors and cables.
- C. Use manufacturer-approved pulling compound or lubricant where necessary; compound used must not deteriorate conductor or insulation. Do not exceed manufacturer's recommended maximum pulling tensions and sidewall pressure values.
- D. Use pulling means, including fish tape, cable, rope, and basket-weave wire/cable grips, that will not damage cables or raceway.
- E. Install exposed cables parallel and perpendicular to surfaces of exposed structural members, and follow surface contours where possible.
- F. Support cables according to Section 260529 "Hangers and Supports for Electrical Systems."
- G. Complete cable tray systems installation according to Section 260536 "Cable Trays for Electrical Systems" prior to installing conductors and cables.

3.4 CONNECTIONS

- A. Tighten electrical connectors and terminals according to manufacturer's published torque-tightening values. If manufacturer's torque values are not indicated, use those specified in UL 486A-486B.
- B. Make splices, terminations, and taps that are compatible with conductor material and that possess equivalent or better mechanical strength and insulation ratings than unspliced conductors.
 - 1. Use oxide inhibitor in each splice, termination, and tap for aluminum conductors.

3.5 IDENTIFICATION

- A. Identify and color-code conductors and cables according to Section 260553 "Identification for Electrical Systems."
- B. Identify each spare conductor at each end with identity number and location of other end of conductor, and identify as spare conductor.

3.6 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."

3.7 FIRESTOPPING

- A. Apply firestopping to electrical penetrations of fire-rated floor and wall assemblies to restore original fire-resistance rating of assembly according to Section 078413 "Penetration Firestopping."

3.8 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to test and inspect components, assemblies, and equipment installations, including connections.
- C. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
 - 1. After installing conductors and cables and before electrical circuitry has been energized, test conductors feeding the following critical equipment and services for compliance with requirements.
 - a. All new fixtures installed within the scope of project.
 - 2. Perform each visual and mechanical inspection and electrical test stated in NETA Acceptance Testing Specification. Certify compliance with test parameters.
 - 3. Infrared Scanning: After Substantial Completion, but not more than 60 days after Final Acceptance, perform an infrared scan of each splice in conductors No. 3 AWG and larger. Remove box and equipment covers so splices are accessible to portable scanner. Correct deficiencies determined during the scan.
 - a. Follow-up Infrared Scanning: Perform an additional follow-up infrared scan of each splice 11 months after date of Substantial Completion.
 - b. Instrument: Use an infrared scanning device designed to measure temperature or to detect significant deviations from normal values. Provide calibration record for device.
 - c. Record of Infrared Scanning: Prepare a certified report that identifies splices checked and that describes scanning results. Include notation of deficiencies detected, remedial action taken, and observations after remedial action.
- D. Test and Inspection Reports: Prepare a written report to record the following:
 - 1. Procedures used.
 - 2. Results that comply with requirements.
 - 3. Results that do not comply with requirements and corrective action taken to achieve compliance with requirements.
- E. Cables will be considered defective if they do not pass tests and inspections.

END OF SECTION 260519

SECTION 260526 - GROUNDING AND BONDING FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section includes grounding and bonding systems and equipment.
- B. Section includes grounding and bonding systems and equipment, plus the following special applications:
 - 1. Underground distribution grounding.
 - 2. Ground bonding common with lightning protection system.
 - 3. Foundation steel electrodes.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product indicated.

1.4 INFORMATIONAL SUBMITTALS

- A. As-Built Data: Plans showing dimensioned as-built locations of grounding features specified in "Field Quality Control" Article, including the following:
 - 1. Test wells.
 - 2. Ground rods.
 - 3. Ground rings.
 - 4. Grounding arrangements and connections for separately derived systems.
- B. Qualification Data: For testing agency and testing agency's field supervisor.
- C. Field quality-control reports.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For grounding to include in emergency, operation, and maintenance manuals.

1.6 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Member company of NETA or an NRTL.
 - 1. Testing Agency's Field Supervisor: Certified by NETA to supervise on-site testing.
- B. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- C. Comply with UL 467 for grounding and bonding materials and equipment.

PART 2 - PRODUCTS

2.1 SYSTEM DESCRIPTION

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Comply with UL 467 for grounding and bonding materials and equipment.

2.2 CONDUCTORS

- A. Insulated Conductors: Copper wire or cable insulated for 600 V unless otherwise required by applicable Code or authorities having jurisdiction.
- B. Bare Copper Conductors:
 - 1. Solid Conductors: ASTM B 3.
 - 2. Stranded Conductors: ASTM B 8.
 - 3. Tinned Conductors: ASTM B 33.
 - 4. Bonding Cable: 28 kcmil, 14 strands of No. 17 AWG conductor, 1/4 inch (6 mm) in diameter.
 - 5. Bonding Conductor: No. 4 or No. 6 AWG, stranded conductor.
 - 6. Bonding Jumper: Copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches (41 mm) wide and 1/16 inch (1.6 mm) thick.
 - 7. Tinned Bonding Jumper: Tinned-copper tape, braided conductors terminated with copper ferrules; 1-5/8 inches (41 mm) wide and 1/16 inch (1.6 mm) thick.

2.3 CONNECTORS

- A. Listed and labeled by an NRTL acceptable to authorities having jurisdiction for applications in which used and for specific types, sizes, and combinations of conductors and other items connected.
- B. Bolted Connectors for Conductors and Pipes: Copper or copper alloy.

- C. Welded Connectors: Exothermic-welding kits of types recommended by kit manufacturer for materials being joined and installation conditions.
- D. Bus-Bar Connectors: Mechanical type, cast silicon bronze, solderless compression-type wire terminals, and long-barrel, two-bolt connection to ground bus bar.

PART 3 - EXECUTION

3.1 APPLICATIONS

- A. Conductors: Install solid conductor for No. 8 AWG and smaller, and stranded conductors for No. 6 AWG and larger unless otherwise indicated.
- B. Underground Grounding Conductors: Install bare copper conductor, No. 2/0 AWG minimum.
 - 1. Bury at least 24 inches (600 mm) below grade.
 - 2. Duct-Bank Grounding Conductor: Bury 12 inches (300 mm) above duct bank when indicated as part of duct-bank installation.
- C. Isolated Grounding Conductors: Green-colored insulation with continuous yellow stripe. On feeders with isolated ground, identify grounding conductor where visible to normal inspection, with alternating bands of green and yellow tape, with at least three bands of green and two bands of yellow.
- D. Grounding Bus: Install in electrical equipment rooms, in rooms housing service equipment, and elsewhere as indicated.
 - 1. Install bus horizontally, on insulated spacers 2 inches (50 mm) minimum from wall, 6 inches (150 mm) above finished floor unless otherwise indicated.
 - 2. Where indicated on both sides of doorways, route bus up to top of door frame, across top of doorway, and down; connect to horizontal bus.
- E. Conductor Terminations and Connections:
 - 1. Pipe and Equipment Grounding Conductor Terminations: Bolted connectors.
 - 2. Underground Connections: Welded connectors except at test wells and as otherwise indicated.
 - 3. Connections to Ground Rods at Test Wells: Bolted connectors.
 - 4. Connections to Structural Steel: Welded connectors.

3.2 GROUNDING AT THE SERVICE

- A. Equipment grounding conductors and grounding electrode conductors shall be connected to the ground bus. Install a main bonding jumper between the neutral and ground buses.

3.3 GROUNDING SEPARATELY DERIVED SYSTEMS

- A. Generator: Install grounding electrode(s) at the generator location. The electrode shall be connected to the equipment grounding conductor and to the frame of the generator.

3.4 GROUNDING UNDERGROUND DISTRIBUTION SYSTEM COMPONENTS

- A. Comply with IEEE C2 grounding requirements.
- B. Grounding Manholes and Handholes: Install a driven ground rod through manhole or handhole floor, close to wall, and set rod depth so 4 inches (100 mm) will extend above finished floor. If necessary, install ground rod before manhole is placed and provide No. 1/0 AWG bare, tinned-copper conductor from ground rod into manhole through a waterproof sleeve in manhole wall. Protect ground rods passing through concrete floor with a double wrapping of pressure-sensitive insulating tape or heat-shrunk insulating sleeve from 2 inches (50 mm) above to 6 inches (150 mm) below concrete. Seal floor opening with waterproof, nonshrink grout.
- C. Grounding Connections to Manhole Components: Bond exposed-metal parts such as inserts, cable racks, pulling irons, ladders, and cable shields within each manhole or handhole, to ground rod or grounding conductor. Make connections with No. 4 AWG minimum, stranded, hard-drawn copper bonding conductor. Train conductors level or plumb around corners and fasten to manhole walls. Connect to cable armor and cable shields according to written instructions by manufacturer of splicing and termination kits.
- D. Pad-Mounted Transformers and Switches: Install two ground rods and ground ring around the pad. Ground pad-mounted equipment and noncurrent-carrying metal items associated with substations by connecting them to underground cable and grounding electrodes. Install tinned-copper conductor not less than No. 2 AWG for ground ring and for taps to equipment grounding terminals. Bury ground ring not less than 6 inches (150 mm) from the foundation.

3.5 EQUIPMENT GROUNDING

- A. Install insulated equipment grounding conductors with all feeders and branch circuits.
- B. Install insulated equipment grounding conductors with the following items, in addition to those required by NFPA 70:
 - 1. Feeders and branch circuits.
 - 2. Lighting circuits.
 - 3. Receptacle circuits.
 - 4. Single-phase motor and appliance branch circuits.
 - 5. Three-phase motor and appliance branch circuits.
 - 6. Flexible raceway runs.
 - 7. Armored and metal-clad cable runs.
 - 8. Busway Supply Circuits: Install insulated equipment grounding conductor from grounding bus in the switchgear, switchboard, or distribution panel to equipment grounding bar terminal on busway.

9. X-Ray Equipment Circuits: Install insulated equipment grounding conductor in circuits supplying x-ray equipment.
- C. Air-Duct Equipment Circuits: Install insulated equipment grounding conductor to duct-mounted electrical devices operating at 120 V and more, including air cleaners, heaters, dampers, humidifiers, and other duct electrical equipment. Bond conductor to each unit and to air duct and connected metallic piping.
- D. Water Heater, Heat-Tracing, and Antifrost Heating Cables: Install a separate insulated equipment grounding conductor to each electric water heater and heat-tracing cable. Bond conductor to heater units, piping, connected equipment, and components.
- E. Isolated Grounding Receptacle Circuits: Install an insulated equipment grounding conductor connected to the receptacle grounding terminal. Isolate conductor from raceway and from panelboard grounding terminals. Terminate at equipment grounding conductor terminal of the applicable derived system or service unless otherwise indicated.
- F. Isolated Equipment Enclosure Circuits: For designated equipment supplied by a branch circuit or feeder, isolate equipment enclosure from supply circuit raceway with a nonmetallic raceway fitting listed for the purpose. Install fitting where raceway enters enclosure, and install a separate insulated equipment grounding conductor. Isolate conductor from raceway and from panelboard grounding terminals. Terminate at equipment grounding conductor terminal of the applicable derived system or service unless otherwise indicated.
- G. Poles Supporting Outdoor Lighting Fixtures: Install grounding electrode and a separate insulated equipment grounding conductor in addition to grounding conductor installed with branch-circuit conductors.
- H. Metallic Fences: Comply with requirements of IEEE C2.
 1. Grounding Conductor: Bare copper, not less than No. 8 AWG.
 2. Gates: Shall be bonded to the grounding conductor with a flexible bonding jumper.
 3. Barbed Wire: Strands shall be bonded to the grounding conductor.

3.6 INSTALLATION

- A. Grounding Conductors: Route along shortest and straightest paths possible unless otherwise indicated or required by Code. Avoid obstructing access or placing conductors where they may be subjected to strain, impact, or damage.
- B. Ground Bonding Common with Lightning Protection System: Comply with NFPA 780 and UL 96 when interconnecting with lightning protection system. Bond electrical power system ground directly to lightning protection system grounding conductor at closest point to electrical service grounding electrode. Use bonding conductor sized same as system grounding electrode conductor, and install in conduit.
- C. Test Wells: Ground rod driven through drilled hole in bottom of handhole. Handholes are specified in Section 260543 "Underground Ducts and Raceways for Electrical Systems," and shall be at least 12 inches (300 mm) deep, with cover.

1. Test Wells: Install at least one test well for each service unless otherwise indicated. Install at the ground rod electrically closest to service entrance. Set top of test well flush with finished grade or floor.
- D. Bonding Straps and Jumpers: Install in locations accessible for inspection and maintenance except where routed through short lengths of conduit.
1. Bonding to Structure: Bond straps directly to basic structure, taking care not to penetrate any adjacent parts.
 2. Bonding to Equipment Mounted on Vibration Isolation Hangers and Supports: Install bonding so vibration is not transmitted to rigidly mounted equipment.
 3. Use exothermic-welded connectors for outdoor locations; if a disconnect-type connection is required, use a bolted clamp.
- E. Grounding and Bonding for Piping:
1. Metal Water Service Pipe: Install insulated copper grounding conductors, in conduit, from building's main service equipment, or grounding bus, to main metal water service entrances to building. Connect grounding conductors to main metal water service pipes; use a bolted clamp connector or bolt a lug-type connector to a pipe flange by using one of the lug bolts of the flange. Where a dielectric main water fitting is installed, connect grounding conductor on street side of fitting. Bond metal grounding conductor conduit or sleeve to conductor at each end.
 2. Water Meter Piping: Use braided-type bonding jumpers to electrically bypass water meters. Connect to pipe with a bolted connector.
 3. Bond each aboveground portion of gas piping system downstream from equipment shutoff valve.

3.7 FIELD QUALITY CONTROL

- A. Testing Agency: Engage a qualified testing agency to perform tests and inspections.
- B. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust components, assemblies, and equipment installations, including connections.
- C. Perform tests and inspections.
1. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect components, assemblies, and equipment installations, including connections, and to assist in testing.
- D. Tests and Inspections:
1. After installing grounding system but before permanent electrical circuits have been energized, test for compliance with requirements.
 2. Inspect physical and mechanical condition. Verify tightness of accessible, bolted, electrical connections with a calibrated torque wrench according to manufacturer's written instructions.

3. Test completed grounding system at each location where a maximum ground-resistance level is specified, at service disconnect enclosure grounding terminal at ground test wells and at individual ground rods. Make tests at ground rods before any conductors are connected.
 - a. Measure ground resistance no fewer than two full days after last trace of precipitation and without soil being moistened by any means other than natural drainage or seepage and without chemical treatment or other artificial means of reducing natural ground resistance.
 - b. Perform tests by fall-of-potential method according to IEEE 81.
 4. Prepare dimensioned Drawings locating each test well, ground rod and ground-rod assembly, and other grounding electrodes. Identify each by letter in alphabetical order, and key to the record of tests and observations. Include the number of rods driven and their depth at each location, and include observations of weather and other phenomena that may affect test results. Describe measures taken to improve test results.
- E. Grounding system will be considered defective if it does not pass tests and inspections.
- F. Prepare test and inspection reports.
- G. Report measured ground resistances that exceed the following values:
1. Power and Lighting Equipment or System with Capacity of 500 kVA and Less: 10 ohms.
 2. Manhole Grounds: 10 ohms.
- H. Excessive Ground Resistance: If resistance to ground exceeds specified values, notify Architect promptly and include recommendations to reduce ground resistance.

END OF SECTION 260526

THIS PAGE IS INTENTIONALLY LEFT BLANK

SECTION 260529 - HANGERS AND SUPPORTS FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

- 1. Hangers and supports for electrical equipment and systems.
 - 2. Construction requirements for concrete bases.

- B. Related Requirements:

- 1. Section 260548.16 "Seismic Controls for Electrical Systems" for products and installation requirements necessary for compliance with seismic criteria.

1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.

- 1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for the following:

- a. Hangers.
 - b. Steel slotted support systems.
 - c. Nonmetallic support systems.
 - d. Trapeze hangers.
 - e. Clamps.
 - f. Turnbuckles.
 - g. Sockets.
 - h. Eye nuts.
 - i. Saddles.
 - j. Brackets.
 - k. Or approved equal.

- 2. Include rated capacities and furnished specialties and accessories.

- B. Shop Drawings: Signed and sealed by a qualified professional engineer. For fabrication and installation details for electrical hangers and support systems.

- 1. Trapeze hangers. Include product data for components.

2. Steel slotted-channel systems.
 3. Nonmetallic slotted-channel systems.
 4. Equipment supports.
 5. Vibration Isolation Base Details: Detail fabrication, including anchorages and attachments to structure and to supported equipment. Include adjustable motor bases, rails, and frames for equipment mounting.
- C. Delegated-Design Submittal: For hangers and supports for electrical systems.
1. Include design calculations and details of trapeze hangers.
 2. Include design calculations for seismic restraints.

1.4 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Reflected ceiling plan(s) and other details, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
1. Suspended ceiling components.
 2. Structural members to which hangers and supports will be attached.
 3. Size and location of initial access modules for acoustical tile.
 4. Items penetrating finished ceiling, including the following:
 - a. Lighting fixtures.
 - b. Air outlets and inlets.
 - c. Speakers.
 - d. Sprinklers.
 - e. Access panels.
 - f. Projectors.
 - g. Or approved equal.
- B. Seismic Qualification Certificates: For hangers and supports for electrical equipment and systems, accessories, and components, from manufacturer.
1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- C. Welding certificates.

1.5 QUALITY ASSURANCE

- A. Welding Qualifications: Qualify procedures and personnel according to AWS D1.2/D1.2M.

- B. Welding Qualifications: Qualify procedures and personnel according to the following:
 - 1. AWS D1.1/D1.1M.
 - 2. AWS D1.2/D1.2M.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Delegated Design: Engage a qualified professional engineer, as defined in Section 014000 "Quality Requirements," to design hanger and support system.
- B. Seismic Performance: Hangers and supports shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.
 - 1. The term "withstand" means "the supported equipment and systems will remain in place without separation of any parts when subjected to the seismic forces specified and the system will be fully operational after the seismic event."
 - 2. Component Importance Factor: 1.5.
- C. Surface-Burning Characteristics: Comply with ASTM E 84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - 1. Flame Rating: Class 1.
 - 2. Self-extinguishing according to ASTM D 635.

2.2 SUPPORT, ANCHORAGE, AND ATTACHMENT COMPONENTS

- A. Steel Slotted Support Systems: Comply with MFMA-4 factory-fabricated components for field assembly
 - 1. Material: Galvanized steel.
 - 2. Channel Width: 1-5/8 inches (41.25 mm).
 - 3. Metallic Coatings: Hot-dip galvanized after fabrication and applied according to MFMA-4.
 - 4. Nonmetallic Coatings: Manufacturer's standard PVC, polyurethane, or polyester coating applied according to MFMA-4.
 - 5. Painted Coatings: Manufacturer's standard painted coating applied according to MFMA-4.
 - 6. Protect finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
 - 7. Channel Dimensions: Selected for applicable load criteria.
- B. Aluminum Slotted Support Systems: Comply with MFMA-4 factory-fabricated components for field assembly.
 - 1. Channel Width: 1-5/8 inches (41.25 mm).

2. Nonmetallic Coatings: Manufacturer's standard PVC, polyurethane, or polyester coating applied according to MFMA-4.
 3. Painted Coatings: Manufacturer's standard painted coating applied according to MFMA-4.
 4. Protect finishes on exposed surfaces from damage by applying a strippable, temporary protective covering before shipping.
 5. Channel Dimensions: Selected for applicable load criteria.
- C. Conduit and Cable Support Devices: Steel hangers, clamps, and associated fittings, designed for types and sizes of raceway or cable to be supported.
- D. Support for Conductors in Vertical Conduit: Factory-fabricated assembly consisting of threaded body and insulating wedging plug or plugs for nonarmored electrical conductors or cables in riser conduits. Plugs shall have number, size, and shape of conductor gripping pieces as required to suit individual conductors or cables supported. Body shall be made of malleable iron.
- E. Structural Steel for Fabricated Supports and Restraints: ASTM A 36/A 36M steel plates, shapes, and bars; black and galvanized.
- F. Mounting, Anchoring, and Attachment Components: Items for fastening electrical items or their supports to building surfaces include the following:
1. Powder-Actuated Fasteners: Threaded-steel stud, for use in hardened portland cement concrete, steel, or wood, with tension, shear, and pullout capacities appropriate for supported loads and building materials where used.
 2. Mechanical-Expansion Anchors: Insert-wedge-type, zinc-coated steel, for use in hardened portland cement concrete, with tension, shear, and pullout capacities appropriate for supported loads and building materials where used.
 3. Concrete Inserts: Steel or malleable-iron, slotted support system units are similar to MSS Type 18 units and comply with MFMA-4 or MSS SP-58.
 4. Clamps for Attachment to Steel Structural Elements: MSS SP-58 units are suitable for attached structural element.
 5. Through Bolts: Structural type, hex head, and high strength. Comply with ASTM A 325.
 6. Toggle Bolts: All-steel springhead type.
 7. Hanger Rods: Threaded steel.

2.3 FABRICATED METAL EQUIPMENT SUPPORT ASSEMBLIES

- A. Description: Welded or bolted structural-steel shapes, shop or field fabricated to fit dimensions of supported equipment.
- B. Materials: Comply with requirements in Section 055000 "Metal Fabrications" for steel shapes and plates.

PART 3 - EXECUTION

3.1 APPLICATION

- A. Comply with NECA 1 and NECA 101 for application of hangers and supports for electrical equipment and systems unless requirements in this Section are stricter.
- B. Comply with requirements for raceways and boxes specified in Section 260533 "Raceways and Boxes for Electrical Systems."
- C. Maximum Support Spacing and Minimum Hanger Rod Size for Raceway: Space supports for EMTs, IMCs, and RMCs as scheduled in NECA 1, where its Table 1 lists maximum spacings that are less than those stated in NFPA 70. Minimum rod size shall be 1/4 inch (6 mm) in diameter.
- D. Multiple Raceways or Cables: Install trapeze-type supports fabricated with steel slotted support system, sized so capacity can be increased by at least 25 percent in future without exceeding specified design load limits.
 - 1. Secure raceways and cables to these supports with two-bolt conduit clamps.
- E. Spring-steel clamps designed for supporting single conduits without bolts may be used for 1-1/2-inch (38-mm) and smaller raceways serving branch circuits and communication systems above suspended ceilings and for fastening raceways to trapeze supports.

3.2 SUPPORT INSTALLATION

- A. Comply with NECA 1 and NECA 101 for installation requirements except as specified in this article.
- B. Raceway Support Methods: In addition to methods described in NECA 1, EMTs, IMCs, and RMCs may be supported by openings through structure members, according to NFPA 70.
- C. Strength of Support Assemblies: Where not indicated, select sizes of components so strength will be adequate to carry present and future static loads within specified loading limits. Minimum static design load used for strength determination shall be weight of supported components plus 200 lb (90 kg).
- D. Mounting and Anchorage of Surface-Mounted Equipment and Components: Anchor and fasten electrical items and their supports to building structural elements by the following methods unless otherwise indicated by code:
 - 1. To Wood: Fasten with lag screws or through bolts.
 - 2. To New Concrete: Bolt to concrete inserts.
 - 3. To Masonry: Approved toggle-type bolts on hollow masonry units and expansion anchor fasteners on solid masonry units.
 - 4. To Existing Concrete: Expansion anchor fasteners.

5. Instead of expansion anchors, powder-actuated driven threaded studs provided with lock washers and nuts may be used in existing standard-weight concrete 4 inches (100 mm) thick or greater. Do not use for anchorage to lightweight-aggregate concrete or for slabs less than 4 inches (100 mm) thick.
 6. To Steel: Welded threaded studs complying with AWS D1.1/D1.1M, with lock washers and nuts.
 7. To Light Steel: Sheet metal screws.
 8. Items Mounted on Hollow Walls and Nonstructural Building Surfaces: Mount cabinets, panelboards, disconnect switches, control enclosures, pull and junction boxes, transformers, and other devices on slotted-channel racks attached to substrate by means that comply with seismic-restraint strength and anchorage requirements.
- E. Drill holes for expansion anchors in concrete at locations and to depths that avoid the need for reinforcing bars.

3.3 INSTALLATION OF FABRICATED METAL SUPPORTS

- A. Comply with installation requirements in Section 055000 "Metal Fabrications" for site-fabricated metal supports.
- B. Cut, fit, and place miscellaneous metal supports accurately in location, alignment, and elevation to support and anchor electrical materials and equipment.
- C. Field Welding: Comply with AWS D1.1/D1.1M.

3.4 PAINTING

- A. Touchup: Clean field welds and abraded areas of shop paint. Paint exposed areas immediately after erecting hangers and supports. Use same materials as used for shop painting. Comply with SSPC-PA 1 requirements for touching up field-painted surfaces.
 1. Apply paint by brush or spray to provide minimum dry film thickness of 2.0 mils (0.05 mm).
- B. Touchup: Provide cleaning and touchup painting of field welds, bolted connections, and abraded areas of shop paint on miscellaneous metal.
- C. Galvanized Surfaces: Clean welds, bolted connections, and abraded areas and apply galvanizing-repair paint to comply with ASTM A 780.

END OF SECTION 260529

SECTION 260533 - RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:

1. Metal conduits, tubing, and fittings.
2. Nonmetal conduits, tubing, and fittings.
3. Metal wireways and auxiliary gutters.
4. Nonmetal wireways and auxiliary gutters.
5. Surface raceways.
6. Boxes, enclosures, and cabinets.
7. Handholes and boxes for exterior underground cabling.

1.3 DEFINITIONS

- A. ARC: Aluminum rigid conduit.
- B. GRC: Galvanized rigid steel conduit.
- C. IMC: Intermediate metal conduit.

1.4 ACTION SUBMITTALS

- A. Product Data: For surface raceways, wireways and fittings, floor boxes, hinged-cover enclosures, and cabinets.
- B. LEED Submittals:
 1. Product Data for Credit IEQ 4.1: For solvent cements and adhesive primers, documentation including printed statement of VOC content.
 2. Laboratory Test Reports for Credit IEQ 4: For solvent cements and adhesive primers, documentation indicating that products comply with the testing and product requirements of the California Department of Health Services' "Standard Practice for the Testing of Volatile Organic Emissions from Various Sources Using Small-Scale Environmental Chambers."

- C. Shop Drawings: For custom enclosures and cabinets. Include plans, elevations, sections, and attachment details.
- D. Samples: For wireways and surface raceways and for each color and texture specified, 12 inches (300 mm) long.

1.5 INFORMATIONAL SUBMITTALS

- A. Coordination Drawings: Conduit routing plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of items involved:
 - 1. Structural members in paths of conduit groups with common supports.
 - 2. HVAC and plumbing items and architectural features in paths of conduit groups with common supports.
- B. Qualification Data: For professional engineer.
- C. Seismic Qualification Certificates: For enclosures, cabinets, and conduit racks and their mounting provisions, including those for internal components, from manufacturer.
 - 1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
 - 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
 - 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
 - 4. Detailed description of conduit support devices and interconnections on which the certification is based and their installation requirements.
- D. Source quality-control reports.

PART 2 - PRODUCTS

2.1 METAL CONDUITS, TUBING, AND FITTINGS

- A. Listing and Labeling: Metal conduits, tubing, and fittings shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. GRC: Comply with ANSI C80.1 and UL 6.
- C. ARC: Comply with ANSI C80.5 and UL 6A.
- D. IMC: Comply with ANSI C80.6 and UL 1242.
- E. PVC-Coated Steel Conduit: PVC-coated rigid steel conduit.
 - 1. Comply with NEMA RN 1.
 - 2. Coating Thickness: 0.040 inch (1 mm), minimum.

- F. EMT: Comply with ANSI C80.3 and UL 797.
- G. FMC: Comply with UL 1; zinc-coated steel.
- H. LFMC: Flexible steel conduit with PVC jacket and complying with UL 360.
- I. Fittings for Metal Conduit: Comply with NEMA FB 1 and UL 514B.
 - 1. Conduit Fittings for Hazardous (Classified) Locations: Comply with UL 886 and NFPA 70.
 - 2. Fittings for EMT:
 - a. Material: Steel.
 - b. Type: Setscrew.
 - 3. Expansion Fittings: PVC or steel to match conduit type, complying with UL 651, rated for environmental conditions where installed, and including flexible external bonding jumper.
 - 4. Coating for Fittings for PVC-Coated Conduit: Minimum thickness of 0.040 inch (1 mm), with overlapping sleeves protecting threaded joints.
- J. Joint Compound for IMC, GRC, or ARC: Approved, as defined in NFPA 70, by authorities having jurisdiction for use in conduit assemblies, and compounded for use to lubricate and protect threaded conduit joints from corrosion and to enhance their conductivity.

2.2 METAL WIREWAYS AND AUXILIARY GUTTERS

- A. Description: Sheet metal, complying with UL 870 and NEMA 250, Type 1 unless otherwise indicated, and sized according to NFPA 70.
 - 1. Metal wireways installed outdoors shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. Fittings and Accessories: Include covers, couplings, offsets, elbows, expansion joints, adapters, hold-down straps, end caps, and other fittings to match and mate with wireways as required for complete system.
- C. Wireway Covers: Hinged type unless otherwise indicated.
- D. Finish: Manufacturer's standard enamel finish.

2.3 SURFACE RACEWAYS

- A. Listing and Labeling: Surface raceways and tele-power poles shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

- B. Surface Metal Raceways: Galvanized steel with snap-on covers complying with UL 5. Prime coated, ready for field painting.
- C. Surface Nonmetallic Raceways: Two- or three-piece construction, complying with UL 5A, and manufactured of rigid PVC with texture and color selected by Architect from manufacturer's standard colors. Product shall comply with UL 94 V-0 requirements for self-extinguishing characteristics.

2.4 BOXES, ENCLOSURES, AND CABINETS

- A. General Requirements for Boxes, Enclosures, and Cabinets: Boxes, enclosures, and cabinets installed in wet locations shall be listed for use in wet locations.
- B. Sheet Metal Outlet and Device Boxes: Comply with NEMA OS 1 and UL 514A.
- C. Cast-Metal Outlet and Device Boxes: Comply with NEMA FB 1, ferrous alloy, Type FD, with gasketed cover.
- D. Nonmetallic Outlet and Device Boxes: Comply with NEMA OS 2 and UL 514C.
- E. Luminaire Outlet Boxes: Nonadjustable, designed for attachment of luminaire weighing 50 lb (23 kg). Outlet boxes designed for attachment of luminaires weighing more than 50 lb (23 kg) shall be listed and marked for the maximum allowable weight.
- F. Small Sheet Metal Pull and Junction Boxes: NEMA OS 1.
- G. Cast-Metal Access, Pull, and Junction Boxes: Comply with NEMA FB 1 and UL 1773, galvanized, cast iron with gasketed cover.
- H. Box extensions used to accommodate new building finishes shall be of same material as recessed box.
- I. Device Box Dimensions: 4 inches square by 2-1/8 inches deep (100 mm square by 60 mm deep).
- J. Hinged-Cover Enclosures: Comply with UL 50 and NEMA 250, Type 1 with continuous-hinge cover with flush latch unless otherwise indicated.
 - 1. Metal Enclosures: Steel, finished inside and out with manufacturer's standard enamel.
 - 2. Interior Panels: Steel; all sides finished with manufacturer's standard enamel.
- K. Cabinets:
 - 1. NEMA 250, Type 1 galvanized-steel box with removable interior panel and removable front, finished inside and out with manufacturer's standard enamel.
 - 2. Hinged door in front cover with flush latch and concealed hinge.
 - 3. Key latch to match panelboards.
 - 4. Metal barriers to separate wiring of different systems and voltage.
 - 5. Accessory feet where required for freestanding equipment.

6. Nonmetallic cabinets shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

2.5 HANDHOLES AND BOXES FOR EXTERIOR UNDERGROUND WIRING

A. General Requirements for Handholes and Boxes:

1. Boxes and handholes for use in underground systems shall be designed and identified as defined in NFPA 70, for intended location and application.
2. Boxes installed in wet areas shall be listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.

B. Polymer-Concrete Handholes and Boxes with Polymer-Concrete Cover: Molded of sand and aggregate, bound together with polymer resin, and reinforced with steel, fiberglass, or a combination of the two.

1. Standard: Comply with SCTE 77.
2. Configuration: Designed for flush burial with closed bottom unless otherwise indicated.
3. Cover: Weatherproof, secured by tamper-resistant locking devices and having structural load rating consistent with enclosure and handhole location.
4. Cover Finish: Nonskid finish shall have a minimum coefficient of friction of 0.50.
5. Cover Legend: Molded lettering, "ELECTRIC."
6. Conduit Entrance Provisions: Conduit-terminating fittings shall mate with entering ducts for secure, fixed installation in enclosure wall.
7. Handholes 12 Inches Wide by 24 Inches Long (300 mm Wide by 600 mm Long) and Larger: Have inserts for cable racks and pulling-in irons installed before concrete is poured.

2.6 SOURCE QUALITY CONTROL FOR UNDERGROUND ENCLOSURES

A. Handhole and Pull-Box Prototype Test: Test prototypes of handholes and boxes for compliance with SCTE 77. Strength tests shall be for specified tier ratings of products supplied.

1. Tests of materials shall be performed by an independent testing agency.
2. Strength tests of complete boxes and covers shall be by either an independent testing agency or manufacturer. A qualified registered professional engineer shall certify tests by manufacturer.
3. Testing machine pressure gages shall have current calibration certification complying with ISO 9000 and ISO 10012 and traceable to NIST standards.

PART 3 - EXECUTION

3.1 RACEWAY APPLICATION

- A. Outdoors: Apply raceway products as specified below unless otherwise indicated:
1. Exposed Conduit: GRC.
 2. Concealed Conduit, Aboveground: EMT.
 3. Underground Conduit: RNC, Type EPC-40-PVC.
 4. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): LFMC.
 5. Boxes and Enclosures, Aboveground: NEMA 250, Type 3R.
- B. Indoors: Apply raceway products as specified below unless otherwise indicated:
1. Exposed, Not Subject to Physical Damage: EMT.
 2. Exposed, Not Subject to Severe Physical Damage: EMT.
 3. Exposed and Subject to Severe Physical Damage: GRC. Raceway locations include the following:
 - a. Loading dock.
 - b. Maintenance garage.
 - c. Bus repair / wash facility.
 4. Concealed in Ceilings and Interior Walls and Partitions: EMT.
 5. Connection to Vibrating Equipment (Including Transformers and Hydraulic, Pneumatic, Electric Solenoid, or Motor-Driven Equipment): FMC, except use LFMC in damp or wet locations.
 6. Damp or Wet Locations: GRC.
 7. Boxes and Enclosures: NEMA 250, Type 1, except use NEMA 250, Type 4 stainless steel in institutional and commercial kitchens and damp or wet locations.
- C. Minimum Raceway Size: 3/4-inch (21-mm) trade size.
- D. Raceway Fittings: Compatible with raceways and suitable for use and location.
1. Rigid and Intermediate Steel Conduit: Use threaded rigid steel conduit fittings unless otherwise indicated. Comply with NEMA FB 2.10.
 2. PVC Externally Coated, Rigid Steel Conduits: Use only fittings listed for use with this type of conduit. Patch and seal all joints, nicks, and scrapes in PVC coating after installing conduits and fittings. Use sealant recommended by fitting manufacturer and apply in thickness and number of coats recommended by manufacturer.
 3. EMT: Use setscrew or compression, steel fittings. Comply with NEMA FB 2.10.
 4. Flexible Conduit: Use only fittings listed for use with flexible conduit. Comply with NEMA FB 2.20.
- E. Install nonferrous conduit or tubing for circuits operating above 60 Hz. Where aluminum raceways are installed for such circuits and pass through concrete, install in nonmetallic sleeve.

- F. Do not install aluminum conduits, boxes, or fittings in contact with concrete or earth.
- G. Install surface raceways only where indicated on Drawings.
- H. Do not install nonmetallic conduit where ambient temperature exceeds 120 deg F (49 deg).

3.2 INSTALLATION

- A. Comply with NECA 1 and NECA 101 for installation requirements except where requirements on Drawings or in this article are stricter. Comply with NECA 102 for aluminum conduits. Comply with NFPA 70 limitations for types of raceways allowed in specific occupancies and number of floors.
- B. Keep raceways at least 6 inches (150 mm) away from parallel runs of flues and steam or hot-water pipes. Install horizontal raceway runs above water and steam piping.
- C. Complete raceway installation before starting conductor installation.
- D. Comply with requirements in Section 260529 "Hangers and Supports for Electrical Systems" for hangers and supports.
- E. Arrange stub-ups so curved portions of bends are not visible above finished slab.
- F. Install no more than the equivalent of three 90-degree bends in any conduit run except for control wiring conduits, for which fewer bends are allowed. Support within 12 inches (300 mm) of changes in direction.
- G. Conceal conduit and EMT within finished walls, ceilings, and floors unless otherwise indicated. Install conduits parallel or perpendicular to building lines.
- H. Support conduit within 12 inches (300 mm) of enclosures to which attached.
- I. Raceways Embedded in Slabs:
 - 1. Run conduit larger than 1-inch (27-mm) trade size, parallel or at right angles to main reinforcement. Where at right angles to reinforcement, place conduit close to slab support. Secure raceways to reinforcement at maximum 10-foot (3-m) intervals.
 - 2. Arrange raceways to cross building expansion joints at right angles with expansion fittings.
 - 3. Arrange raceways to keep a minimum of 1 inch (25 mm) of concrete cover in all directions.
 - 4. Do not embed threadless fittings in concrete unless specifically approved by Architect for each specific location.
- J. Stub-ups to Above Recessed Ceilings:
 - 1. Use EMT, IMC, or RMC for raceways.
 - 2. Use a conduit bushing or insulated fitting to terminate stub-ups not terminated in hubs or in an enclosure.

- K. Threaded Conduit Joints, Exposed to Wet, Damp, Corrosive, or Outdoor Conditions: Apply listed compound to threads of raceway and fittings before making up joints. Follow compound manufacturer's written instructions.
- L. Coat field-cut threads on PVC-coated raceway with a corrosion-preventing conductive compound prior to assembly.
- M. Raceway Terminations at Locations Subject to Moisture or Vibration: Use insulating bushings to protect conductors including conductors smaller than No. 4 AWG.
- N. Terminate threaded conduits into threaded hubs or with locknuts on inside and outside of boxes or cabinets. Install bushings on conduits up to 1-1/4-inch (35mm) trade size and insulated throat metal bushings on 1-1/2-inch (41-mm) trade size and larger conduits terminated with locknuts. Install insulated throat metal grounding bushings on service conduits.
- O. Install raceways square to the enclosure and terminate at enclosures with locknuts. Install locknuts hand tight plus 1/4 turn more.
- P. Do not rely on locknuts to penetrate nonconductive coatings on enclosures. Remove coatings in the locknut area prior to assembling conduit to enclosure to assure a continuous ground path.
- Q. Cut conduit perpendicular to the length. For conduits 2-inch (53-mm) trade size and larger, use roll cutter or a guide to make cut straight and perpendicular to the length.
- R. Install pull wires in empty raceways. Use polypropylene or monofilament plastic line with not less than 200-lb (90-kg) tensile strength. Leave at least 12 inches (300 mm) of slack at each end of pull wire. Cap underground raceways designated as spare above grade alongside raceways in use.
- S. Surface Raceways:
 - 1. Install surface raceway with a minimum 2-inch (50-mm) radius control at bend points.
 - 2. Secure surface raceway with screws or other anchor-type devices at intervals not exceeding 48 inches (1200 mm) and with no less than two supports per straight raceway section. Support surface raceway according to manufacturer's written instructions. Tape and glue are not acceptable support methods.
- T. Install raceway sealing fittings at accessible locations according to NFPA 70 and fill them with listed sealing compound. For concealed raceways, install each fitting in a flush steel box with a blank cover plate having a finish similar to that of adjacent plates or surfaces. Install raceway sealing fittings according to NFPA 70.
- U. Install devices to seal raceway interiors at accessible locations. Locate seals so no fittings or boxes are between the seal and the following changes of environments. Seal the interior of all raceways at the following points:
 - 1. Where conduits pass from warm to cold locations, such as boundaries of refrigerated spaces.
 - 2. Where an underground service raceway enters a building or structure.
 - 3. Where otherwise required by NFPA 70.

- V. Comply with manufacturer's written instructions for solvent welding RNC and fittings.
- W. Expansion-Joint Fittings:
1. Install in each run of aboveground RNC that is located where environmental temperature change may exceed 30 deg F (17 deg C) and that has straight-run length that exceeds 25 feet (7.6 m). Install in each run of aboveground RMC conduit that is located where environmental temperature change may exceed 100 deg F (55 deg C) and that has straight-run length that exceeds 100 feet (30 m).
 2. Install type and quantity of fittings that accommodate temperature change listed for each of the following locations:
 - a. Outdoor Locations Not Exposed to Direct Sunlight: 125 deg F (70 deg C) temperature change.
 - b. Outdoor Locations Exposed to Direct Sunlight: 155 deg F (86 deg C) temperature change.
 - c. Indoor Spaces Connected with Outdoors without Physical Separation: 125 deg F (70 deg C) temperature change.
 - d. Attics: 135 deg F (75 deg C) temperature change.
 3. Install fitting(s) that provide expansion and contraction for at least 0.00041 inch per foot of length of straight run per deg F (0.06 mm per meter of length of straight run per deg C) of temperature change for PVC conduits. Install fitting(s) that provide expansion and contraction for at least 0.000078 inch per foot of length of straight run per deg F (0.0115 mm per meter of length of straight run per deg C) of temperature change for metal conduits.
 4. Install expansion fittings at all locations where conduits cross building or structure expansion joints.
 5. Install each expansion-joint fitting with position, mounting, and piston setting selected according to manufacturer's written instructions for conditions at specific location at time of installation. Install conduit supports to allow for expansion movement.
- X. Flexible Conduit Connections: Comply with NEMA RV 3. Use a maximum of 72 inches (1830 mm) of flexible conduit for recessed and semirecessed luminaires, equipment subject to vibration, noise transmission, or movement; and for transformers and motors.
1. Use LFMC in damp or wet locations subject to severe physical damage.
 2. Use LFMC or LFNC in damp or wet locations not subject to severe physical damage.
- Y. Mount boxes at heights indicated on Drawings. If mounting heights of boxes are not individually indicated, give priority to ADA requirements. Install boxes with height measured to center of box unless otherwise indicated.
- Z. Recessed Boxes in Masonry Walls: Saw-cut opening for box in center of cell of masonry block, and install box flush with surface of wall. Prepare block surfaces to provide a flat surface for a raintight connection between box and cover plate or supported equipment and box.
- AA. Horizontally separate boxes mounted on opposite sides of walls so they are not in the same vertical channel.

- BB. Locate boxes so that cover or plate will not span different building finishes.
- CC. Support boxes of three gangs or more from more than one side by spanning two framing members or mounting on brackets specifically designed for the purpose.
- DD. Fasten junction and pull boxes to or support from building structure. Do not support boxes by conduits.
- EE. Set metal floor boxes level and flush with finished floor surface.
- FF. Set nonmetallic floor boxes level. Trim after installation to fit flush with finished floor surface.

3.3 INSTALLATION OF UNDERGROUND CONDUIT

A. Direct-Buried Conduit:

1. Excavate trench bottom to provide firm and uniform support for conduit. Prepare trench bottom as specified in Section 312000 "Earth Moving" for pipe less than 6 inches (150 mm) in nominal diameter.
2. Install backfill as specified in Section 312000 "Earth Moving."
3. After installing conduit, backfill and compact. Start at tie-in point, and work toward end of conduit run, leaving conduit at end of run free to move with expansion and contraction as temperature changes during this process. Firmly hand tamp backfill around conduit to provide maximum supporting strength. After placing controlled backfill to within 12 inches (300 mm) of finished grade, make final conduit connection at end of run and complete backfilling with normal compaction as specified in Section 312000 "Earth Moving."
4. Install manufactured duct elbows for stub-ups at poles and equipment and at building entrances through floor unless otherwise indicated. Encase elbows for stub-up ducts throughout length of elbow.
5. Install manufactured rigid steel conduit elbows for stub-ups at poles and equipment and at building entrances through floor.
 - a. Couple steel conduits to ducts with adapters designed for this purpose, and encase coupling with 3 inches (75 mm) of concrete for a minimum of 12 inches (300 mm) on each side of the coupling.
 - b. For stub-ups at equipment mounted on outdoor concrete bases and where conduits penetrate building foundations, extend steel conduit horizontally a minimum of 60 inches (1500 mm) from edge of foundation or equipment base. Install insulated grounding bushings on terminations at equipment.
6. Warning Planks: Bury warning planks approximately 12 inches (300 mm) above direct-buried conduits but a minimum of 6 inches (150 mm) below grade. Align planks along centerline of conduit.
7. Underground Warning Tape: Comply with requirements in Section 260553 "Identification for Electrical Systems."

3.4 INSTALLATION OF UNDERGROUND HANDHOLES AND BOXES

- A. Install handholes and boxes level and plumb and with orientation and depth coordinated with connecting conduits to minimize bends and deflections required for proper entrances.
- B. Unless otherwise indicated, support units on a level bed of crushed stone or gravel, graded from 1/2-inch (12.5-mm) sieve to No. 4 (4.75-mm) sieve and compacted to same density as adjacent undisturbed earth.
- C. Elevation: In paved areas, set so cover surface will be flush with finished grade. Set covers of other enclosures 1 inch (25 mm) above finished grade.
- D. Install handholes with bottom below frost line, below grade.
- E. Install removable hardware, including pulling eyes, cable stanchions, cable arms, and insulators, as required for installation and support of cables and conductors and as indicated. Select arm lengths to be long enough to provide spare space for future cables but short enough to preserve adequate working clearances in enclosure.
- F. Field-cut openings for conduits according to enclosure manufacturer's written instructions. Cut wall of enclosure with a tool designed for material to be cut. Size holes for terminating fittings to be used, and seal around penetrations after fittings are installed.

3.5 SLEEVE AND SLEEVE-SEAL INSTALLATION FOR ELECTRICAL PENETRATIONS

- A. Install sleeves and sleeve seals at penetrations of exterior floor and wall assemblies. Comply with requirements in Section 260544 "Sleeves and Sleeve Seals for Electrical Raceways and Cabling."

3.6 FIRESTOPPING

- A. Install firestopping at penetrations of fire-rated floor and wall assemblies. Comply with requirements in Section 078413 "Penetration Firestopping."

3.7 PROTECTION

- A. Protect coatings, finishes, and cabinets from damage and deterioration.
 - 1. Repair damage to galvanized finishes with zinc-rich paint recommended by manufacturer.
 - 2. Repair damage to PVC coatings or paint finishes with matching touchup coating recommended by manufacturer.

END OF SECTION 260533

THIS PAGE IS INTENTIONALLY LEFT BLANK

SECTION 260553 - IDENTIFICATION FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Identification for raceways.
2. Identification of power and control cables.
3. Identification for conductors.
4. Underground-line warning tape.
5. Warning labels and signs.
6. Instruction signs.
7. Equipment identification labels, including arc-flash warning labels.
8. Miscellaneous identification products.

1.2 ACTION SUBMITTALS

A. Product Data: For each type of product.

1. Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for electrical identification products.

B. Samples: For each type of label and sign to illustrate composition, size, colors, lettering style, mounting provisions, and graphic features of identification products.

C. Identification Schedule: For each piece of electrical equipment and electrical system components to be an index of nomenclature for electrical equipment and system components used in identification signs and labels. Use same designations indicated on Drawings.

D. Delegated-Design Submittal: For arc-flash hazard study.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Comply with ASME A13.1 and IEEE C2.
- B. Comply with NFPA 70.
- C. Comply with 29 CFR 1910.144 and 29 CFR 1910.145.
- D. Comply with ANSI Z535.4 for safety signs and labels.

- E. Adhesive-attached labeling materials, including label stocks, laminating adhesives, and inks used by label printers, shall comply with UL 969.
- F. Thermal Movements: Allow for thermal movements from ambient and surface temperature changes.
 - 1. Temperature Change: 120 deg F (67 deg C), ambient; 180 deg F (100 deg C), material surfaces.

2.2 COLOR AND LEGEND REQUIREMENTS

- A. Raceways and Cables Carrying Circuits at 600 V or Less:
 - 1. Black letters on an orange field.
 - 2. Legend: Indicate voltage.
- B. Raceways and Cables Carrying Circuits at More Than 600 V:
 - 1. Black letters on an orange field.
 - 2. Legend: "DANGER - CONCEALED HIGH VOLTAGE WIRING."
- C. Warning labels and signs shall include, but are not limited to, the following legends:
 - 1. Multiple Power Source Warning: "DANGER - ELECTRICAL SHOCK HAZARD - EQUIPMENT HAS MULTIPLE POWER SOURCES."
 - 2. Workspace Clearance Warning: "WARNING - OSHA REGULATION - AREA IN FRONT OF ELECTRICAL EQUIPMENT MUST BE KEPT CLEAR FOR 36 INCHES (915 MM)."

2.3 LABELS

- A. Vinyl Labels for Raceways Carrying Circuits at 600 V or Less: Preprinted, flexible labels laminated with a clear, weather- and chemical-resistant coating and matching wraparound clear adhesive tape for securing label ends.
- B. Snap-Around Labels for Raceways and Cables Carrying Circuits at 600 V or Less: Slit, pretensioned, flexible, preprinted, color-coded acrylic sleeves, with diameters sized to suit diameters of raceways they identify, and that stay in place by gripping action.
- C. Self-Adhesive Labels:
 - 1. Preprinted, 3-mil- (0.08-mm-) thick, polyester flexible label with acrylic pressure-sensitive adhesive.
 - a. Self-Lamination: Clear; UV-, weather- and chemical-resistant; self-laminating, protective shield over the legend. Labels sized to fit the cable diameter, such that the clear shield overlaps the entire printed legend.

2. Polyester, thermal, transfer-printed, 3-mil- (0.08-mm-) thick, multicolor, weather- and UV-resistant, pressure-sensitive adhesive labels, configured for display on front cover, door, or other access to equipment unless otherwise indicated.
 - a. Nominal Size: 3.5-by-5-inch (76-by-127-mm).
3. Marker for Tags: Permanent, waterproof, black ink marker recommended by tag manufacturer.
4. Marker for Tags: Machine-printed, permanent, waterproof, black ink recommended by printer manufacturer.

2.4 BANDS AND TUBES:

- A. Snap-Around, Color-Coding Bands for Raceways and Cables: Slit, pretensioned, flexible, solid-colored acrylic sleeves, 2 inches (50 mm) long, with diameters sized to suit diameters of raceways or cables they identify, and that stay in place by gripping action.
- B. Heat-Shrink Preprinted Tubes: Flame-retardant polyolefin tubes with machine-printed identification labels, sized to suit diameters of and shrunk to fit firmly around cables they identify. Full shrink recovery occurs at a maximum of 200 deg F (93 deg C). Comply with UL 224.

2.5 TAPES AND STENCILS:

- A. Marker Tapes: Vinyl or vinyl-cloth, self-adhesive wraparound type, with circuit identification legend machine printed by thermal transfer or equivalent process.
- B. Self-Adhesive Vinyl Tape: Colored, heavy duty, waterproof, fade resistant; not less than 3 mils (0.08 mm) thick by 1 to 2 inches (25 to 50 mm) wide; compounded for outdoor use.
- C. Tape and Stencil for Raceways Carrying Circuits 600 V or Less: 4-inch- (100-mm-) wide black stripes on 10-inch (250-mm) centers placed diagonally over orange background that extends full length of raceway or duct and is 12 inches (300 mm) wide. Stop stripes at legends.
- D. Floor Marking Tape: 2-inch- (50-mm-) wide, 5-mil (0.125-mm) pressure-sensitive vinyl tape, with black and white stripes and clear vinyl overlay.
- E. Underground-Line Warning Tape
 1. Tape:
 - a. Recommended by manufacturer for the method of installation and suitable to identify and locate underground electrical utility lines.
 - b. Printing on tape shall be permanent and shall not be damaged by burial operations.
 - c. Tape material and ink shall be chemically inert and not subject to degradation when exposed to acids, alkalis, and other destructive substances commonly found in soils.

2. Color and Printing:
 - a. Comply with ANSI Z535.1, ANSI Z535.2, ANSI Z535.3, ANSI Z535.4, and ANSI Z535.5.
 - b. Inscriptions for Red-Colored Tapes: "ELECTRIC LINE, HIGH VOLTAGE"
 - c. Inscriptions for Orange-Colored Tapes: "TELEPHONE CABLE, CATV CABLE, COMMUNICATIONS CABLE, OPTICAL FIBER CABLE".

3. Tag: Type I:
 - a. Pigmented polyolefin, bright colored, continuous-printed on one side with the inscription of the utility, compounded for direct-burial service.
 - b. Width: 3 inches (75 mm).
 - c. Thickness: 4 mils (0.1 mm).
 - d. Weight: 18.5 lb/1000 sq. ft. (9.0 kg/100 sq. m).
 - e. Tensile according to ASTM D 882: 30 lbf (133.4 N) and 2500 psi (17.2 MPa).

4. Tag: Type II:
 - a. Multilayer laminate, consisting of high-density polyethylene scrim coated with pigmented polyolefin; bright colored, continuous-printed on one side with the inscription of the utility, compounded for direct-burial service.
 - b. Width: 3 inches (75-mm).
 - c. Thickness: 12 mils (0.3 mm).
 - d. Weight: 36.1 lb/1000 sq. ft. (17.6 kg/100 sq. m).
 - e. Tensile according to ASTM D 882: 400 lbf (1780 N) and 11,500 psi (79.2 MPa).

5. Tag: Type ID:
 - a. Detectable three-layer laminate, consisting of a printed pigmented polyolefin film, a solid aluminum-foil core, and a clear protective film that allows inspection of the continuity of the conductive core; bright colored, continuous-printed on one side with the inscription of the utility, compounded for direct-burial service.
 - b. Width: 3 inches (75 mm).
 - c. Overall Thickness: 5 mils (0.125 mm).
 - d. Foil Core Thickness: 0.35 mil (0.00889 mm).
 - e. Weight: 28 lb/1000 sq. ft. (13.7 kg/100 sq. m).
 - f. Tensile according to ASTM D 882: 70 lbf (311.3 N) and 4600 psi (31.7 MPa).

6. Tag: Type IID:
 - a. Reinforced, detectable three-layer laminate, consisting of a printed pigmented woven scrim, a solid aluminum-foil core, and a clear protective film that allows inspection of the continuity of the conductive core; bright-colored, continuous-printed on one side with the inscription of the utility, compounded for direct-burial service.
 - b. Width: 3 inches (75-mm).
 - c. Overall Thickness: 8 mils (0.2 mm).
 - d. Foil Core Thickness: 0.35 mil (0.00889 mm).
 - e. Weight: 34 lb/1000 sq. ft. (16.6 kg/100 sq. m).

f. Tensile according to ASTM D 882: 300 lbf (1334 N) and 12,500 psi (86.1 MPa).

F. Stenciled Legend: In nonfading, waterproof, black ink or paint. Minimum letter height shall be 1 inch (25 mm).

2.6 Tags

A. Metal Tags: Brass or aluminum, 2 by 2 by 0.05 inch (50 by 50 by 1.3 mm), with stamped legend, punched for use with self-locking cable tie fastener.

B. Nonmetallic Preprinted Tags: Polyethylene tags, 0.015 inch (0.38 mm) thick, color-coded for phase and voltage level, with factory screened permanent designations; punched for use with self-locking cable tie fastener.

C. Write-On Tags:

1. Polyester Tags: 0.010 inch (0.25 mm) thick, with corrosion-resistant grommet and cable tie for attachment to raceway, conductor, or cable.

2. Marker for Tags: Permanent, waterproof, black ink marker recommended by tag manufacturer.

3. Marker for Tags: Machine-printed, permanent, waterproof, black ink marker recommended by printer manufacturer.

2.7 Signs

A. Baked-Enamel Signs:

1. Preprinted aluminum signs, punched or drilled for fasteners, with colors, legend, and size required for application.

2. 1/4-inch (6.4-mm) grommets in corners for mounting.

3. Nominal Size: 7 by 10 inches (180 by 250 mm).

B. Metal-Backed Butyrate Signs:

1. Weather-resistant, nonfading, preprinted, cellulose-acetate butyrate signs, with 0.0396-inch (1-mm) galvanized-steel backing and with colors, legend, and size required for application.

2. 1/4-inch (6.4-mm) grommets in corners for mounting.

3. Nominal Size: 10 by 14 inches (250 by 360 mm).

C. Laminated Acrylic or Melamine Plastic Signs:

1. Engraved legend.

2. Thickness:

a. For signs up to 20 sq. inches (129 sq. cm), minimum 1/16-inch- (1.6-mm-).

b. For signs larger than 20 sq. inches (129 sq. cm), 1/8 inch (3.2 mm) thick.

c. Engraved legend with black letters on white face.

- d. Self-adhesive.
- e. Framed with mitered acrylic molding and arranged for attachment at applicable equipment.

2.8 CABLE TIES

- A. General-Purpose Cable Ties: Fungus inert, self-extinguishing, one piece, self-locking, Type 6/6 nylon.
 - 1. Minimum Width: 3/16 inch (5 mm).
 - 2. Tensile Strength at 73 deg F (23 deg C) according to ASTM D 638: 12,000 psi (82.7 MPa).
 - 3. Temperature Range: Minus 40 to plus 185 deg F (Minus 40 to plus 85 deg C).
 - 4. Color: Black, except where used for color-coding.
- B. UV-Stabilized Cable Ties: Fungus inert, designed for continuous exposure to exterior sunlight, self-extinguishing, one piece, self-locking, Type 6/6 nylon.
 - 1. Minimum Width: 3/16 inch (5 mm).
 - 2. Tensile Strength at 73 deg F (23 deg C) according to ASTM D 638: 12,000 psi (82.7 MPa).
 - 3. Temperature Range: Minus 40 to plus 185 deg F (Minus 40 to plus 85 deg C).
 - 4. Color: Black.
- C. Plenum-Rated Cable Ties: Self-extinguishing, UV stabilized, one piece, self-locking.
 - 1. Minimum Width: 3/16 inch (5 mm).
 - 2. Tensile Strength at 73 deg F (23 deg C) according to ASTM D 638: 7000 psi (48.2 MPa).
 - 3. UL 94 Flame Rating: 94V-0.
 - 4. Temperature Range: Minus 50 to plus 284 deg F (Minus 46 to plus 140 deg C).
 - 5. Color: Black.

2.9 MISCELLANEOUS IDENTIFICATION PRODUCTS

- A. Paint: Comply with requirements in painting Sections for paint materials and application requirements. Retain paint system applicable for surface material and location (exterior or interior).
- B. Fasteners for Labels and Signs: Self-tapping, stainless-steel screws or stainless-steel machine screws with nuts and flat and lock washers.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Self-Adhesive Identification Products: Before applying electrical identification products, clean substrates of substances that could impair bond, using materials and methods recommended by manufacturer of identification product.

3.2 INSTALLATION

- A. Verify and coordinate identification names, abbreviations, colors, and other features with requirements in other Sections requiring identification applications, Drawings, Shop Drawings, manufacturer's wiring diagrams, and operation and maintenance manual. Use consistent designations throughout Project.
- B. Install identifying devices before installing acoustical ceilings and similar concealment.
- C. Verify identity of each item before installing identification products.
- D. Install identification materials and devices at locations for most convenient viewing without interference with operation and maintenance of equipment. Install access doors or panels to provide view of identifying devices.
- E. Apply identification devices to surfaces that require finish after completing finish work.
- F. Attach signs and plastic labels that are not self-adhesive type with mechanical fasteners appropriate to the location and substrate.
- G. Attach plastic raceway and cable labels that are not self-adhesive type with clear vinyl tape, with adhesive appropriate to the location and substrate.
- H. Cable Ties: For attaching tags. Use general-purpose type, except as listed below:
 - 1. Outdoors: UV-stabilized nylon.
 - 2. In Spaces Handling Environmental Air: Plenum rated.
- I. Painted Identification: Comply with requirements in painting Sections for surface preparation and paint application.
- J. Aluminum Wraparound Marker Labels and Metal Tags: Secure tight to surface of conductor or cable at a location with high visibility and accessibility.
- K. System Identification Color-Coding Bands for Raceways and Cables: Each color-coding band shall completely encircle cable or conduit. Place adjacent bands of two-color markings in contact, side by side. Locate bands at changes in direction, at penetrations of walls and floors, at 50-foot (15-m) maximum intervals in straight runs, and at 25-foot (7.6-m) maximum intervals in congested areas.

- L. During backfilling of trenches, install continuous underground-line warning tape directly above cable or raceway at 6 to 8 inches (150 to 200 mm) below finished grade. Use multiple tapes where width of multiple lines installed in a common trench or concrete envelope exceeds 16 inches (400 mm) overall.

3.3 IDENTIFICATION SCHEDULE

- A. Concealed Raceways, Duct Banks, More Than 600 V, within Buildings: Tape and stencil 4-inch- (100-mm-) wide black stripes on 10-inch (250-mm) centers over orange background that extends full length of raceway or duct and is 12 inches (300 mm) wide. Stencil legend "DANGER CONCEALED HIGH VOLTAGE WIRING" with 3-inch- (75-mm-) high black letters on 20-inch (500-mm) centers. Stop stripes at legends. Apply stripes to the following finished surfaces:
 - 1. Floor surface directly above conduits running beneath and within 12 inches (300 mm) of a floor that is in contact with earth or is framed above unexcavated space.
 - 2. Wall surfaces directly external to raceways concealed within wall.
 - 3. Accessible surfaces of concrete envelope around raceways in vertical shafts, exposed in the building, or concealed above suspended ceilings.
- B. Accessible Raceways, Armored and Metal-Clad Cables, More Than 600 V: Self-adhesive vinyl labels. Install labels at 10-foot (3-m) maximum intervals.
- C. Accessible Raceways and Metal-Clad Cables, 600 V or Less, for Service, Feeder, and Branch Circuits, More Than 30 A and 120 V to Ground: Identify with self-adhesive vinyl label. Install labels at 10-foot (3-m) maximum intervals.
- D. Accessible Raceways and Cables within Buildings: Identify the covers of each junction and pull box of the following systems with self-adhesive vinyl labels containing the wiring system legend and system voltage. System legends shall be as follows:
 - 1. "EMERGENCY POWER."
 - 2. "POWER."
 - 3. "UPS."
- E. Power-Circuit Conductor Identification, 600 V or Less: For conductors in vaults, pull and junction boxes, manholes, and handholes, use color-coding conductor tape to identify the phase.
 - 1. Color-Coding for Phase- Identification, 600 V or Less: Use colors listed below for ungrounded feeder and branch-circuit conductors.
 - a. Color shall be factory applied.
 - b. Colors for 208/120-V Circuits:
 - 1) Phase A: Black.
 - 2) Phase B: Red.
 - 3) Phase C: Blue.

- c. Colors for 480/277-V Circuits:
 - 1) Phase A: Brown.
 - 2) Phase B: Orange.
 - 3) Phase C: Yellow.
- d. Field-Applied, Color-Coding Conductor Tape: Apply in half-lapped turns for a minimum distance of 6 inches (150 mm) from terminal points and in boxes where splices or taps are made. Apply last two turns of tape with no tension to prevent possible unwinding. Locate bands to avoid obscuring factory cable markings.
- F. Install instructional sign, including the color code for grounded and ungrounded conductors using adhesive-film-type labels.
- G. Conductors To Be Extended in the Future: Attach marker tape to conductors and list source.
- H. Auxiliary Electrical Systems Conductor Identification: Identify field-installed alarm, control, and signal connections.
 - 1. Identify conductors, cables, and terminals in enclosures and at junctions, terminals, and pull points. Identify by system and circuit designation.
 - 2. Use system of marker-tape designations that is uniform and consistent with system used by manufacturer for factory-installed connections.
 - 3. Coordinate identification with Project Drawings, manufacturer's wiring diagrams, and operation and maintenance manual.
- I. Locations of Underground Lines: Identify with underground-line warning tape for power, lighting, communication, and control wiring and optical-fiber cable.
 - 1. Limit use of underground-line warning tape to direct-buried cables.
 - 2. Install underground-line warning tape for direct-buried cables and cables in raceways.
- J. Workspace Indication: Install floor marking tape to show working clearances in the direction of access to live parts. Workspace shall comply with NFPA 70 and 29 CFR 1926.403 unless otherwise indicated. Do not install at flush-mounted panelboards and similar equipment in finished spaces.
- K. Warning Labels for Indoor Cabinets, Boxes, and Enclosures for Power and Lighting: Self-adhesive warning labels.
 - 1. Comply with 29 CFR 1910.145.
 - 2. Identify system voltage with black letters on an orange background.
 - 3. Apply to exterior of door, cover, or other access.
 - 4. For equipment with multiple power or control sources, apply to door or cover of equipment, including, but not limited to, the following:
 - a. Power-transfer switches.
 - b. Controls with external control power connections.
- L. Arc Flash Warning Labeling: Self-adhesive thermal transfer vinyl labels.

1. Comply with NFPA 70E and ANSI Z535.4.
 2. Comply with Section 260574 "Overcurrent Protective Device Arc-Flash Study" requirements for arc-flash warning labels.
- M. Operating Instruction Signs: Install instruction signs to facilitate proper operation and maintenance of electrical systems and items to which they connect. Install instruction signs with approved legend where instructions are needed for system or equipment operation.
- N. Equipment Identification Labels: On each unit of equipment, install unique designation label that is consistent with wiring diagrams, schedules, and operation and maintenance manual. Apply labels to disconnect switches and protection equipment, central or master units, control panels, control stations, terminal cabinets, and racks of each system. Systems include power, lighting, control, communication, signal, monitoring, and alarm unless equipment is provided with its own identification.
1. Labeling Instructions:
 - a. Indoor Equipment: Self-adhesive label. Unless otherwise indicated, provide a single line of text with 1/2-inch- (13-mm-) high letters on 1-1/2-inch- (38-mm-) high label; where two lines of text are required, use labels 2 inches (50 mm) high.
 - b. Outdoor Equipment: Engraved, laminated acrylic or melamine label.
 - c. Elevated Components: Increase sizes of labels and letters to those appropriate for viewing from the floor.
 - d. Unless labels are provided with self-adhesive means of attachment, fasten them with appropriate mechanical fasteners that do not change the NEMA or NRTL rating of the enclosure.
 2. Equipment To Be Labeled:
 - a. Panelboards: Typewritten directory of circuits in the location provided by panelboard manufacturer. Panelboard identification shall be in the form of a self-adhesive, engraved laminated acrylic or melamine label.
 - b. Enclosures and electrical cabinets.
 - c. Access doors and panels for concealed electrical items.
 - d. Switchgear.
 - e. Switchboards.
 - f. Transformers: Label that includes tag designation shown on Drawings for the transformer, feeder, and panelboards or equipment supplied by the secondary.
 - g. Substations.
 - h. Emergency system boxes and enclosures.
 - i. Motor-control centers.
 - j. Enclosed switches.
 - k. Enclosed circuit breakers.
 - l. Enclosed controllers.
 - m. Variable-speed controllers.
 - n. Push-button stations.
 - o. Power-transfer equipment.
 - p. Contactors.
 - q. Remote-controlled switches, dimmer modules, and control devices.
 - r. Battery-inverter units.

- s. Battery racks.
- t. Power-generating units.
- u. Monitoring and control equipment.
- v. UPS equipment.

END OF SECTION 260553

THIS PAGE IS INTENTIONALLY LEFT BLANK

SECTION 265619 - EXTERIOR LIGHTING

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:

1. Exterior solid-state luminaires that are designed for and exclusively use LED lamp technology.
2. Luminaire supports.
3. Luminaire-mounted photoelectric relays.

1.2 DEFINITIONS

- A. CCT: Correlated color temperature.
- B. CRI: Color rendering index.
- C. Fixture: See "Luminaire."
- D. IP: International Protection or Ingress Protection Rating.
- E. Lumen: Measured output of lamp and luminaire, or both.
- F. Luminaire: Complete lighting unit, including lamp, reflector, and housing.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of luminaire.

1. Arrange in order of luminaire designation.
2. Include data on features, accessories, and finishes.
3. Include physical description and dimensions of luminaire.
4. Lamps, include life, output (lumens, CCT, and CRI), and energy-efficiency data.
5. Photometric data and adjustment factors based on laboratory tests, complying with IES Lighting Measurements Testing and Calculation Guides, of each luminaire type. The adjustment factors shall be for lamps and accessories identical to those indicated for the luminaire as applied in this Project.
 - a. Manufacturer's Certified Data: Photometric data certified by manufacturer's laboratory with a current accreditation under the NVLAP for Energy Efficient Lighting Products.
 - b. Testing Agency Certified Data: For indicated luminaires, photometric data certified by a qualified independent testing agency. Photometric data for remaining luminaires shall be certified by manufacturer.

6. Wiring diagrams for power, control, and signal wiring.
 7. Photoelectric relays.
 8. Means of attaching luminaires to supports and indication that the attachment is suitable for components involved.
- B. Shop Drawings: For nonstandard or custom luminaires.
1. Include plans, elevations, sections, and mounting and attachment details.
 2. Include details of luminaire assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
 3. Include diagrams for power, signal, and control wiring.
- C. LEED Submittals:
1. Product Data for Credit EA 5: For specified metering equipment.
 2. Product Data for Credit MR 4: For products having recycled content, documentation indicating percentages by weight of postconsumer and preconsumer recycled content. Include statement indicating cost for each product having recycled content.
- D. Samples: For each luminaire and for each color and texture indicated with factory-applied finish.
- E. Product Schedule: For luminaires and lamps. Use same designations indicated on Drawings.
- F. Delegated-Design Submittal: For luminaire supports.
1. Include design calculations for luminaire supports and seismic restraints.
- 1.4 INFORMATIONAL SUBMITTALS
- A. Coordination Drawings: Plans, drawn to scale, on which the following items are shown and coordinated with each other, using input from installers of the items involved:
1. Luminaires.
 2. Structural members to which equipment and luminaires will be attached.
 3. Underground utilities and structures.
 4. Existing underground utilities and structures.
 5. Above-grade utilities and structures.
 6. Existing above-grade utilities and structures.
 7. Building features.
 8. Vertical and horizontal information.
- B. Qualification Data: For testing laboratory providing photometric data for luminaires.
- C. Seismic Qualification Certificates: For luminaires, accessories, and components, from manufacturer.

1. Basis for Certification: Indicate whether withstand certification is based on actual test of assembled components or on calculation.
 2. Dimensioned Outline Drawings of Equipment Unit: Identify center of gravity and locate and describe mounting and anchorage provisions.
 3. Detailed description of equipment anchorage devices on which the certification is based and their installation requirements.
- D. Product Certificates: For each type of the following:
1. Luminaire.
 2. Photoelectric relay.
- E. Product Test Reports: For each luminaire, for tests performed by manufacturer and witnessed by a qualified testing agency.
- F. Source quality-control reports.
- G. Sample warranty.

1.5 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For luminaires and photoelectric relays to include in operation and maintenance manuals.
1. Provide a list of all lamp types used on Project. Use ANSI and manufacturers' codes.
 2. Provide a list of all photoelectric relay types used on Project; use manufacturers' codes.

1.6 MAINTENANCE MATERIAL SUBMITTALS

- A. Furnish extra materials that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
1. Lamps: Ten for every 100 of each type and rating installed. Furnish at least one of each type.
 2. Glass, Acrylic, and Plastic Lenses, Covers, and Other Optical Parts: One for every 100 of each type and rating installed. Furnish at least one of each type.
 3. Diffusers and Lenses: One for every 100 of each type and rating installed. Furnish at least one of each type.
 4. Globes and Guards: One for every 20 of each type and rating installed. Furnish at least one of each type.

1.7 QUALITY ASSURANCE

- A. Luminaire Photometric Data Testing Laboratory Qualifications: Luminaire manufacturers' laboratory that is accredited under the NVLAP for Energy Efficient Lighting Products.

- B. Luminaire Photometric Data Testing Laboratory Qualifications: Provided by an independent agency, with the experience and capability to conduct the testing indicated, that is an NRTL as defined by OSHA in 29 CFR 1910.7, accredited under the NVLAP for Energy Efficient Lighting Products and complying with applicable IES testing standards.
- C. Provide luminaires from a single manufacturer for each luminaire type.
- D. Each luminaire type shall be binned within a three-step MacAdam Ellipse to ensure color consistency among luminaires.
- E. Installer Qualifications: An authorized representative who is trained and approved by manufacturer.
- F. Mockups: For exterior luminaires, complete with power and control connections.
 - 1. Obtain Architect's approval of luminaires in mockups before starting installations.
 - 2. Maintain mockups during construction in an undisturbed condition as a standard for judging the completed work.
 - 3. Approval of mockups does not constitute approval of deviations from the Contract Documents contained in mockups unless Architect specifically approves such deviations in writing.
 - 4. Subject to compliance with requirements, approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

1.8 DELIVERY, STORAGE, AND HANDLING

- A. Protect finishes of exposed surfaces by applying a strippable, temporary protective covering prior to shipping.

1.9 FIELD CONDITIONS

- A. Verify existing and proposed utility structures prior to the start of work associated with luminaire installation.
- B. Mark locations of exterior luminaires for approval by Architect prior to the start of luminaire installation.

1.10 WARRANTY

- A. Warranty: Manufacturer and Installer agree to repair or replace components of luminaires that fail in materials or workmanship within specified warranty period.
 - 1. Failures include, but are not limited to, the following:
 - a. Structural failures, including luminaire support components.
 - b. Faulty operation of luminaires and accessories.

c. Deterioration of metals, metal finishes, and other materials beyond normal weathering.

2. Warranty Period: 2 year(s) from date of Substantial Completion.

PART 2 - PRODUCTS

2.1 PERFORMANCE REQUIREMENTS

- A. Seismic Performance: Luminaires shall withstand the effects of earthquake motions determined according to ASCE/SEI 7.
- B. Seismic Performance: Luminaires and lamps shall be labeled vibration and shock resistant.
 - 1. The term "withstand" means "the luminaire will remain in place without separation of any parts when subjected to the seismic forces specified and the luminaire will be fully operational during and after the seismic event."

2.2 LUMINAIRE REQUIREMENTS

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a qualified testing agency, and marked for intended location and application.
- B. NRTL Compliance: Luminaires shall be listed and labeled for indicated class and division of hazard by an NRTL.
- C. FM Global Compliance: Luminaires for hazardous locations shall be listed and labeled for indicated class and division of hazard by FM Global.
- D. UL Compliance: Comply with UL 1598 and listed for wet location.
- E. Lamp base complying with ANSI C81.61.
- F. Bulb shape complying with ANSI C79.1.
- G. CRI of minimum 80. CCT of 3000 K or as indicated in fixture schedules on drawings.
- H. L70 lamp life of 50,000 hours.
- I. Lamps dimmable from 100 percent to 0 percent of maximum light output.
- J. Internal driver.
- K. Nominal Operating Voltage: as indicated in fixture schedule on drawings.
- L. In-line Fusing: On the primary for each luminaire.
- M. Lamp Rating: Lamp marked for outdoor use and in enclosed locations.

- N. Source Limitations: Obtain luminaires from single source from a single manufacturer.
- O. Source Limitations: For luminaires, obtain each color, grade, finish, type, and variety of luminaire from single source with resources to provide products of consistent quality in appearance and physical properties.

2.3 LUMINAIRE TYPES

As indicated in fixture schedule on drawings.

2.4 MATERIALS

- A. Metal Parts: Free of burrs and sharp corners and edges.
- B. Sheet Metal Components: Corrosion-resistant aluminum. Form and support to prevent warping and sagging.
- C. Doors, Frames, and Other Internal Access: Smooth operating, free of light leakage under operating conditions, and designed to permit relamping without use of tools. Designed to prevent doors, frames, lenses, diffusers, and other components from falling accidentally during relamping and when secured in operating position. Doors shall be removable for cleaning or replacing lenses.
- D. Diffusers and Globes:
 - 1. Acrylic Diffusers: 100 percent virgin acrylic plastic, with high resistance to yellowing and other changes due to aging, exposure to heat, and UV radiation.
 - 2. Glass: Annealed crystal glass unless otherwise indicated.
 - 3. Lens Thickness: At least 0.125 inch ((3.175 mm)) minimum unless otherwise indicated.
- E. Lens and Refractor Gaskets: Use heat- and aging-resistant resilient gaskets to seal and cushion lenses and refractors in luminaire doors.
- F. Reflecting surfaces shall have minimum reflectance as follows unless otherwise indicated:
 - 1. White Surfaces: 85 percent.
 - 2. Specular Surfaces: 83 percent.
 - 3. Diffusing Specular Surfaces: 75 percent.
- G. Housings:
 - 1. Rigidly formed, weather- and light-tight enclosure that will not warp, sag, or deform in use.
 - 2. Provide filter/breather for enclosed luminaires.
- H. Factory-Applied Labels: Comply with UL 1598. Include recommended lamps. Labels shall be located where they will be readily visible to service personnel, but not seen from normal viewing angles when lamps are in place.

1. Label shall include the following lamp characteristics:
 - a. "USE ONLY" and include specific lamp type.
 - b. Lamp diameter, shape, size, wattage and coating.
 - c. CCT and CRI for all luminaires.

2.5 FINISHES

- A. Variations in Finishes: Noticeable variations in same piece are unacceptable. Variations in appearance of adjoining components are acceptable if they are within the range of approved Samples and are assembled or installed to minimize contrast.
- B. Luminaire Finish: Manufacturer's standard paint applied to factory-assembled and -tested luminaire before shipping. Where indicated, match finish process and color of pole or support materials.
- C. Factory-Applied Finish for Aluminum Luminaires: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
 1. Finish designations prefixed by AA comply with the system established by the Aluminum Association for designating aluminum finishes.
 2. Natural Satin Finish: Provide fine, directional, medium satin polish (AA-M32); buff complying with AA-M20 requirements; and seal aluminum surfaces with clear, hard-coat wax.
 3. Class I, Clear-Anodic Finish: AA-M32C22A41 (Mechanical Finish: Medium satin; Chemical Finish: Etched, medium matte; Anodic Coating: Architectural Class I, clear coating 0.018 mm or thicker) complying with AAMA 611.
 4. Class I, Color-Anodic Finish: AA-M32C22A42/A44 (Mechanical Finish: Medium satin; Chemical Finish: Etched, medium matte; Anodic Coating: Architectural Class I, integrally colored or electrolytically deposited color coating 0.018 mm or thicker), complying with AAMA 611.
 - a. Color: Light bronze.
- D. Factory-Applied Finish for Steel Luminaires: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations for applying and designating finishes.
 1. Surface Preparation: Clean surfaces to comply with SSPC-SP 1, to remove dirt, oil, grease, and other contaminants that could impair paint bond. Grind welds and polish surfaces to a smooth, even finish. Remove mill scale and rust, if present, from uncoated steel, complying with SSPC-SP 5/NACE No. 1 or SSPC-SP 8.
 2. Exterior Surfaces: Manufacturer's standard finish consisting of one or more coats of primer and two finish coats of high-gloss, high-build polyurethane enamel.
 - a. Color: As selected from manufacturer's standard catalog of colors.
 - b. Color: Match Architect's sample of manufacturer's standard color.
 - c. Color: As selected by Architect from manufacturer's full range.

2.6 LUMINAIRE SUPPORT COMPONENTS

- A. Comply with requirements in Section 260529 "Hangers and Supports for Electrical Systems" for channel and angle iron supports and nonmetallic channel and angle supports.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of the Work.
- B. Examine roughing-in for luminaire electrical conduit to verify actual locations of conduit connections before luminaire installation.
- C. Examine walls, roofs, and canopy ceilings and overhang ceilings for suitable conditions where luminaires will be installed.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 TEMPORARY LIGHTING

- A. If approved by the Architect, use selected permanent luminaires for temporary lighting. When construction is substantially complete, clean luminaires used for temporary lighting and install new lamps.

3.3 GENERAL INSTALLATION REQUIREMENTS

- A. Comply with NECA 1.
- B. Use fastening methods and materials selected to resist seismic forces defined for the application and approved by manufacturer.
- C. Install lamps in each luminaire.
- D. Fasten luminaire to structural support.
- E. Supports:
 - 1. Sized and rated for luminaire weight.
 - 2. Able to maintain luminaire position after cleaning and relamping.
 - 3. Support luminaires without causing deflection of finished surface.
 - 4. Luminaire-mounting devices shall be capable of supporting a horizontal force of 100 percent of luminaire weight and a vertical force of 400 percent of luminaire weight.
- F. Wiring Method: Install cables in raceways. Conceal raceways and cables.

- G. Coordinate layout and installation of luminaires with other construction.
- H. Adjust luminaires that require field adjustment or aiming. Include adjustment of photoelectric device to prevent false operation of relay by artificial light sources, favoring a north orientation.
- I. Comply with requirements in Section 260519 "Low-Voltage Electrical Power Conductors and Cables" and 260533 "Raceways and Boxes for Electrical Systems" for wiring connections and wiring methods.

3.4 BOLLARD LUMINAIRE INSTALLATION:

- A. Align units for optimum directional alignment of light distribution.
 - 1. Install on concrete base with top 4 inches (100 mm) above finished grade or surface at luminaire location. Cast conduit into base, and shape base to match shape of bollard base. Finish by troweling and rubbing smooth. Concrete materials, installation, and finishing are specified in Section 033000 "Cast-in-Place Concrete."

3.5 INSTALLATION OF INDIVIDUAL GROUND-MOUNTED LUMINAIRES

- A. Aim as indicated on Drawings.
- B. Install on concrete base with top 4 inches (100 mm) above finished grade or surface at luminaire location. Cast conduit into base, and finish by troweling and rubbing smooth. Concrete materials, installation, and finishing are specified in Section 033000 "Cast-in-Place Concrete."

3.6 CORROSION PREVENTION

- A. Aluminum: Do not use in contact with earth or concrete. When in direct contact with a dissimilar metal, protect aluminum by insulating fittings or treatment.
- B. Steel Conduits: Comply with Section 260533 "Raceways and Boxes for Electrical Systems." In concrete foundations, wrap conduit with 0.010-inch- (0.254-mm-) thick, pipe-wrapping plastic tape applied with a 50 percent overlap.

3.7 IDENTIFICATION

- A. Identify system components, wiring, cabling, and terminals. Comply with requirements for identification specified in Section 260553 "Identification for Electrical Systems."

3.8 FIELD QUALITY CONTROL

- A. Inspect each installed luminaire for damage. Replace damaged luminaires and components.

- B. Perform the following tests and inspections with the assistance of a factory-authorized service representative:
 - 1. Operational Test: After installing luminaires, switches, and accessories, and after electrical circuitry has been energized, test units to confirm proper operation.
 - 2. Verify operation of photoelectric controls.
- C. Illumination Tests:
 - 1. Measure light intensities at night. Use photometers with calibration referenced to NIST standards. Comply with the following IES testing guide(s):
 - a. IES LM-5.
 - b. IES LM-50.
 - c. IES LM-52.
 - d. IES LM-64.
 - e. IES LM-72.
 - 2. Operational Test: After installing luminaires, switches, and accessories, and after electrical circuitry has been energized, test units to confirm proper operation.
- D. Luminaire will be considered defective if it does not pass tests and inspections.
- E. Prepare a written report of tests, inspections, observations, and verifications indicating and interpreting results. If adjustments are made to lighting system, retest to demonstrate compliance with standards.

3.9 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain luminaires and photocell relays.

3.10 ADJUSTING

- A. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion, provide on-site assistance in adjusting the direction of aim of luminaires to suit occupied conditions. Make up to two visits to Project during other-than-normal hours for this purpose. Some of this work may be required during hours of darkness.
 - 1. During adjustment visits, inspect all luminaires. Replace lamps or luminaires that are defective.
 - 2. Parts and supplies shall be manufacturer's authorized replacement parts and supplies.
 - 3. Adjust the aim of luminaires in the presence of the Architect.

END OF SECTION 265619