

FDC

SYSTEM TYPE

Address and Street

System – XXX PSI

FDC Sign Specifications

1. Sign sizes to fit required lettering height and stroke.
2. Sign stock shall be .08 gauge, reflectorized aluminum.
3. All lettering shall be white reflective on red reflective background.
4. "FDC" lettering shall be 3 inches in height with a ½ inch paint stroke
5. System type lettering shall be 1 ½ inches in height with a ¼ inch paint stroke
 - a. System types as follows:
 - "Auto Sprinkler" for fire sprinkler system
 - "Deluge System" for deluge system
 - "Dry Standpipe" for dry standpipe system
 - "Wet Standpipe" for wet standpipe system
 - "Combination Standpipe" for combination wet standpipe and fire sprinkler system
6. Address and Street lettering shall be 1 ½ inches in height with a ¼ inch paint stroke
7. **Include System PSI on the sign for pump systems only.** **System PSI lettering is to be the system pressure the fire protection system is designed to.** Lettering shall be 1 ½ inches in height with a ¼ brush stroke.
8. Sign shall be mounted by the following:
 - a. On a sign post with the bottom of the sign a minimum 5 feet from grade, or
 - b. If the FDC is mounted on or next to a structure, attached to the structure above the FDC